

STUDY

# **DELTA COLLEGE**

## **FACILITIES CONDITION ASSESSMENT**

---



DSD Project No. 20-0501

September 30, 2020

STUDY  
FOR THE  
DELTA COLLEGE  
FACILITIES CONDITION ASSESSMENT

---

UNIVERSITY CENTER, MICHIGAN

Prepared by:

DiCLEMENTE SIEGEL DESIGN INC.  
28105 GREENFIELD ROAD  
SOUTHFIELD, MICHIGAN 48076

DSD Project No. 20-0501.00

OWNER PROGRESS REVIEW  
September 30, 2020

## TABLE OF CONTENTS

<u>TAB</u>		<u>PAGE</u>
I	EXECUTIVE SUMMARY.....	1
II	INTRODUCTION.....	5
III	BUILDING ANALYSIS .....	6

## **EXECUTIVE SUMMARY**

## **EXECUTIVE SUMMARY**

This study documents the Main Building, Utility Building, Maintenance Building, Farm buildings and Planetarium, by area utilizing a brief narrative study, detailed spreadsheets and a drawing package for equipment locations. The three components (Narrative Study, Spreadsheets and Drawings) of this study are to function to assist with maintenance planning, however the spreadsheet is the primary tool.

The spreadsheet lists the equipment and building systems along with the observed condition and estimated age of each item. Industry standards are used to determine estimated standard life and the remaining approximate service life is listed. The deficiencies and concerns identified are then prioritized based on age, condition and an evaluation of the impact of a failure.

Overall, where concerns were found, they were primarily due to the age of the systems in question. Everything was found to be in well maintained condition for its age and use. There are however many building components that are beyond their normal service life and in need of attention.

From a Site standpoint, the parking lots are in need of an overall topcoat and resurfacing, there are several structures that need repair before the resurfacing. There are several areas where ADA egress is inhibited by sidewalk heaving or cracking.

The architectural concerns identified in this study generally are identified as exterior door condition and hardware configuration, building exterior wall crack and repair, corrosion on window frames and doors and a generally aging finishes such as flooring, millwork and ceiling tiles.

Mechanically, the concerns are centered around aging air handling systems including inefficient multizone units that should be considered for replacement. There are also several pieces of hydronic equipment including heat exchangers, circulating pumps and condensate return pumps that are beyond their service life and likely to cause high maintenance attention if not replaced. The primary energy plant serving the campus is in generally good condition and is well maintained. One newer boiler should be considered to increase the system reliability and efficiency as the main boilers age. The cooling towers are beyond their normal service life and should be systematically replaced or rebuilt in order to increase the campus cooling system reliability.

Electrically, there is evidence of a systematic conversion to LED lighting. Although many areas still have fluorescent fixtures and some minor areas of incandescent fixtures, however, fluorescent and incandescent fixtures have been retrofitted with LED lamps. Lighting control is achieved through occupancy/daylight sensors and building control systems.

Some electrical panels and substations in the building are original and beyond normal service life, however, they are maintained well and serviced accordingly. Panels and equipment that are 50+ years old should be planned on replacement in the near future.

The fire alarm systems installed through most areas are over 20 years old and should be planned on being replaced in the near future.

Several conditions arose out of building discussions for future improvements needed to the campus:

The Planetarium Chiller is in need of replacement due to a combination of age and problems experienced with the chiller, the chiller is to be replaced. Along with the chiller replacement, the pumps should be replaced and pump accessories (valves, strainers, etc.). Consideration for the addition of a buffer tank to reduce short-cycling of the compressors during light loads should also be included.

The pool equipment room has a high level of humidity and aerated chlorine in the air. A dedicated ventilation system including outdoor air and exhaust air should be added to reduce the concentration and its corrosion impact on items within the room.

The campus uses an outdoor water tower for domestic and fire protection water supply. The tower is connected to the piping that loops the campus. Because of the piping arrangement, on a daily basis the filling of the tower causes a water shortage in the campus loop. The tower is filled by pressure booster pumps that draw their water from the same main that feeds the tower and feeds the campus. The piping system should be studied to determine what modifications would be necessary to allow for simultaneous filling of the pump while maintaining pressure on the campus loop.

The kitchen serving the campus utilizes a grease separation system for addressing cooking grease to protect the sanitary piping system, as is required by the Michigan Plumbing Code. The initial design of the system had a warming system to re-liquify the grease and pump it to a tank. The heaters have failed and were generally unreliable from the initial installation forcing the college to hire a sanitary pumping service to pump out the holding tank. Because the system was not designed for this approach, the location for the pumping access points and the configuration of the system make this a difficult process. Consideration to study the system further to either replace the heating/pumping system or make the access point more accessible should be undertaken.

The present wood dust collector is beyond normal service life and although it is functioning, it should be reconditioned for efficiency and effectiveness. Along with the review, consideration can be given to recycling the clean air or applying energy recovery in order to improve campus energy consumption.

Portions of the campus utilized grooved couplings for the heating hot water system. This is often applied because it is generally more efficient to install in an existing system than welding for larger pipes. The campus has been experiencing seasonal leaks in the system as the system is cooled down and then rewarmed for the next season. The leaking is due to normal wear on the system at the couplings, however, the unpredictable nature of the leaks causes significant damage to ceiling tiles. During each renovation of an area, the piping or piping joints should be replaced to avoid future problems in renovated areas.

The structural support for exterior piping at the chilled water ice storage equipment is showing significant signs of rust. A full scraping and galvanizing of the piping should be considered. The existing cooling towers are performing well and there is a stand-by tower in the system, however because the campus is

dependent on the system, the N+1 nature of the tower system should be maintained. Reconditioning of the tower should be considered.

The water service to the “Farmhouse” portion of the campus comes from the main campus. The unusually long run of the piping has been a significant source of maintenance problems each year due to the elevational changes in the piping and distance. Because the meeting-use of the farmhouse area, maintaining the larger water service is appropriate. Further study should be undertaken to determine if a deeper installation (below frost) is needed, alternative materials should be considered or a dedicated water service for the farmhouse is most appropriate.

The F-Wing of the main campus building has been experienced footing drain clogs causing backups within the building. There are piping irregularities at the southwestern most corner of this piping contributing to the problem that should be addressed through replacement or rerouting.

## **INTRODUCTION**

## INTRODUCTION

The purpose of this study is to provide a conditional assessment of the Delta College buildings and campus. It is to provide an overview of the architectural, structural, mechanical, plumbing, electrical and low voltage systems of the buildings, their condition and establish a prioritized means for system replacement and upgrade. The buildings consist of the following:

DELTA COLLEGE	ADDRESS	SQUARE FEET	Yr. BUILT
Planetarium & Science Center	100 Center Ave, Bay City, MI	39204	1996
A Wing	1961 Delta Road, University Center, MI	153406	1961
B Wing	1962 Delta Road, University Center, MI	25413	1961
C Wing - Administration	1963 Delta Road, University Center, MI	39773	1961
D-Wing	1964 Delta Road, University Center, MI	40323	1968
E Wing	1965 Delta Road, University Center, MI	28392	1978
F Wing (Health Professions)	1966 Delta Road, University Center, MI	93387	1978
G Wing	1967 Delta Road, University Center, MI	20698	1961
H Wing	1968 Delta Road, University Center, MI	11630	1961
J Wing	1969 Delta Road, University Center, MI	27156	1962
K Wing	1970 Delta Road, University Center, MI	16247	1961
L Wing	1971 Delta Road, University Center, MI	35072	1961
M Wing	1972 Delta Road, University Center, MI	70799	1968
N Wing	1973 Delta Road, University Center, MI	126073	1961
P Wing	1974 Delta Road, University Center, MI	117702	1979
S Wing (Fine Arts)	1975 Delta Road, University Center, MI	79545	1972
Z Wing (Power House)	1976 Delta Road, University Center, MI	14066	1961
Grounds Maintenance	Delta Road, University Center, MI	8400	1968
Grounds Maintenance Storage	Delta Road, University Center, MI	1792	1984
Grounds Maintenance Storage	Delta Road, University Center, MI	4224	2009
Grounds Maintenance Storage	Delta Road, University Center, MI	2772	2009
Transmitter 1	Delta Road, University Center, MI	1025	1981
Transmitter 2	Delta Road, University Center, MI	860	1964
Satelite Ground Terminal	Delta Road, University Center, MI	100	1964
TV Tower	Delta Road, University Center, MI	450	1964
Water Tower	Delta Road, University Center, MI	1362	1960
Water Meter Building	Delta Road, University Center, MI	408	2004
Farm House	Delta Road, University Center, MI	9064	1870
Farm Barn	Delta Road, University Center, MI	7900	1881
Farm Shed	Delta Road, University Center, MI	1020	1890
Farm Tool Shed	Delta Road, University Center, MI	1320	1930
Farm Pavilion	Delta Road, University Center, MI	960	1984

## **BUILDING ANALYSIS**

## BUILDING ANALYSIS

The composite building consists of Wings sixteen wings, lettered A through P (skipping I and O), but including S and Z. All the wings are connected at the main level but also include some interconnecting utility tunnels. The wings have some separation by Colleges. Four additional building areas, Facilities, Grounds, the Farm area and a remote Planetarium were also included in the study. Altogether, the areas studied include almost one million square feet. The building construction generally ranges from 1960 to present, with exception of the historical farms were which were constructed in 1870, 80 and 90. The objective of this study is to establish maintenance and building planning in the coming decade as well as to outline general condition.

As an architectural overview, the buildings are generally in good condition. With exception of some cracking of exterior walls, all of the features of the building are in good condition relative to their age and material type but are showing signs of aging. The parking lots, generally asphalt, are in need of resurfacing along with considerable patching.

**Exterior walls:** The exterior walls of the building have areas within every wing where cracks have formed. In some areas the cracks are more significant and should receive immediate attention. Other areas are minor fractures where infill and caulking is needed and then a schedule should be established for regular review to determine the crack growth and expansion.

The roof of the building is under a regular maintenance program and has received ongoing attention. The roofing repairs and replacements have been systematic and have generally left the roofs in good condition due to the vigilant approach to maintenance.

Exterior doors and windows are one of the areas where age is showing. There is considerable corrosion on the windows and doors with some reaching a point of infiltration and water penetration into the buildings. In most cases, minor repairs and preventive maintenance should be applied. Generally speaking, window replacement is never financed in a reasonable amount of time by the energy savings, however, in any major renovation window replacement should be reviewed and strongly considered. Exterior door and door hardware, however, is a significant issue around the building and a replacement program should be considered, methodically

addressing those doors in the worse condition and allowing infiltration in the most vulnerable areas.

Generally, the interior of the building, with exception of recently renovated areas, is showing signs of age. Although well kept and in good condition for its age, the carpet, ceiling tiles and mill work should each be refreshed. In any renovation project, these systems should be upgraded, however a phased prioritized systematic approach to their upgrade should also be planned to allow for a continuous refreshing of the building. Similarly, systematic painting of the non-wood surfaces should be considered, especially in high traffic areas.

There are several areas where door hardware should be replaced and upgraded to present code requirements to allow better building egress. This condition exists primarily in the exterior doors (which would be addressed during the envelope walk).

In the auditorium area, there are ADA slope issues that should be addressed in order to allow for a more accessible building.

Mechanically, the building is sound and, again, well maintained. There is not evidence of significant leakage or poorly maintained equipment and there are many pieces of equipment that are in good appearance for their age. There are, however quite a few multizone air handling units that are beyond their normal service life and should be scheduled for replacement. The replacement systems should be more efficient air-side systems to allow for indoor air quality measurement and meet present and upcoming ventilation standards while providing variable volume efficiency for a reduced motor and heat/cool energy footprint. These conditions occur in several wings of the building.

The second predominant issue with the mechanical systems are heat exchangers and pumps. There are several hydronic pumps that are beyond service life and in need of replacement. Similarly, there are non-redundant heat exchangers that should be considered for systematic replacement to avoid a loss of heat in various areas of the building. Because of the multizone/reheat nature of the building, loss of these systems will result in pockets or wings of the building with discomfort in the event of a failure.

The cooling towers in the power plant are beyond their normal service life and should be considered for systematic replacement or rebuilding with pan, fill and control replacement.

The boilers are at the end of normal service life, however with routine 20 year maintenance, they can continue life serving the building. Because of their life, however one new boiler should be considered to increase the system reliability. Many of the supporting equipment components have been replaced. There are, however, out in the wings of the building, steam-condensate units that are beyond normal service life and should receive pump replacement or entire unit replacement. There is evidence of a systematic approach to the replacement of these, found by several wings having new or relatively new equipment.

The terminal heating equipment (cabinet heaters and unit ventilators) are generally original throughout the areas they serve and should be systematically replaced in order to avoid a high maintenance requirement in the future. Most of this equipment is 25-50+ years old.

The plumbing fixtures in the building are mostly original. Although water saving fixtures are generally not recommended in existing systems of this age due to poor flow conditions in the sanitary piping, touch free technology can be introduced in order to provide more reliable and regular flushing while maintaining sanitary conditions.

Electrically, the buildings are in generally very good condition. Although some equipment is beyond normal service life it is well maintained and functioning well.

The lighting in the buildings are mostly fluorescent, however there are pockets of LED lighting throughout. Any future renovation should include replacement of fluorescent fixtures with LED. Lighting controls have been systematically replaced with occupancy and daylighting technology. Building emergency and egress lighting should be tested regularly, (power was not turned off during this study to test emergency fixtures). Parking Lot lighting has been converted to LED with some minor exceptions, including Hodgkin's Drive, which is still utilizing H.I.D. fixtures.

Most of the panel boards in the building are original and generally beyond industry normal service life, however it is rare to replace electrical panels due to age, except where replacement parts cannot be obtained. There are, however several panels and load centers that are in

excess of 50 years old and are recommended to be replaced. In any renovation of a wing or large area that encompass an electrical panels area of service, the panel should be replaced to avoid less convenient replacement in the future at equipment failure. Where panels are replaced, the accompanying transformers, where applicable, should also be replaced.

There are areas where the electrical service area clearances have been violated at electrical panels and equipment. In particular, the original unit substations do not meet current code requirements for rear egress.

Electrical equipment, including substations and panel boards, in the pool equipment room, P020, are showing signs of external corrosion due to the room's chlorinated atmospheric condition. Methods of remediation should be considered.

Underground conduit in A-Wing are also showing signs of corrosion and consideration should be given to remedy this.

A systematic fire alarm replacement and upgrade should be considered due to the age of the system and changing code requirements for sound levels and synchronization. Currently, replacement heat detectors are not available.

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>ROOFING</b>																		
													1	Ea.				
<b>EXTERIOR ELEMENTS</b>																		
													1	Ea.				
<b>INTERIORS</b>																		
A Wing			Lower Level															
	<u>Mechanical Room &amp; Tunnels</u>																	
		Ceilings (Exposed)		X				50+		No leaking from above indentified.			Ea.					x
		Floors (Concrete)		X				50+		Floors show wear and cracking.			Ea.					x
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks indentified.			Ea.					x
		Doors (H.M.)			X		30			Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.			Ea.	x				
	<u>Corridors</u>																	
		Ceilings (Act 2 x 2)		X			20						Ea.					x
		Ceilings (Act 1 x 1)		X			20						Ea.					x
		Ceilings (Gyp. bd.)		X			50+						Ea.					x
		Doors (H.M.)		X			30											x
		Steel Columns			X		50+			Columns show rusting at base			Ea.		x			
		Floors (Vct)		X			25			As VCT is replaced where worn, the color is a fair match. Missing appropriate expansion joint covers in some locations.			Ea.					x
		Walls (Brick)		X			50 +			All tile or resilient base has been removed.			Ea.					x
		Walls (Gyp. Bd.)					50 +						Ea.					x
		Windows (Aluminum)			X		30			Sealant/ weatherstripping requires replacement in some areas. Glass is in good condition. No signs of cracking.			Ea.	x	x			
	<u>Conference Rooms / Offices</u>												Ea.					
		Ceilings (Act 2 x 2)			X		20			Minor water staining throughout.			Ea.		x			
		Floors (Carpet)			X		10			Carpet is fading in areas wear furniture has been moved or at high volume circulation locations.			Ea.		x			
		Walls (Gyp. Bd.)		X			50 +						Ea.					x
		Doors (H.M. / Wood)		X			30						Ea.					x
		Windows		X			30			Same as Corridors, life expectancy if a sealer is approximately 5 years			Ea.					x
		Millwork (P.lam)		X			20			Appearance is dated but no signs of wear.			Ea.					x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.							x
		Floors (Ceramic Tiles)		X			20		Ea.							x
		Walls (Ceramic Tile)		X			20		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Millwork (S.S.)		X			30		Ea.							x
		Janitor Closets					20		Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Epoxy / Exposed)		X			10	Floors require painting.	Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)			X		30	Frames rusting at floor.	Ea.			x				
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Carpet/ VCT)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M. / Wood)		X			50 +		Ea.							x
A Wing		First Level														
		Corridors							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Ceilings (Act 1 x 1)		X			20		Ea.			x				
		Ceilings (Gyp. bd.)		X			50+		Ea.			x				
		Doors (H.M.)		X			30		Ea.			x				
		Steel Columns			X		50+	Coulmns show rusting at base	Ea.			x				
		Floors (Vct)		X			25	As VCT is replaced where worn, the color is a fair match. Missing appropriate expansion joint covers in some locations.	Ea.			x				
		Walls (Brick)		X			50 +	All tile or resilient base has been removed.	Ea.			x				
		Walls (Gyp. Bd.)			X		50 +		Ea.			x				
		Windows (Aluminum)			X		30	Sealant/ weatherstripping requires replacement in some areas. Glass is in good condition. No signs of cracking.	Ea.			x				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Library								Ea.						
		Ceilings (Act 2 x 2)		X			20	Minor water staining throughout.		Ea.			x			
		Floors (Carpet)		X			10	Carpet is fading in areas wear furniture has been moved. Some rooms are currently being upgraded.		Ea.			x			
		Walls (Block / Dry Wall)		X			50+	Uneven painting and unfinished wall repair. Some rooms are currently being upgraded.		Ea.			x			
		Doors (H.M. / Wood)		X			30	Frames have rusting at floor.		Ea.			x			
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (Plam)		X			20	Appearance is dated but no signs of wear.		Ea.			x			
		Break Area								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.			x			
		Floors (Vinyl sheet / Tile)		X			25			Ea.			x			
		Walls (Brick)		X			50+			Ea.			x			
		Windows (Aluminum)		X			30	Sealant/ weatherstripping requires replacement in some areas. Glass is in good condition. No signs of cracking.		Ea.			x			
		Millwork (Plam)		X			20			Ea.			x			
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)		X			20	Minor water staining throughout.		Ea.			x			
		Floors (Carpet)		X			10	Carpet is fading in areas wear furniture has been moved at high volume circulation locations.		Ea.			x			
		Walls (Gyp. Bd.)		X			50+			Ea.			x			
		Doors (H.M. / Wood)		X			30			Ea.			x			
		Windows (H.M. )		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (Plam)		X			20	Appearance is dated but no signs of wear.		Ea.			x			
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.			x			
		Floors (Ceramic Tiles)		X			20			Ea.			x			
		Walls (Ceramic Tile)		X			20			Ea.			x			
		Doors (H.M. / Wood)		X			30			Ea.			x			
		Millwork (S.S.)		X			30			Ea.			x			
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.			x			
		Floors (Epoxy / Exposed)		X			10	Floors require painting.		Ea.			x			
		Walls (Block / Dry Wall)		X			50+			Ea.			x			
		Doors (H.M.)		X			30	Frames rusting at floor.		Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities					
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required		

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Classrooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.						x	
		Floors (Carpet)		X			10		Ea.						x	
		Walls (Block / Dry Wall)		X			50+		Ea.						x	
		Doors (H.M. / Wood)		X			30		Ea.						x	
		Windows		X			30	Life expectancy of a sealer is approximately 5 years.	Ea.						x	
		Millwork		X				Appearance is dated but no signs of wear.	Ea.						x	
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.						x	
		Floors (Carpet/ VCT)		X			20		Ea.						x	
		Walls (Block / Dry Wall)		X			50+		Ea.						x	
		Doors (H.M. / Wood)		X			30		Ea.						x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
A Wing			Second Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 4)		X			20			Ea.						x
		Ceilings (Gyp. bd.)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Floors (Vct)		X			25	As VCT is replaced where worn, the color is a fair match. Missing appropriate expansion joint covers in some locations.		Ea.						x
		Walls (Brick)		X			50 +	All tile or resilient base has been removed.		Ea.						x
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.						x
		Floors (Ceramic Tiles)		X			20			Ea.						x
		Walls (Ceramic Tile)		X			20			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.						x
		Floors (Epoxy / Exposed)		X			10	Floors require painting.		Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Classrooms								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.						x
		Floors (Carpet)		X			10			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Windows		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Storages								Ea.						
		Ceilings (Exposed)		X						Ea.						x
		Floors (Carpet/ VCT)		X			20			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
A Wing		Elevator			X					Walls, floor, and ceiling worn from use.	1	Ea.			x			
		Stairs (Terrazzo)		X				50+		Anti-slip rubber treads may be considered to be added.	4	Ea.			x			
<b>INTERIORS</b>																		
B Wing			Lower Level															
	<u>Mechanical Room &amp; Tunnels</u>																	
		Ceilings (Exposed)		X				50+		No leaking from above indentified.		Ea.				x		
		Floors (Concrete)		X				50+		Floors show wear and cracking.		Ea.				x		
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks indentified.		Ea.				x		
		Doors (H.M.)				X		30		Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.		Ea.	x					
	<u>Storage</u>											Ea.						
		Ceilings (Exposed)		X				50+		No leaking from above indentified.		Ea.				x		
		Floors (concrete)		X				50+		Floors show wear and cracking.		Ea.				x		
		Walls (Block /Concrete)		X				50+		Minimal/ to no cracking. No leaks indentified.		Ea.				x		
		Doors (H.M.)		X				30				Ea.				x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
B Wing			First Level															
		Corridors																
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Carpet)		X				20				Ea.					x	
		Walls (Block / Dry Wall)		X				25				Ea.					x	
		Doors (H.M. / Wood)		X				30				Ea.					x	
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.		Ea.					x	
		Conference Rooms / Offices										Ea.						
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Carpet)		X				20				Ea.					x	
		Walls (Block / Dry Wall)		X				50+				Ea.					x	
		Doors (Wood)		X				30				Ea.					x	
		Windows (Aluminum )		X				30		Where applicable. Life expectancy of a sealant is 5 years		Ea.					x	
		Toilet Rooms										Ea.						
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Ceramic Tiles)		X				20				Ea.					x	
		Walls (Ceramic Tiles)		X				20				Ea.					x	
		Doors (H.M.)		X				30				Ea.					x	
		Janitor Closets										Ea.						
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Vct)		X				25				Ea.					x	
		Walls (Block)		X				50+				Ea.					x	
		Doors (H.M.)		X				50 +				Ea.					x	
		Storages										Ea.						
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Carpet)		X				20				Ea.					x	
		Walls (Block / Dry Wall)		X				50+				Ea.					x	
		Doors (Wood)		X				30				Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
C Wing			Lower Level															
		Mechanical Room & Tunnels																
		Ceilings (Exposed)		X				50+		No leaking from above indentified.		Ea.					x	
		Floors (Concrete)		X				50+		Floors show wear and cracking.		Ea.				x		
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks indentified.		Ea.				x		
		Doors (H.M.)			X			30		Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.		Ea.		x				
C Wing			First Level															
		Corridors																
		Ceilings (Act 2 x 4)		X				20		Minor water staining throughout.		Ea.			x			
		Floors (Vct)		X				30				Ea.			x			
		Walls (Block / Dry Wall)		X				50+				Ea.			x			
		Doors (H.M.)			X			30		Frames showing rust at floor.		Ea.		x				
		Classrooms										Ea.						
		Ceilings (Act 2 x 4)		X				20				Ea.			x			
		Floors (Carpet)		X				20				Ea.			x			
		Walls (Block / Dry Wall)			X			50+		Crack in wall all the way appears in the floor		Ea.	x					
		Doors (H.M.)			X			30		Frames showing rust at floor.		Ea.		x				
		Windows (Aluminum)						30		Life expectancy of a sealer is approximately 5 years.		Ea.		x				
		Labs										Ea.						
		Ceilings (Act 2 x 4)		X				20				Ea.			x			
		Floors (Vct)		X				30				Ea.			x			
		Walls (Block / Dry Wall)		X				50+				Ea.			x			
		Doors (H.M.)			X			30		Frames showing rust at floor.		Ea.		x				
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (P.lam)		X				30		Appearance is dated but no signs of wear.		Ea.			x			
		Toilet Rooms						20				Ea.						
		Ceilings (Gypsum)		X				50+				Ea.			x			
		Floors (Ceramic Tiles)		X				30				Ea.			x			
		Walls (Ceramic Tile)		X				30				Ea.			x			
		Doors (H.M.)			X			30		Frames showing rust at floor.		Ea.		x				
		Millwork (P.lam)		X				20				Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets									Ea.							
		Ceilings (Exposed)		X				50+			Ea.						x	
		Floors (Epoxy / Exposed)		X				50+			Ea.						x	
		Walls (Block / Dry Wall)		X				50+			Ea.						x	
		Doors (H.M.)			X			30		Frames showing rust at floor.	Ea.			x				
		Storages									Ea.							
		Ceilings (Act 2 x 4)		X				20			Ea.						x	
		Floors (Vct)		X				30			Ea.						x	
		Walls (Block / Dry Wall)		X				50+			Ea.						x	
		Doors (H.M.)			X			30		Frames showing rust at floor.	Ea.			x				
<b>INTERIORS</b>																		
D Wing			Lower Level															
		Mechanical Room/ Tunnels									Ea.							
		Ceilings (Exposed)		X				50+		No leaking from above indentified.	Ea.						x	
		Floors (Concrete)		X				50+		Floors show wear and cracking.	Ea.						x	
		Walls (Block / Concrete)		X				50 +		Minimal/ to no cracking. No leaks indentified.	Ea.						x	
		Doors (H.M.)				X		30		Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.	Ea.	x						

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
D Wing			First Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 4)		X			20	Minor water staining throughout.		Ea.						x
		Floors (Vct)		X			30			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			
		Classrooms								Ea.						
		Ceilings (Act 2 x 4)		X			20			Ea.						x
		Floors (Carpet)		X			20			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			
		Windows (Aluminum)					30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Labs								Ea.						
		Ceilings (Act 2 x4)		X			20			Ea.						x
		Floors (Vct)		X			30			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.		Ea.						x
		Toilet Rooms					20			Ea.						
		Ceilings (Gypsum)		X			50+			Ea.						x
		Floors (Ceramic Tiles)		X			30			Ea.						x
		Walls (Ceramic Tile)		X			30			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			
		Millwork (P.lam)		X			20			Ea.						x
		Janitor Closets								Ea.						
		Ceilings (Exposed)		X			50+			Ea.						x
		Floors (Epoxy / Exposed)		X			50+			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			
		Storage								Ea.						
		Ceilings (Act 2 x 4)		X			20			Ea.						x
		Floors (Vct)		X			30			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)			X		30	Frames showing rust at floor.		Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
D Wing			Second Level															
		Mechanical Room/ Tunnels											Ea.					
		Ceilings (Exposed)		X				50+					Ea.				x	
		Floors (Concrete)		X				50+					Ea.				x	
		Walls (Block / Concrete)		X				50 +					Ea.				x	
		Doors (H.M.)				X		30					Ea.	x				
VERTICAL AND HORIZONTAL TRANSPORTATION																		
D Wing													Ea.					
		Stairs (concrete)			X			50 +		Stair nosings damaged.	3	Ea.	x					
INTERIORS																		
E Wing			Lower Level															
		Mechanical Room & Tunnels																
		Ceilings (Exposed)		X				50+		No leaking from above indentified.		Ea.					x	
		Floors (Concrete)		X				50+		Floors show wear and cracking.		Ea.				x		
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks indentified.		Ea.				x		
		Doors (H.M.)				X		30		Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.		Ea.	x					
E Wing			First Level															
		Corridors											Ea.					
		Ceilings (Act 2 x 4)		X				20		Minor water staining throughout.		Ea.				x		
		Floors (Vct)		X				30				Ea.				x		
		Walls (Block / Dry Wall)		X				50+				Ea.				x		
		Doors (H.M.)				X		30		Frames showing rust at floor.		Ea.		x				
		Classrooms											Ea.					
		Ceilings (Act 2 x 4)		X				20				Ea.				x		
		Floors (Carpet)		X				20				Ea.				x		
		Walls (Block / Dry Wall)		X				50+				Ea.				x		
		Doors (H.M.)				X		30		Frames showing rust at floor.		Ea.		x				
		Windows (Aluminum)						30		Life expectancy of a sealer is approximately 5 years.		Ea.				x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concern and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
	Labs								Ea.							
	Ceilings (Act 2 x4)			X			20		Ea.							x
	Floors (Vct)			X			30		Ea.							x
	Walls (Block / Dry Wall)			X			50+		Ea.							x
	Doors (H.M.)				X		30	Frames showing rust at floor.	Ea.			x				
	Windows (Aluminum)			X			30	Life expectancy of a sealer is approximately 5 years.	Ea.							x
	Millwork (P.lam)			X			30	Appearance is dated but no signs of wear.	Ea.							x
	Toilet Rooms						20		Ea.							
	Ceilings (Gypsum)			X			50+		Ea.							x
	Floors (Ceramic Tiles)			X			30		Ea.							x
	Walls (Ceramic Tile)			X			30		Ea.							x
	Doors (H.M.)				X		30	Frames showing rust at floor.	Ea.			x				
	Millwork (P.lam)			X			20		Ea.							x
	Janitor Closets								Ea.							
	Ceilings (Exposed)			X			50+		Ea.							x
	Floors (Epoxy / Exposed)			X			50+		Ea.							x
	Walls (Block / Dry Wall)			X			50+		Ea.							x
	Doors (H.M.)				X		30	Frames showing rust at floor.	Ea.			x				
	Storage								Ea.							
	Ceilings (Act 2 x 4)			X			20		Ea.							x
	Floors (Vct)			X			30		Ea.							x
	Walls (Block / Dry Wall)			X			50+		Ea.							x
	Doors (H.M.)				X		30	Frames showing rust at floor.	Ea.			x				
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																
E Wing									Ea.							
	Stairs (Concrete)				X		50 +	Stair nosings damaged.	3	Ea.	x					

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
F Wing - Allied Health			Lower Level															
		Corridors											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Vct)		X				25					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M. / Wood)		X				30					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Classrooms											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Carpet)		X				10					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M. / Wood)		X				30					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Labs											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Vinyl sheet / Tile)		X				25					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M. / Wood)		X				30					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Conference Rooms / Offices											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Carpet)		X				10					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M. / Wood)		X				30					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Toilet Rooms											Ea.					
		Ceilings (Gypsum)		X				50					Ea.					x
		Floors (Ceramic Tiles)		X				50 +					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M. / Wood)		X				30					Ea.					x
		Millwork (P.lam)		X				20					Ea.					x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Epoxy / Exposed)		X			15	Cracks developed at certain areas	Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Dental Clinic / X-Ray Rooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Carpet)		X			10		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			20		Ea.							x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years	Ea.							x
		Millwork (Plam)		X			20		Ea.							x
		Storage							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors		X					Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area:	899,682 SF
No. of Floors:	3
Year Built:	1961
Year Renovated:	Various -- see A001, A002 and A003
Evaluated:	First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
F Wing - Allied Health			First Level															
		Corridors										Ea.						
		Ceilings (Act 2 x 2)		X					20			Ea.					x	
		Floors (Vct)		X					25			Ea.					x	
		Walls (Block / Dry Wall)		X					50 +			Ea.					x	
		Doors (H.M. / Wood)		X					30			Ea.					x	
		Windows (Aluminum)		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.					x	
		Classrooms										Ea.						
		Ceilings (Act 2 x 2)		X					20			Ea.					x	
		Floors (Carpet)		X					10			Ea.					x	
		Walls (Block / Dry Wall)		X					50 +			Ea.					x	
		Doors (H.M. / Wood)		X					30			Ea.					x	
		Windows (Aluminum)		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.					x	
		Millwork (P.lam)		X					20			Ea.					x	
		Labs										Ea.						
		Ceilings (Act 2 x 2)		X					20			Ea.					x	
		Floors (Vinyl sheet / Tile)		X					25			Ea.					x	
		Walls (Block / Dry Wall)		X					50 +			Ea.					x	
		Doors (H.M. / Wood)		X					30			Ea.					x	
		Windows (Aluminum)		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.					x	
		Millwork (P.lam)		X					20			Ea.					x	
		Conference Rooms / Offices										Ea.						
		Ceilings (Act 2 x 2)		X					20			Ea.					x	
		Floors (Carpet)		X					10			Ea.					x	
		Walls (Block / Dry Wall)		X					50 +			Ea.					x	
		Doors (H.M. / Wood)		X					30			Ea.					x	
		Windows (Aluminum)		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.					x	
		Millwork (P.lam)		X					20			Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50		Ea.							x
		Floors (Ceramic Tiles)		X			50 +		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Millwork (P.lam)		X			20		Ea.							x
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Epoxy / Exposed)		X			15	Cracks developed at certain areas	Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Dental Clinic / X-Ray Rooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Carpet)		X			10		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			20		Ea.							x
		Windows (Aluminum)		X			30	Life span of a sealer is approximately 5 years	Ea.							x
		Millwork (P.lam)		X			20		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors		X					Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Locker Rooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors		X					Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Millwork (P.lam)		X			20		Ea.							x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
F Wing - Allied Health			Second Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.						x
		Floors Vct		X			25			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30			Ea.						x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Classrooms								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.						x
		Floors (Carpet)		X			10			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30			Ea.						x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Labs								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.						x
		Floors (Vinyl sheet / Tile)		X			25			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30			Ea.						x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.						x
		Floors (Carpet)		X			10			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30			Ea.						x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50			Ea.						x
		Floors (Ceramic Tiles)		X			50 +			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30			Ea.						x
		Millwork (P.lam)		X			20			Ea.						x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Epoxy / Exposed)		X			15	Cracks developed at certain areas	Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
		Dental Clinic / X-Ray Rooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Carpet)		X			10		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			20		Ea.							x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years	Ea.							x
		Millwork (Plam)		X			20		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M. / Wood)		X			30		Ea.							x
									Ea.							
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																
F Wing - Allied Health									Ea.							
	Elevator															
				X						1	Ea.					x
		Stairs (Terrazzo)		X						4	Ea.					x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
G Wing			First Level															
		Corridors											Ea.					
		Ceilings (Act 2 x 4)		X				20					Ea.					x
		Floors (Vct)		X				25					Ea.					x
		Walls (Brick)		X				50 +					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Classrooms											Ea.					
		Ceilings (Act 2 x 4)		X				20					Ea.					x
		Floors (Vct)		X				25					Ea.					x
		Walls (Block / Dry Wall)		X				50 +					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Windows (Aluminum)		X				30					Ea.					x
		Millwork (P.lam)		X				20		Appearance is dated but no signs of wear.			Ea.					x
		Auditorium											Ea.					
		Ceilings (Gyp. Bd.)		X				20					Ea.					x
		Floors (Carpet)			X			10		Floor slope exceeds ADA requirements.			Ea.		x			
		Walls (Brick / Dry Wall)		X				50 +					Ea.					x
		Stage (Wood/ carpet)		X				10					Ea.					x
		Seating			X			10		Worn but still operable.						x		
		Doors (H.M.)		X				30					Ea.					x
		Conference Rooms / Offices											Ea.					
		Ceilings (Act 2 x 2)		X				10					Ea.					x
		Floors (Carpet)		X				20					Ea.					x
		Walls (Block / Dry Wall)		X				50+					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Toilet Rooms											Ea.					
		Ceilings (Gypsum)		X				50+					Ea.					x
		Floors (Ceramic Tile)		X				50+					Ea.					x
		Walls (ceramic Tile)		X				50 +					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Millwork (P.lam)		X				30		Appearance is dated but no signs of wear.			Ea.					x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
G Wing		Second Level														
		Corridors							Ea.							
		Ceilings (Act 2 x 4)		X			20		Ea.							x
		Floors (Vct)		X			25		Ea.							x
		Walls (Brick)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Classrooms							Ea.							
		Ceilings (Act 2 x 4)		X			20		Ea.							x
		Floors (Vct)		X			25		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Windows (Aluminum)		X			30	Life expectancy of a sealer is approximately 5 years.	Ea.							x
		Millwork (Plam)		X			20	Appearance is dated but no signs of wear.	Ea.							x
		Auditorium							Ea.							
		Ceilings (Gyp. Bd.)		X			20		Ea.							x
		Floors (wood)			X		10		Ea.			x				
		Walls (Gyp. Bd.)		X			50 +		Ea.							x
		Lightning balcony				X	10	Finishes, access, and ADA.				x				
		Doors (H.M.)		X			30		Ea.							x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Conference Rooms / Offices							Ea.							
		Ceilings (Act 2 x 2)		X			10		Ea.							x
		Floors (Carpet)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Windows (Aluminum )		X			30	Life expectancy of a sealer is approximately 5 years.	Ea.							x
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.							x
		Floors (Ceramic Tile)		X			50+		Ea.							x
		Walls (ceramic Tile)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork (Plam)		X			30	Appearance is dated but no signs of wear.	Ea.							x
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																
G Wing									Ea.							
		Stairs (Terrazzo)		X					2	Ea.						x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
H Wing			Lower Level															
	Mechanical Area/ Tunnels												Ea.					
	Ceilings (Exposed)			X				50+		No leaking from above identified.		Ea.					x	
	Floors (Concrete)			X				50+		Floors show wear and cracking.		Ea.					x	
	Walls (Block / Concrete)			X				50+		Minimal/ to no cracking. No leaks identified.		Ea.					x	
	Doors (H.M.)				X			30		Doors are in poor condition.		Ea.		x				
H Wing			First Level															
	Corridors												Ea.					
	Ceilings (Act 2 x 4)			X				20				Ea.					x	
	Floors (Vct)			X				25				Ea.					x	
	Walls (Brick)			X				50 +				Ea.					x	
	Doors (H.M.)			X				30				Ea.					x	
	Conference Rooms / Offices											Ea.						
	Ceilings (Act 2 x 2)			X				10				Ea.					x	
	Floors (Carpet)			X				20				Ea.					x	
	Walls (Block / Dry Wall)				X			50+		Cracking at various areas at window sill.		Ea.		x				
	Doors (H.M.)			X				30				Ea.					x	
	Windows (Aluminum )			X				30		Life expectancy of a sealer is approximately 5 years.		Ea.					x	
	Millwork (P.lam)			X				20				Ea.					x	
	Toilet Rooms											Ea.						
	Ceilings (Gypsum)			X				50+				Ea.					x	
	Floors (Ceramic Tile)			X				50+				Ea.					x	
	Walls (ceramic Tile)			X				50 +				Ea.					x	
	Doors (H.M.)			X				30				Ea.					x	
	Millwork (P.lam)			X				30		Appearance is dated but no signs of wear.		Ea.					x	
	Janitor Closets											Ea.						
	Ceilings (Exposed)			X								Ea.					x	
	Floors (Concrete)			X				50+				Ea.					x	
	Walls (Block / Dry Wall)			X				50+				Ea.					x	
	Doors (H.M.)			X				30				Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Pantry							Ea.							
		Ceilings (Act 2 x 2)		X			50+		Ea.							x
		Floors (Vinyl sheet/ Tile)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.	Ea.							x
<b>INTERIORS</b>																
J Wing			Lower Level													
		Mechanical Area/ Tunnels								Ea.						
		Ceilings (Exposed)		X			50+	No leaking from above indentified.	Ea.							x
		Floors (Concrete)		X			50+	Floors show wear and cracking.	Ea.							x
		Walls (Block / Concrete)		X			50+	Minimal/ to no cracking. No leaks indentified.	Ea.							x
		Doors (H.M.)				X	30	Doors are in poor condition.	Ea.				x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
J Wing			First Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 4)		X			20			Ea.						x
		Floors (Vct)		X			25			Ea.						x
		Walls (Brick)		X			50 +			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Classrooms								Ea.						
		Ceilings (Act 2 x 2)		X			10			Ea.						x
		Floors (Carpet)		X			20			Ea.						x
		Walls (Block / Dry Wall)		X			50+	Cracking at various areas at window sill.		Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Windows (Aluminum )		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)		X			10			Ea.						x
		Floors (Carpet)		X			20			Ea.						x
		Walls (Block / Dry Wall)			X		50+	Cracking at various areas.		Ea.		x				
		Doors (H.M.)		X			30			Ea.						x
		Windows (Aluminum )		X			30	Life expectancy of a sealer is approximately 5 years.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.						x
		Floors (Ceramic Tile)		X			50+			Ea.						x
		Walls (ceramic Tile)		X			50 +			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.		Ea.						x
		Janitor Closets								Ea.						
		Ceilings (Exposed)		X						Ea.						x
		Floors (Concrete)		X			50+			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.						x	
		Floors (Vct)		X			20		Ea.						x	
		Walls (Block / Dry Wall)		X			50+		Ea.						x	
		Doors (H.M.)		X			30		Ea.						x	

## INTERIORS

K Wing		Lower Level	Condition										Priority 1	Priority 2	Priority 3	Priority 4	Priority 5
			Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit						
		Mechanical Area/ Tunnels								Ea.						x	
		Ceilings (Exposed)	X				50+		No leaking from above indentified.	Ea.						x	
		Floors (Concrete)	X				50+		Floors show wear and cracking.	Ea.						x	
		Walls (Block / Concrete)	X				50+		Minimal/ no cracking. No leaks identified.	Ea.							
		Doors (H.M.)			X		30		Doors are in poor condition.	Ea.		x					
K Wing		First Level	Condition										Priority 1	Priority 2	Priority 3	Priority 4	Priority 5
			Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit						
		Corridors		X			20			Ea.						x	
		Ceilings (Act 2 x 4)	X				20			Ea.						x	
		Floors (Vct)			X		25		Crack appears in flooring at some areas.	Ea.		x					
		Walls (Brick)	X				50 +			Ea.						x	
		Doors (H.M.)	X				30			Ea.						x	
		Classrooms	Condition										Priority 1	Priority 2	Priority 3	Priority 4	Priority 5
			Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit						
		Ceilings (Act 2 x 2)	X				10			Ea.						x	
		Floors (Carpet)		X			20		Worn out carpet in some areas.	Ea.		x					
		Walls (Block / Dry Wall)	X				50+			Ea.						x	
		Doors (H.M.)	X				30			Ea.						x	
		Windows (Aluminum )	X				30		Life expectancy of a sealer is approximately 5 years.	Ea.						x	
		Millwork (P.lam)	X				20			Ea.						x	

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Conference Rooms / Offices							Ea.							
		Ceilings (Act 2 x 2)		X			10		Ea.							x
		Floors (Carpet)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+	Cracking at various areas at window sill.	Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Windows (Aluminum )		X			30	Life expectancy of a sealer is approximately 5 years.	Ea.							x
		Millwork (P.lam)		X			20		Ea.							x
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.							x
		Floors (Ceramic Tile)		X			50+		Ea.							x
		Walls (ceramic Tile)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.	Ea.							x
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Storage							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30	Doors are in poor condition.	Ea.		x					x
<b>INTERIORS</b>																
L Wing			Lower Level													
		Mechanical Area/ Tunnels							Ea.							
		Ceilings (Exposed)		X			50+	No leaking from above indentified.	Ea.							x
		Floors (Concrete)		X			50+	Floors show wear and cracking.	Ea.							x
		Walls (Block / Concrete)		X			50+	Minimal/ no cracking. No leaks indentified.	Ea.							x
		Doors (H.M.)			X		30	Doors are in poor condition.	Ea.		x					

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
L Wing			First Level															
		Corridors										Ea.						
		Ceilings (Act 2 x 4)		X					20			Ea.					x	
		Floors (Vct)		X					25			Ea.					x	
		Walls (Brick)		X					50 +			Ea.					x	
		Doors (H.M.)		X					30			Ea.					x	
		Classrooms										Ea.						
		Ceilings (Act 2 x 2)		X					10			Ea.					x	
		Floors (Carpet)			X				20	Worn out carpet in some areas.		Ea.			x			
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Windows (Aluminum )		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (P.lam)		X					20			Ea.			x			
		Workshops										Ea.						
		Ceilings (Exposed)		X					10			Ea.			x			
		Floors (concrete)			X				20	cracks in some areas		Ea.	x					
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Windows (Aluminum )		X					30			Ea.			x			
		Millwork (P.lam)		X					20			Ea.			x			
		Toilet Rooms										Ea.						
		Ceilings (Gypsum)		X					50+			Ea.			x			
		Floors (Ceramic Tile)		X					50+			Ea.			x			
		Walls (ceramic Tile)		X					50 +			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Millwork (P.lam)		X					30	Appearance is dated but no signs of wear.		Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets							Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)			X		20	Missing ceiling tiles and stained.	Ea.			x				
		Floors (Vct)		X			20		Ea.			x				
		Walls (Block / Dry Wall)		X			50+		Ea.			x				
		Doors (H.M.)		X			30		Ea.			x				
		Exhaust Fan				X		Rust on roofing around and up to exhaust fan	Ea.			x				
		Exterior wall				X		Bricks missing, exposed metal leaking into building	Ea.		x					
		Walking pads				X		Needs replacement of all walkpads in area	Ea.		x					
		Roofing		X				Needs cleaning, minimal / no damage identified (Replaced in 2001 / 2003)	Ea.			x				
		Metal Coping		X				Minimal / no damage identified	Ea.			x				
		Water buildup			X			Build up of water	Ea.		x					
		Roof drain / Overflow drain		X				Clean in and around drains for proper draining	Ea.			x				
		INTERIORS														
M Wing			Lower Level													
		Mechanical Area/ Tunnels														
		Ceilings (Exposed)			X		50+	No leaking from above identified.	Ea.			x				
		Floors (Concrete)			X		50+	Floors show wear and cracking.	Ea.			x				
		Walls (Block / Concrete)			X		50+	Minimal / no cracking. No leaks identified.	Ea.			x				
		Doors (H.M.)				X	30	Doors are in poor condition.	Ea.		x					

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
M Wing			First Level															
		Corridors										Ea.						
		Ceilings (Act 2 x 4)		X					20			Ea.					x	
		Floors (Vct)		X					25			Ea.					x	
		Walls (Brick)		X					50 +			Ea.					x	
		Doors (H.M.)		X					30			Ea.					x	
		Classrooms										Ea.						
		Ceilings (Act 2 x 2)		X					10			Ea.					x	
		Floors (Carpet)			X				20	Worn out carpet in some areas.		Ea.			x			
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Windows (Aluminum )		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (P.lam)		X					20			Ea.			x			
		Workshops										Ea.						
		Ceilings (Exposed)		X					10			Ea.			x			
		Floors (concrete)			X				20	cracks in some areas		Ea.	x					
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Windows (Aluminum )		X					30			Ea.			x			
		Millwork (P.lam)		X					20			Ea.			x			
		Conference Rooms / Offices										Ea.						
		Ceilings (Act 2 x 2)		X					10			Ea.						
		Floors (Carpet)		X					20			Ea.			x			
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
		Windows (Aluminum )		X					30	Life expectancy of a sealer is approximately 5 years.		Ea.			x			
		Millwork (P.lam)		X					20			Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.							x
		Floors (Ceramic Tile)		X			50+		Ea.							x
		Walls (ceramic Tile)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork (Plam)		X			30	Appearance is dated but no signs of wear.		Ea.						x
		Janitor Closets								Ea.						
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Storages							Ea.							
		Ceilings (Act 2 x 2)			X		20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
M Wing		Second Level														
		Mechanical Area							Ea.							
		Ceilings (Exposed)		X			50+	No leaking from above indentified.	Ea.							x
		Floors (Concrete)		X			50+	Floors show wear and cracking.	Ea.							x
		Walls (Block / Concrete)		X			50+	Minimal/ to no cracking. No leaks indentified.	Ea.							x
		Doors (H.M.)			X		30	Doors are in poor condition.	Ea.			x				
		Walking pads			X			Needs replacment of all walkpads in area	Ea.		x					
		Roofing		X				Needs cleaning. Minimal / to no damage identified (Replaced in 2003 / 2012)	Ea.							x
		Metal Coping		X				Minimal / to no damage identified	Ea.							x
		Water buildup			X			Build up of water	Ea.		x					
		Roof drain / Overflow drain		X				Clean in and around drains for proper draining	Ea.							x
VERTICAL AND HORIZONTAL TRANSPORTATION																
M Wing										Ea.						
		Stairs (Terrazzo)					50 +		2	Ea.						

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
N Wing			Lower Level															
		Corridors											Ea.					
		Ceilings (Act 2 x 4)		X				20					Ea.					x
		Floors (Vct)		X				25					Ea.					x
		Walls (Brick)		X				50+					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Cafeteria											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Carpet & VCT)		X				10					Ea.					x
		Walls (Block / Dry Wall)		X				50+					Ea.					x
		Doors (H.M. / Wood)		X				30		Frames have rusting at floor.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Break Area											Ea.					
		Ceilings (Act 2 x 2)		X				20					Ea.					x
		Floors (Carpet)		X				25					Ea.					x
		Walls (Brick)		X				50+					Ea.					x
		Windows (Aluminum)		X				30		Life expectancy of a sealant is approximately 5 years.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Conference Rooms / Offices											Ea.					
		Ceilings (Act 2 x 2)		X				10					Ea.					x
		Floors (Carpet)		X				20					Ea.					x
		Walls (Block / Dry Wall)		X				50+					Ea.					x
		Doors (H.M.)		X				30					Ea.					x
		Windows (Aluminum )		X				30		Life expectancy of a sealer is approximately 5 years.			Ea.					x
		Millwork (P.lam)		X				20					Ea.					x
		Kitchen																
		Ceilings (Act 2 x 2)		X				10										x
		Floors (VCT)		X				10										x
		Walls (Block / Dry Wall)		X				50+										x
		Doors (H.M.)		X				30										x
		Millwork (P.lam)		X				20										x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Kitchen cold storage														
		Ceilings		X			10									x
		Floors (VCT)		X			10									x
		Walls (Block / Dry Wall)		X			50+									x
		Doors		X			30									x
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.						x
		Floors (Ceramic Tile)		X			50+			Ea.						x
		Walls (ceramic Tile)		X			50 +			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.		Ea.						x
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.						x
		Floors (Concrete)		X			50+			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Storage								Ea.						
		Ceilings (Act 2 x 2)			X		20			Ea.				x		
		Floors (Vct)		X			20			Ea.				x		
		Walls (Block / Dry Wall)				X	50+	Creaking in the wall		Ea.		x				
		Doors (H.M.)		X			30			Ea.				x		
		Roofing		X				Replaced in 2003								x
		Metal Coping		X				Minimal / no damage identified		Ea.				x		
		Walking pads						None		Ea.						

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
N Wing			First Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 4)		X			20			Ea.						x
		Floors (Vct)		X			25			Ea.						x
		Walls (Brick)		X			50 +			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Locker rooms								Ea.						
		Ceilings (Exposed)		X			20			Ea.						x
		Floors (VCT)			X		10	Floor tiles were chipped at some locations		Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Doors (H.M. / Wood)		X			30	Frames have rusting at floor.		Ea.						x
		Millwork (P.lam)		X			20			Ea.						x
		Gym								Ea.						
		Ceilings (Exposed)		X			20			Ea.						x
		Floors (Hardwood)		X			25			Ea.						x
		Walls (Block / Dry Wall)		X			50 +			Ea.						x
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)		X			10			Ea.						x
		Floors (Carpet)		X			20			Ea.						x
		Walls (Block / Dry Wall)			X		50+	Damaged at certain locations		Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			
		Millwork (P.lam)		X			20			Ea.			x			
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.			x			
		Floors (Ceramic Tile)		X			50+			Ea.			x			
		Walls (ceramic Tile)		X			50 +			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.		Ea.			x			
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.			x			
		Floors (Concrete)		X			50+			Ea.			x			
		Walls (Block / Dry Wall)		X			50+			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.				x			
		Floors (Vct)		X			20		Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			
N Wing		Second Level														
		Corridors							Ea.							
		Ceilings (Act 2 x 4)		X			20		Ea.				x			
		Floors (Vct)		X			25		Ea.				x			
		Walls (Brick)		X			50 +		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			
		Bleachers Seating Balcony							Ea.							
		Ceilings (Exposed)		X			20		Ea.				x			
		Floors (VCT)		X			10		Ea.				x			
		Walls (Block / Dry Wall)		X			50 +		Ea.				x			
		Doors (H.M. / Wood)		X			30		Ea.				x			
		Classrooms							Ea.							
		Ceilings (Act 2 x 2)		X			10		Ea.				x			
		Floors (Carpet)		X			20		Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			
		Windows (Aluminum )		X			30	Life expectancy of a sealer is approximately 5 years.	Ea.				x			
		Millwork (P.lam)		X			20		Ea.				x			
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.				x			
		Floors (Ceramic Tile)		X			50+		Ea.				x			
		Walls (ceramic Tile)		X			50 +		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			
		Millwork (P.lam)		X			30	Appearance is dated but no signs of wear.	Ea.				x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.						x
		Floors (Concrete)		X			50+			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
		Storages								Ea.						
		Ceilings (Act 2 x 2)			X		20			Ea.						x
		Floors (Vct)		X			20			Ea.						x
		Walls (Block / Dry Wall)		X			50+			Ea.						x
		Doors (H.M.)		X			30			Ea.						x
N Wing		Third Level														
		Mechanical Area								Ea.						
		Ceilings (Exposed)		X			50+	No leaking from above indentified.		Ea.						x
		Floors (Concrete)		X			50+	Floors show wear and cracking.		Ea.						x
		Walls (Block / Concrete)		X			50+	Minimal/ no cracking. No leaks indentified.		Ea.						x
		Doors (H.M.)			X		30			Ea.				x		
VERTICAL AND HORIZONTAL TRANSPORTATION																
N Wing										Ea.						
		Elevator		X			25		1	Ea.						x
		Stairs (Terrazzo)		X			50 +		8	Ea.						x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
P Wing			Lower Level															
		Pool Mechanical Area											Ea.					
		Ceilings (Exposed)		X				50+		No leaking from above identified.		Ea.					x	
		Floors (Concrete)		X				50+		Floors show wear and cracking.		Ea.					x	
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks identified.		Ea.					x	
		Doors (H.M.)		X				30				Ea.					x	
		Corridors										Ea.						
		Ceilings (Act 2 x 4)		X				20				Ea.					x	
		Doors (H.M.)			X			30		Frames showing rust at floor.					x			
		Floors (Vct)		X				25		As VCT is replaced where worn, the color is a fair match..		Ea.					x	
		Walls (Brick)		X				50 +				Ea.					x	
		Conference Rooms / Offices										Ea.						
		Ceilings (Act 2 x42)		X				20		Minor water staining throughout.		Ea.					x	
		Floors (Carpet)			X			10		Carpet is fading in some areas.		Ea.			x			
		Walls (Concrete & Gyp. Bd.)		X				50 +				Ea.			x			
		Doors (H.M.)		X				30				Ea.			x			
		Millwork (P.lam)		X				20		Appearance is dated but no signs of wear.		Ea.			x			
		Toilet Rooms										Ea.						
		Ceilings (Gypsum)		X				50+				Ea.			x			
		Floors (Ceramic Tiles)		X				20				Ea.			x			
		Walls (Ceramic Tile)		X				20				Ea.			x			
		Doors (H.M.)		X				30				Ea.			x			
		Millwork		X				30				Ea.			x			
		Janitor Closets						20				Ea.						
		Ceilings (Exposed)		X								Ea.			x			
		Floors (Concrete)		X				50+				Ea.			x			
		Walls (Block / Dry Wall)		X				50+				Ea.			x			
		Doors (H.M.)		X				30				Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Vct)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
P Wing			First Level													
		Corridors							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Doors (H.M.)		X			30									x
		Floors (VCT and Carpet)		X			25									x
		Walls (Brick)		X			50 +		Ea.							x
		Swimming Pool							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Doors (H.M.)		X			30									x
		Floors (VCT and Carpet)		X			25									x
		Walls (Brick)		X			50 +		Ea.							x
		Windows			X		30	Life expectancy of sealer is approximately 5 years	Ea.			x				
		Swimming Pool Equipment		X												x
		Conference Rooms / Offices							Ea.							
		Ceilings (Act 2 x42)		X			20		Ea.							x
		Floors (Carpet)		X			10		Ea.							x
		Walls (Concrete & Gyp. Bd.)		X			50 +		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork (P.lam)		X			20	Appearance is dated but no signs of wear.	Ea.							x
		Janitor Closets					20		Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area:	899,682 SF
No. of Floors:	3
Year Built:	1961
Year Renovated:	Various -- see A001, A002 and A003
Evaluated:	First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities							
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered or no immediate action required						

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Locker rooms							Ea.							
		Ceilings (Exposed)		X			20		Ea.						x	
		Floors (VCT)			X		10	Floor tiles were chipped at some locations	Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M. / Wood)		X			30	Frames have rusting at floor.	Ea.				x			
		Millwork (P.lam)		X			20		Ea.				x			
		Exercise Rooms							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.				x			
		Floors (Rubber Mat)		X			10		Ea.				x			
		Walls (Storefront)		X			50+		Ea.				x			
		Doors (Glass)		X			50+		Ea.				x			
		Windows		X			30		Ea.				x			
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.				x			
		Floors (Vct)		X			20		Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			
P Wing		Second Level														
		Corridors							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.				x			
		Doors (H.M.)		X			30						x			
		Floors (VCT and Carpet)		X			25						x			
		Walls (Brick)		X			50+		Ea.				x			
		Basketball Court							Ea.							
		Ceilings (Exposed)		X			20		Ea.				x			
		Floors (Hardwood)		X			10		Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M. / Wood)		X			30		Ea.				x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Toilet Rooms							Ea.							
		Ceilings (Gypsum)		X			50+		Ea.							x
		Floors (Ceramic Tiles)		X			20		Ea.							x
		Walls (Ceramic Tile)		X			20		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Millwork		X			30		Ea.							x
		Janitor Closets					20		Ea.							
		Ceilings (Exposed)		X					Ea.							x
		Floors (Concrete)		X			50+		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
		Exercise Rooms						2 Racquet ball courts requires remodelling.	Ea.							
		Ceilings (Act 2 x 4 and Gyp.)		X			20		Ea.							x
		Floors (Rubber Mat)		X			10		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M. / Wood)		X			50 +		Ea.							x
		Millwork		X			20	Appearance is dated but no signs of wear.	Ea.							x
		Storage							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.							x
		Floors (Carpet and VCT)		X			20		Ea.							x
		Walls (Block / Dry Wall)		X			50+		Ea.							x
		Doors (H.M.)		X			30		Ea.							x
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																
P Wing										Ea.						
		Elevator		X			25		2	Ea.						x
		Stairs (Terrazzo)		X			50 +		3	Ea.						x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities							
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered or no immediate action required						

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIORS</b>																		
S Wing			Lower Level															
		Mechanical Room & Tunnels																
		Ceilings (Exposed)		X				50+		No leaking from above identified.		Ea.					x	
		Floors (Concrete)		X				50+		Floors show wear and cracking.		Ea.					x	
		Walls (Block / Concrete)		X				50+		Minimal/ to no cracking. No leaks identified.		Ea.					x	
		Doors (H.M.)			X			30		Doors to exterior ventilation pit have no locksets, panic hardware, and are in poor condition.		Ea.	x					
		Corridors										Ea.						
		Ceilings (Act 2 x 2)		X				20				Ea.					x	
		Floors (Vct)		X				25				Ea.					x	
		Walls (Brick)		X				50 +		All tile or resilient base has been removed.		Ea.					x	
		Conference Rooms / Offices										Ea.						
		Ceilings (Act 2 x 2)			X			20		Minor water staining throughout.		Ea.			x			
		Floors (Carpet)			X			10				Ea.			x			
		Walls (Concrete/ Block wall.)		X				50 +				Ea.					x	
		Doors (H.M. / Wood)		X				30				Ea.					x	
		Millwork (P-lam)		X				20		Appearance is dated but no signs of wear.		Ea.					x	
		Toilet Rooms										Ea.						
		Ceilings (Gypsum)		X				50+				Ea.					x	
		Floors (Ceramic Tiles)		X				20				Ea.					x	
		Walls (Ceramic Tile)		X				20				Ea.					x	
		Doors (H.M.)		X				30				Ea.					x	
		Millwork		X				30				Ea.					x	
		Janitor Closets						20				Ea.						
		Ceilings (Exposed)		X								Ea.					x	
		Floors (Concrete)		X				50+				Ea.					x	
		Walls (Block / Dry Wall)		X				50+				Ea.					x	
		Doors (H.M.)		X				30				Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 2	Potential Critical: Problem Avoidance								
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Classrooms								Ea.						
		Ceilings (Act 2 x 2)		X			20	Minor water staining throughout.		Ea.			x			
		Floors (Carpet)		X			10			Ea.			x			
		Walls (Concrete/ Block wall.)		X			50+	All tile or resilient base has been removed.		Ea.			x			
		Doors (H.M. / Wood)		X			30			Ea.			x			
		Millwork (Plam)		X			20	Appearance is dated but no signs of wear.		Ea.			x			
		Storage								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.			x			
		Floors (Carpet and VCT)		X			20			Ea.			x			
		Walls (Block / Dry Wall)		X			50+			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			
S Wing		First Level														
		Corridors								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.			x			
		Floors (Vct)		X			25			Ea.			x			
		Walls (Block/ Dry wall)		X			50+	All tile or resilient base has been removed.		Ea.			x			
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)		X			20	Minor water staining throughout.		Ea.			x			
		Floors (Carpet)		X			10			Ea.			x			
		Walls (Concrete/ Block wall.)		X			50+			Ea.			x			
		Doors (H.M. / Wood)		X			30			Ea.			x			
		Millwork (Plam)		X			20	Appearance is dated but no signs of wear.		Ea.			x			
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.			x			
		Floors (Ceramic Tiles)		X			20			Ea.			x			
		Walls (Ceramic Tile)		X			20			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			
		Millwork		X			30			Ea.			x			
		Janitor Closets								Ea.						
		Ceilings (Exposed)		X						Ea.			x			
		Floors (Concrete)		X			50+			Ea.			x			
		Walls (Block / Dry Wall)		X			50+			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Classrooms							Ea.							
		Ceilings (Act 2 x 2)		X			20	Minor water staining throughout.	Ea.				x			
		Floors (Carpet)			X		10		Ea.				x			
		Walls (Concrete/ Block wall.)		X			50+	All tile or resilient base has been removed.	Ea.				x			
		Doors (H.M. / Wood)		X			30		Ea.				x			
		Millwork (P.lam)		X			20	Appearance is dated but no signs of wear.	Ea.				x			
		Auditorium							Ea.							
		Ceilings (Act 2 x 2 and Gyp.)		X			20		Ea.				x			
		Floors (Carpet)				X	20	Finishes, access, and ADA.	Ea.	x						
		Walls (Brick)		X			50+		Ea.				x			
		Doors (H.M. / Wood)		X			50+		Ea.				x			
		Art Labs							Ea.							
		Ceilings (Exposed)		X			20		Ea.				x			
		Floors (VCT and Exposed)		X			10		Ea.				x			
		Walls (Block/ Gyp.I)		X			50+		Ea.				x			
		Doors (H.M)		X			50+		Ea.				x			
		Windows		X			30	Life expectancy of sealer is approximately 5 years	Ea.				x			
		Millwork			X		20	Millwork worn out.	Ea.				x			
		Storages							Ea.							
		Ceilings (Act 2 x 2)		X			20		Ea.				x			
		Floors (Carpet and VCT)		X			20		Ea.				x			
		Walls (Block / Dry Wall)		X			50+		Ea.				x			
		Doors (H.M.)		X			30		Ea.				x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
S Wing			Second Level													
		Corridors								Ea.						
		Ceilings (Act 2 x 2)		X			20			Ea.					x	
		Floors (Vct)		X			25			Ea.					x	
		Walls (Block/ Dry wall)		X			50 +	All tile or resilient base has been removed.		Ea.					x	
		Conference Rooms / Offices								Ea.						
		Ceilings (Act 2 x 2)			X		20	Minor water staining throughout.		Ea.			x			
		Floors (Carpet)			X		10			Ea.			x			
		Walls (Concrete/ Block wall.)		X			50 +			Ea.			x			
		Doors (H.M. / Wood)		X			30			Ea.			x			
		Millwork (P.lam)		X			20	Appearance is dated but no signs of wear.		Ea.			x			
		Art labs								Ea.						
		Ceilings (Exposed)		X			20			Ea.			x			
		Floors (VCT and Exposed)		X			10			Ea.			x			
		Walls (Block/ Gyp.J)		X			50+			Ea.			x			
		Doors (H.M)		X			50 +			Ea.			x			
		Windows		X			30	Life expectancy of sealer is approximately 5 years		Ea.			x			
		Millwork			X		20	Millwork worn out.		Ea.			x			
		Toilet Rooms								Ea.						
		Ceilings (Gypsum)		X			50+			Ea.			x			
		Floors (Ceramic Tiles)		X			20			Ea.			x			
		Walls (Ceramic Tile)		X			20			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			
		Millwork		X			30			Ea.			x			
		Janitor Closets					20			Ea.						
		Ceilings (Exposed)		X						Ea.			x			
		Floors (Concrete)		X			50+			Ea.			x			
		Walls (Block / Dry Wall)		X			50+			Ea.			x			
		Doors (H.M.)		X			30			Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Classrooms										Ea.						
		Ceilings (Act 2 x 2)			X			20		Minor water staining throughout.		Ea.			x			
		Floors (Carpet)				X			10			Ea.			x			
		Walls (Concrete/ Block wall.)		X					50 +	All tile or resilient base has been removed.		Ea.			x			
		Doors (H.M. / Wood)		X					30			Ea.			x			
		Millwork (P.Iam)		X					20	Appearance is dated but no signs of wear.		Ea.			x			
		Storage										Ea.						
		Ceilings (Act 2 x 2)		X					20			Ea.			x			
		Floors (Carpet and VCT)		X					20			Ea.			x			
		Walls (Block / Dry Wall)		X					50+			Ea.			x			
		Doors (H.M.)		X					30			Ea.			x			
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
S Wing												Ea.						
		Elevator			X				25			1	Ea.			x		
		Stairs (Terrazzo)			X				50 +			4	Ea.			x		
<b>INTERIORS</b>																		
Z Wing			Lower Level															
		Mechanical Area										Ea.						
		Ceilings (Exposed)			X				50+	No leaking from above identified.		Ea.			x			
		Floors (Concrete)			X				50+	Floors show wear and cracking.		Ea.			x			
		Walls (Block / Concrete)			X				50+	Minimal/ no cracking. No leaks identified.		Ea.			x			
		Doors (H.M.)				X			30	Doors are in poor condition.		Ea.		x				
Z Wing			First Level															
		Mechanical Room										Ea.						
		Ceilings (Act 2 x 2)							20 Years	NA		Ea.						
		Floors (Carpet)							10 Years	NA		Ea.						
		Walls (Block / Dry Wall)			X				50 + Years			Ea.			x			
		Doors (H.M. / Wood)			X				30 Years			Ea.			x			
		Windows (Aluminum)			X				30 Years			Ea.			x			
		Millwork								NA		Ea.						

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concern and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Garages							Ea.							
		Ceilings (Act 2 x 2)					20 Years	NA	Ea.							
		Floors (Carpet)					10 Years	NA	Ea.							
		Walls (Block / Dry Wall)		x			50 + Years		Ea.						x	
		Doors (H.M. / Wood)		x			30 Years		Ea.						x	
		Windows (Aluminum)		x			30 Years		Ea.						x	
		Millwork		x					Ea.						x	
Offices									Ea.							
		Ceilings (Act 2 x 2)			x		20 Years		Ea.					x		
		Floors (Carpet)		x			10 Years		Ea.					x		
		Walls (Block / Dry Wall)		x			50 + Years		Ea.					x		
		Doors (H.M. / Wood)			x		30 Years		Ea.					x		
		Windows (Aluminum)			x		30 Years		Ea.					x		
		Millwork (P.lam)			x		20 Years		Ea.					x		
Toilet Rooms									Ea.							
		Ceilings (Gypsum)		x			50 Years		Ea.					x		
		Floors (Ceramic Tiles)		x			50 + Years		Ea.					x		
		Walls (Block / Dry Wall)		x			50 + Years		Ea.					x		
		Doors (H.M. / Wood)			x		30 Years		Ea.					x		
		Windows						NA	Ea.							
		Millwork (P.lam)			x		20 Years		Ea.					x		
Janitor Closets									Ea.							
		Ceilings (Exposed)			x				Ea.					x		
		Floors (Epoxy / Exposed)		x			15 Years		Ea.					x		
		Walls (Block / Dry Wall)		x			50 + Years		Ea.					x		
		Doors (H.M. / Wood)			x		30 Years	Cosmetic	Ea.					x		
		Windows						NA	Ea.							
		Millwork						NA	Ea.							

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Storages										Ea.						
		Ceilings (Act 2 x 2)						20 Years		NA		Ea.						
		Floors		X								Ea.					X	
		Walls (Block / Dry Wall)		X					50 + Years			Ea.					X	
		Doors (H.M. / Wood)			X				30 Years			Ea.					X	
		Windows								NA		Ea.						
		Millwork								NA		Ea.						
VERTICAL AND HORIZONTAL TRANSPORTATION																		
Z Wing												Ea.						
		Elevator			X				25 Years			Ea.					X	
		Stairs (Terrazzo)			X				50 + Years			Ea.					X	
AIR HANDLING UNITS																		
Lower Level/ Wing	L-	AHU-7	Air Handling Unit - Serves Paint Shop, Bookstore, and Graphics Area	LT01		X		2003	25 Years	8 Years	Trane Climate Changer, 8,000 CFM, 347 MBH Steam Heating, 60 GPM (23 Tons) Chilled Water Cooling, 200V, 3 Ph. Design Data taken from documents provided by the College. (w/VFD and disconnect)	1	Ea.				X	
Lower Level/ Wing	L-	AHU-8	Air Handling Unit - Serves N-Wing Conference Room and Kitchen Office	LT01		X		2003	25 Years	8 Years	Trane Climate Changer, Variable Volume, 18,000 CFM, 710 MBH Steam Heating, 158 GPM (60 Tons) Chilled Water Cooling, 200V, 3 Ph. Design data taken from documents provided by the College (w/VFD and disconnect).	1	Ea.				X	
Lower Level/ Wing	K-	AH-9	Air Handling Unit - Serves JT102 and Main Concourse Lower Level and First Floor	KT01		X		2005	25 Years	10 Years	Trane Climate Changer, Variable Volume, 22,600 CFM, 1225.6 MBH Steam Heating, 161.71 GPM (71 Tons) Chilled Water Cooling, 200V, 3 Ph. Design data taken from documents provided by the College. (w/VFD and disconnect)	1	Ea.				X	
Lower Level/ Wing	K-	RF-9	Return Fan - Serves AHU-9	KT01		X		2005	20 Years	5 Years	Trane Climate Changer, 200V, 3 Ph. (w/ disconnect)	1	Ea.				X	
Lower Level/ Wing	H-	AH-10	Air Handling Unit - Serves J101, Main Concourse Lower Level and First Floor	HT01		X		2005	25 Years	10 Years	Trane Climate Changer, Variable Volume, 21,625 CFM, 1172.7 MBH Steam Heating, 154.77 GPM (68 Tons) Chilled Water, 460V, 3 Ph. Design data taken from documents provided by the College. (w/ disconnect and VFD)	1	Ea.				X	
Lower Level/ Wing	H-	RF-10	Return Fan - Serves AH-10	HT01		X		2005	20 Years	5 Years	Trane Climate Changer, 200V, 3 Ph. (w/ disconnect)	1	Ea.				X	
Lower Level/ Wing	E	AH-11	Air Handling Unit - Serves Main Corridor Northwest Lower Level and First Florr	ET01		X		2005	25 Years	10 Years	Trane Climate Changer, Variable Volume, 23,380 CFM, 1267.8 MBH Steam Heating, 167.24 GPM (73.5 Tons) Chilled Water, 460V, 3 Ph. Design data taken from documents provided by the College. (w/ disconnect and VFD)	1	Ea.				X	
Lower Level/ Wing	E	RF-11	Return Fan - Serves AH-11	ET01		X		2005	20 Years	5 Years	Trane Climate Changer, 200V, 3 Ph. (w/ disconnect)	1	Ea.				X	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ Wing	C	AH-12	Air Handling Unit - Serves Main Corridor Southwest Lower Level and First Floor	CT01		X		2005	25 Years	10 Years	Trane Climate Changer. Variable Volume. 11,230 CFM, 609.0 GPM Steam Heating, 81.52 GPM (35.8 Tons) Chilled Water, 460V, 3 Ph. Design data taken from documents provided by the College. (w/ disconnect and VFD)	1	Ea.			x		
Lower Level/ Wing	C	RF-12	Return Fan - Serves AH-12	CT01		X		2005	20 Years	5 Years	Trane Climate Changer. 200V, 3 Ph. (w/ disconnect)	1	Ea.			x		
Grade Level/ C-Wing	AHU-37	Air Handling Unit - Serves Greenhouse	C130			X		1998	25 Years	3 Years	Trane modular unit. Variable Volume. 10,000 CFM, 981 MBH Steam Heating, 132.5 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD). Relocated in 2014.				x			
Grade Level/ C-Wing	RF-37	Air Handling Unit - Serves Greenhouse	C130		X			Unknown	20 Years		Trane Climate Changer. 460V, 3 Ph. (w/ VFD). Appears newer	1	Ea.			x		
Lower Level/ Wing	J-	AH-17	Air Handling Unit - Serves	JT01		X		2005	25 Years	10 Years	Trane Climate Changer. Variable Volume. 20,650 CFM, 1119.8 MBH Steam Heating, 146.95 GPM (64.6 tons) Chilled Water Cooling, 200V, 3 Ph. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect and VFD).	1	Ea.			x		
Lower Level/ Wing	J-	RF-17	Return Fan - Serves AHU-17	JT01		X		2005	20 Years	5 Years	Trane Climate Changer. 200V, 3 Ph.	1	Ea.			x		
Lower Level/ Wing	B-	HV-18	Air Handling Unit - Serves B-Wing West	BT01		X		1995	20 Years	-5 Years	Trane Constant Volume Climate Changer, 16,410 CFM, Steam heating, 90.1 GPM (38 Tons) Chilled Water Cooling, Insulation torn at ductwork above and hanging. Piping corroded. Design data taken from documents provided by College. (w/ VFD). On at time of survey. Per College, this wing and unit should be changed to VAV system.	1	Ea.		x			
Lower Level/ Wing	B-	RF-18	Return Fan - Serves HV-18	BT01		X	Assume 1995	20 Years	-5 Years	Return Fan exposed. Baldor motor. 5 HP, 230/460 V, 3 Ph. (w/ VFD)	1	Ea.		x				
First Floor/ B-Wing	CRAC-1A	Computer Room Air Conditioning Unit	B127	X			2019	15 Years	14 Years	73.2 MBH3400 CFM, 1 fan, 3/4 HP each, 480V, 3 Ph.35% ethylene glycol	1	Ea.			x			
First Floor/ B-Wing	CRAC-1B	Computer Room Air Conditioning Unit	B127	X			2019	15 Years	14 Years	73.2 MBH3400 CFM, 1 fan, 3/4 HP each, 480V, 3 Ph.35% ethylene glycol	1	Ea.			x			
Lower Level/ Wing	S-	HV-22	Air Handling Unit - Serves S-Wing Fine Arts	ST01		X	Assume 1970	20 Years	-28 Years	Trane, Constant Volume, 50,000 CFM, 370 GPM, no heating. Chilled Water Cooling only. Supply fan motor exposed. Reliance motor, 75 HP, 230/460V, 3 Ph. Piping Corroded at unit. Design data taken from documents provided by College. No date given - assumed original to construction of wing. Paint peeling, sheet metal bent/damage, piping corroded and appears to have leaked at one time. On at time of survey. (w/ disconnect). Per College this wing and unit should be changed to a VAV system.	1	Ea.		x				
Lower Level/ Wing	S-	RF-22	Return Fan - Serves HV-22	ST01		X	Assume 1970	20 Years	-28 Years	Return Fan exposed. Fan belt appears partially broken and unit was very loud. 50 HP, 230/460V, 3 Ph. On at time of survey. (w/ disconnect)	1	Ea.		x				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ Wing	F	AHU-23 Air Handling Unit - Serves F Wing East All Levels	FT01	X			2013	25 Years	18 Years	Trane Climate Changer. Variable Volume, 32,400 CFM, Hot Water Heating, 270 GPM (119 Tons) Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. (w/ VFD).	1	Ea.					x	
Lower Level/ Wing	F	RF-23 Return Fan - Serves AHU-23	FT01	X			2013	20 Years	13 Years	Trane Climate Changer, 460V 3 Ph.	1	Ea.					x	
Lower Level/ Wing	F	AHU-24 Air Handling Unit - Serves F Wing West All Levels	FT01	X			2013	25 Years	18 Years	Trane Climate Changer. Variable Volume, 46,800 CFM, Hot Water Heating, 394 GPM (172 Tons) Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. (w/ VFD).	1	Ea.					x	
Lower Level/ Wing	F	RF-24 Return Fan - Serves AHU-24	FT01	X			2013	20 Years	13 Years	Trane Climate Changer, 460V 3 Ph.	1	Ea.					x	
Lower Level/ Wing	F	ERU-1 Energy Recovery Ventilator - Provides OA and EA to AHU-23 and AHU-24	FT01	X			2013	20 Years	13 Years	RenewAire. 460V, 3 Ph.	1	Ea.					x	
Lower Level/ Wing	P	AHU-25 Air Handling Unit - Serves P-Wing 2nd Floor Raquetball Court	P020	X			2003	25 Years	8 Years	Trane. Climate Changer. Variable Volume, 28,000 CFM, 1050 GPM Steam Heating, 236 GPM (89 Tons) Chilled Water Cooling. Design data taken from documents provided by College. (w/ disconnect and VFD). Pipes showing corrosion entering unit.	1	Ea.					x	
Lower Level/ Wing	P	AHU-26 Air Handling Unit - Serves P-Wing 2nd Floor	P020	X			2003	25 Years	8 Years	Trane. Climate Changer. Variable Volume, 32,000 CFM, 1200 GPM Steam Heating, 272 GPM (103 Tons) Chilled Water Cooling. Design data taken from documents provided by College. (w/ two VFD's).	1	Ea.					x	
Lower Level/ Wing	P	AHU-27 Air Handling Unit - Serves P-Wing Pool	P020			X	2003	25 Years	8 Years	Des Chmaps. Constant Volume, 30,000 CFM, Hot Water Heating, 18-GPM (75 Tons) Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. (w/ disconnect and VFD). Drain pan leaking all over floor. Per College dampers also need to be replaced.	1	Ea.		x				
Lower Level/ Wing	P	AHU-28 Air Handling Unit - Serves P-Wing Lower Level and First Floor	P020	X			2003	25 Years	8 Years	Trane Climate Changer. Variable Volume, 50,000 CFM, 1870 MBH Steam Heating, 428 MBH (165 Tons) Chilled Water Cooling. Design data taken from documents provided by College. (w/ disconnect and VFD).	1	Ea.					x	
Lower Level/ Wing	A-	HV-13 Air Handling Unit - Serves Main Hallway, Southwest Corridor, and North half of S-Wing Connector	AT01			X	1960	20 Years	-40 Years	Trane. Multizone. 6,600 CFM, 415 MBH Steam Heating, 50 GPM Chilled Water Cooling. Cooling. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect). Unit rattling at time of survey.	1	Ea.		x				
Lower Level/ Wing	A-	RF-13 Return Fan - Serves AHU-13	AT01			X	Assume 1960	20 Years	-40 Years	Trane Centrifugal Fan. Marathon Motor 3/2 HP, 208/230-460V, 3 Ph. (w/ disconnect)	1	Ea.		x				
Lower Level/ Wing	A-	HV-14 (aka AHU-5) Air Handling Unit - Serves B-Wing East Offices and Registration Area	AT01			X	1998	20 Years	-2 Years	Trane. Variable Volume. 12,500 CFM, 677.8 MBH Steam Heating, 50 GPM Chilled Water Cooling. Design data taken from documents provided by the College. (W/ disconnect)	1	Ea.		x				
Lower Level/ Wing	A-	RF-14 (aka RF-5) Return Fan - Serves AHU-14	AT01			X	1998	20 Years	-2 Years	Trane Climate Changer. Variable Volume. 8,900 CFM, 326.5 MBH Steam Heating, 69.1 GPM (29.1 Tons) Chilled Water Cooling. 10 HP, 208V, 3 Ph. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect)	1	Ea.		x				
Lower Level/ Wing	A-	AHU-15 Air Handling Unit - Serves DT Offices	AT01		X		2010	25 Years	15 Years	Trane Climate Changer. 8900 CFM, 5 HP, 208V, 3 Ph. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect)	1	Ea.				x		
Lower Level/ Wing	A-	RF-15 Return Fan - Serves AHU-15	AT01		X		2010	20 Years	10 Years	Trane Climate Changer. 8900 CFM, 5 HP, 208V, 3 Ph. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect)	1	Ea.				x		
Lower Level/ Wing	A-	AHU-16 Air Handling Unit - Serves DTV Radio and Studios	AT01		X		2010	25 Years	15 Years	Trane Climate Changer. Variable Volume. 10,800 CFM, 420.5 MBH Steam Heating, 90.1 GPM (38 Tons) Chilled Water Cooling. 15 HP, 208V, 3 Ph. Design data taken from documents provided by the College. On at time of survey. (w/ disconnect)	1	Ea.				x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ A-Wing	RF-16	Return Fan - Serves AHU-16	AT01		X		2010	20 Years	10 Years	Trane Climate Changer. 10,800 CFM, 7.5 HP, 208V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ A-Wing	AHU-5	Air Handling Unit - Serves A-Wing Second Floor Classrooms	A221			X	1998	25 Years	3 Years	Trane modular unit. Variable Volume, 20,000 CFM, 1084.5 MBH Steam Heating, 174.32 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.			x			
Second Floor/ A-Wing	RF-5	Return Fan - Serves AHU-5	A221			X	1998	20 Years	-2 Years	Inaccessible behind AHU-5 and RF-5	1	Ea.		x				
Second Floor/ A-Wing	AHU-6	Air Handling Unit - Serves G-Wing Lecture Theatre	A221	X			2017	25 Years	22 Years	Trane Climate Changer. Variable Volume, 13,000 CFM, 423 MBH hot water heating, 63.5 GPM Chilled Water Cooling, 208V 3 Ph. Design data taken from documents provided by College. (w/ disconnect and VFD)	1	Ea.				x		
Second Floor/ A-Wing	RF-6	Return Fan - Serves AHU-6	A221	X			2017	20 Years	17 Years	Trane Climate Changer. Variable Volume, 13,000 CFM (1) 8.0 HP, 208V, 3 Ph. (w/ disconnect and VFD)	1	Ea.			x			
Lower Level/ wing	HV-31 (aka AHU-8)	Air Handling Unit - Serves A-Wing Library East	AT07			X	1998	20 Years	-2 Years	Trane modular unit. Variable Volume, 39,000 CFM, 2114.8 MBH Steam Heating, 339.15 GPM Chilled Water Cooling, 460V, 3Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.		x				
Lower Level/ wing	RF-31 (aka RF-8)	Return Fan - Serves HV-31	AT07			X	1998	20 Years	-2 Years	Greenheck (w/ VFD and disconnect). Return fan very noisy.	1	Ea.		x				
Lower Level/ wing	HV-32 (aka AHU-7)	Air Handling Unit - Serves A-Wing Library West	AT05			X	1998	20 Years	-2 Years	Trane modular unit. Variable Volume, 39,000 CFM, 2114.8 MBH Steam Heating, 339.15 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.		x				
Lower Level/ wing	RF-32 (aka RF-7)	Return Fan - Serves HV-32	AT05			X	1998	20 Years	-2 Years	Greenheck (w/ VFD and disconnect). Return fan humming at time of survey.	1	Ea.		x				
Lower Level/ A-Wing	LB-1 (aka AHU-47)	Cooling Unit #1 - Serves DTV Area	AT08		X		2002	20 Years	2 Years	Liebert 4,750 CFM, 25 GPM cooling. No heating. Tagged filters and belts replaced 2/2020. Trane Controls. On at time of survey.	1	Ea.			x			
Lower Level/ A-Wing	LB-2 (aka AHU-48)	Cooling Unit #2 - Serves DTV Area	AT08		X		2002	20 Years	2 Years	Liebert 4,750 CFM, 25 GPM cooling. No heating. Tagged filters and belts replaced 2/2020. Trane Controls. On at time of survey.	1	Ea.		x				
Lower Level/ A-Wing	LB-3 (aka AHU-49)	Cooling Unit #3 - Serves DTV Area	AT08		X		2002	20 Years	2 Years	Liebert 4,750 CFM, 25 GPM cooling. No heating. Tagged filters and belts replaced 2/2020. Trane Controls.	1	Ea.		x				
Lower Level/ A-Wing	AHU-46	Cooling Unit - Serves IDF Room	AT03		X		2002	20 Years	2 Years	Trane .800 CFM, 5.1 GPM Chilled Water Cooling. No heating.	1	Ea.		x				
Lower Level/ wing	AH-33	Air Handling Unit - Serves D-Wing West	DT01		X		1998	25 Years	3 Years	Trane modular unit. Variable Volume, 10,000 CFM, 542.2 MBH Steam Heating, 85.75 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.		x				
Lower Level/ wing	RF-33	Return Fan - Serves AH-33	DT01		X		1998	20 Years	-2 Years	Greenheck (w/ VFD and disconnect). Off at time of survey, but AH-33 on at time of survey.	1	Ea.		x				
Lower Level/ wing	AH-34	Air Handling Unit - Serves E-Wing Offices and Classrooms	DT01		X		1998	25 Years	3 Years	Trane modular unit. Variable Volume, 28,000 CFM, 1518.3 MBH Steam Heating, 242 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.		x				
Lower Level/ wing	RF-34	Return Fan - Serves AH-34	DT01			X	1998	20 Years	-2 Years	Greenheck (w/ VFD and disconnect). Very loud at time of survey.	1	Ea.		x				
Lower Level/ wing	AH-35	Air Handling Unit - Serves C-Wing	DT01		X		1998	25 Years	3 Years	Trane modular unit. Variable Volume, 28,000 CFM, 1518.3 MBH Steam Heating, 242 GPM Chilled Water Cooling, 460V, 3 Ph. Design data taken from documents provided by College. On at time of survey. (w/ VFD)	1	Ea.		x				
Lower Level/ wing	RF-35	Return Fan - Serves AH-35	DT01		X		1998	20 Years	-2 Years	Greenheck (w/ VFD and disconnect). On at time of survey.	1	Ea.		x				
Lower Level/ wing	MAU-36 (aka AH-36)	Air Handling Unit - Serves C-Wing and D-Wing West Science Labs	DT01		X		1998	20 Years	-2 Years	Trane. Variable Volume Make Up Air. 40,000 CFM, 4028 MBH Steam Heating, 525.75 GPM Chilled Water Cooling. Design data taken from documents provided by College. On at time of survey. (w/ VFD). Piping entering front side of unit almost inaccessible. Ductwork would need to be reconfigured when replaced.	1	Ea.		x				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Second Floor/ D-wing	AH-20	Air Handling Unit - Serves D-Wing Administration	D201		X		1998	20 Years	-2 Years	Trane modular unit. Constant Volume, 14,500 CFM, 786.3 MBH Steam Heating, 125.47 GPM Chilled Water Cooling, Cooling. Design data taken from documents provided by College. On at time of survey.	1	Ea.			x			
Second Floor/ D-wing	RF-20	Return Fan - Serves AHU-20	D201		X		1998	20 Years	-2 Years	Greenheck. Noisy at time of survey.	1	Ea.			x			
Lower Level/ Wing	L-AHU-45	Air Handling Unit - Serves Kitchen	LT01		X		2003	25 Years	8 Years	Trane Climate Changer. Variable Volume, 28,450 CFM, 2453 MBH Steam Heating, 5.1 GPM Chilled Water Cooling, 200V, 3 Ph, Design data taken from documents provided by College. On at time of survey (w/ VFD and disconnect).	1	Ea.			x			
Lower Level/ Wing	H-AH-50	Air Handling Unit - Serves UPS Room East Tunnel			X					Trane, Fan Coil Unit, 1,600 CFM, 9 GPM, no heating, Chilled Water Cooling only, 208V., 3 Ph, Design data taken from documents provided by College. On at time of survey and squeaking.	1	Ea.			x			
Second Floor/ G-Wing	AHU-21	Air Handling Unit - Serves G-wing First and Second Floors		X			2017	25 Years	22 Years	Trane Climate Changer. Variable Volume, 10,000 CFM, 325.4 MBH, 24 GPM Hot Water Heating, 308 MBH, 48.7 GPM Chilled Water Cooling, (1) 10 HP, 208V, 3 Ph, Design data taken from documents provided by College. On at time of survey (w/ VFD and disconnect).	1	Ea.			x			
Second Floor/ G-Wing	RF-21	Return Fan - Serves RF-21	G229	X			2017	20 Years	17 Years	Trane Climate Changer, Variable Volume, 10,000 CFM (2) 2.5 HP, 208V, 3 Ph, (w/ disconnect and VFD)	1	Ea.			x			
Upper Level/ Z-Wing	AHU-Z	Air Handling Unit	Z111			X	Unknown	25 Years	9 Years	Appears to be abandoned, pressure gauges read 0, but oil gauges reading higher. Open.	1	Ea.	x	x				
Grade Level/ M-Wing	HV-29	Air Handling Unit - Serves M-Wing West	M105 (M106)			X				Trane, Variable Volume, 12,400 CFM, No heating, 100 GPM Chilled Water, 10 HP, 460V, 3 Ph, (w/ disconnect)	1	Ea.						
Grade Level/ M-Wing	RF-29	Return Fan - Serves HV-29	M105 (M106)			X	1991	20 Years	9 Years	Inline, (w/ disconnect)	1	Ea.		x				
Second Floor/ M-Wing	MAU-38	Make Up Air Unit - Serves M-Wing North Auto Lab	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Makeup Air Heat Recovery, 12,100 CFM, 1024 MBH Steam Heating, 140 GPM Chilled Water Cooling. Design data taken from documents provided by college, (w/ VFD and disconnect). Steam pipes squealing at time of survey.	1	Ea.			x			
Second Floor/ M-Wing	AHU-39	Air Handling Unit - Serves L-Wing Process Controls	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Constant Volume Reheat, 7,050 CFM, 252 MBH Steam Heating, 44.5 GPM Chilled Water Cooling, Design data taken from documents provided by college, (w/ 2 VFD's and disconnect)	1	Ea.			x			
Second Floor/ M-Wing	AHU-40	Air Handling Unit - Serves M-Wing South Auto Lab	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Makeup Air Heat Recovery, 14,100 CFM, 1193 MBH Steam Heating, 157 GPM Chilled Water Cooling. Design data taken from documents provided by college, (w/ 2 VFD's and disconnect)	1	Ea.			x			
Second Floor/ M-Wing	AHU-41	Air Handling Unit - Serves L-Wing	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Variable Volume, 13,500 CFM, 483 MBH Steam Heating, 106 GPM Chilled Water Cooling, Design data taken from documents provided by college, (w/ 2 VFD's and disconnects)	1	Ea.			x			
Second Floor/ M-Wing	MAU-42	Make Up Air Unit - Serves L-Wing Welding	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Makeup Air with VFD, 16,500 CFM, 1074 MBH Steam Heating, 189 GPM Chilled Water Cooling, Design data taken from documents provided by college, (w/ VFD and disconnect)	1	Ea.			x			
Second Floor/ M-Wing	AHU-43	Air Handling Unit - Serves M-Wing Construction Lab	M201		X		2003	25 Years	8 Years	Trane Climate Changer, Variable Volume, 11,000 CFM, 399 MBH Steam Heating, 76.5 GPM Chilled Water Cooling, Design data taken from documents provided by college, (w/ 2 VFD's and disconnects)	1	Ea.			x			
Second Floor/ M-Wing	AHU-44	Air Handling Unit - Serves M-Wing Office, RAH/HVAC Lab, Hall/Classroom	M201		X		2003	25 Years	8 Years	Trane, Variable Volume, 14,000 CFM, 501 MBH Steam Heating, 110 GPM Chilled Water Cooling, Design data taken from documents provided by college, (w/ 2 VFD's and disconnects)	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Roof/ Wing	AHU-A	Air handling unit - Serves Automotive Lab M-110	M-Wing roof		X		Unknown	25 Years		Per college, unit revamped to operate as exhaust only. Piping disconnected.	1	Ea.			x			
Roof/ Wing	AHU-B	Air handling unit - Serves Automotive Lab M-115	M-Wing roof		X		Unknown	25 Years		Per college, unit revamped to operate as exhaust only. Piping disconnected.	1	Ea.			x			
Third Floor/ N-Wing	AHU-1	Air Handling Unit - Serves N-Wing East Gym	N300		X		2003	25 Years	8 Years	Trane Climate Changer. Constant Volume, 24,000 CFM, 1563 MBH Steam Heating, 202 GPM Chilled Water Cooling. Design data taken from documents provided by college. (w/ disconnect)	1	Ea.			x			
Third Floor/ N-Wing	AHU-2	Air Handling Unit - Serves N-Wing West Gym	N300		X		2003	25 Years	8 Years	Trane Climate Changer. Constant Volume, 24,000 CFM, 1563 MBH Steam Heating, 202 GPM Chilled Water Cooling. Design data taken from documents provided by college. (w/ disconnect)	1	Ea.			x			
Third Floor/ N-Wing	AHU-3	Air Handling Unit - Serves N-Wing Cafeteria, Locker Rooms, Dining Area, First Floor Coach's Offices	N300		X		2003	25 Years	8 Years	Trane Climate Changer. Variable Volume, 26,300 CFM, 1020 MBH Steam Heating, 226 GPM Chilled Water Cooling. Design data taken from documents provided by college. (w/ 2 VFD's and disconnects)	1	Ea.			x			
Third Floor/ N-Wing	AHU-4	Air Handling Unit - Serves Second Floor Classrooms	N300		X		2003	25 Years	8 Years	Trane Climate Changer. Variable Volume, 7,140 CFM, 312 MBH Steam Heating, 59 GPM Chilled Water Cooling. Design data taken from documents provided by college. (w/ disconnect)	1	Ea.			x			
Third Floor/ N-Wing	HV-30	Air Handline Unit - Servs N-Wing Campus Police Work Force Development	N300			X	1990	20	-10 Years	Trane, Inline, Dual Duct Variable Volume, 2,600 CFM, Steam Heating, 14 GPM Chilled water Cooling. Design data taken from documents provided by college. (w/ disconnect).	1	Ea.		x				
Third Floor/ N-Wing	RF-30	Return Fan - Serves HV-30	N300			X	1990	20	-10 Years	Inline. (w/ disconnect).	1	Ea.		x				
<b>EXHAUST EQUIPMENT</b>																		
Roof/ Wing	EF-A	Exhaust fan - Serves Toilet rooms	L-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-B	Exhaust fan - Serves workshop	L-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-C	Exhaust fan - Serves Toilet rooms	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-D	Exhaust fan - Serves welding lab	M-wing roof		X		2003	20 Years	3 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-E	Exhaust fan - Serves welding lab	M-wing roof		X		2003	20 Years	3 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-F	Exhaust fan - Serves welding lab	M-wing roof		X		2003	20 Years	3 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-G	Exhaust fan - Serves welding lab	M-wing roof	X			2018	20 Years	18 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-H	Exhaust fan - Serves welding lab	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-I	Exhaust fan - Serves welding lab	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-J	Exhaust fan	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-K	Exhaust fan	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-L	Exhaust fan	M-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	EF-M	Exhaust fan - Serves Garage	M-wing roof	X			2012	20 Years	12 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-N	Exhaust fan - Serves Garage	M-wing roof	X			2017	20 Years	17 Years	Greenheck, centrifugal upblast	1	Ea.			x			
Roof/ Wing	EF-O	Exhaust fan	M-wing roof		X		Unknown	20 Years		Swartwout, upblast	1	Ea.			x			
Roof/ Wing	EF-P	Exhaust fan	M-wing roof		X		Unknown	20 Years		Swartwout, upblast	1	Ea.			x			
Roof/ Wing	EF-Q	Exhaust fan	P-wing roof		X		Unknown	20 Years		Upblast	1	Ea.			x			
Roof/ Wing	EF-R	Exhaust fan - Serves Toilet rooms	E-eing roof		X		Unknown	20 Years		downblast	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Roof/ Wing	D- EF-S	Exhaust fan	D-wing roof		X		1997	20 Years	-3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	D- EF-T	Exhaust fan	D-wing roof		X		2009	20 Years	9 Years	Greenheck, downblast	1	Ea.				x		
Roof/ Wing	C- EF-U	Exhaust fan	C-wing roof		X		1998	20 Years	-2 Years	Greenheck, upblast	1	Ea.			x			
Roof/ Wing	C- EF-V	Exhaust fan	C-wing roof	X			2012	20 Years	12 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	C- EF-W	Exhaust fan	C-wing roof	X			2012	20 Years	12 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	C- EF-X	Exhaust fan	C-wing roof		X		1998	20 Years	-2 Years	Greenheck, upblast	1	Ea.			x			
Roof/ Wing	C- EF-Y	Exhaust fan	C-wing roof		X		1998	20 Years	-2 Years	Greenheck, upblast	1	Ea.			x			
Roof/ Wing	C- EF-Z	Exhaust fan - Serves Toilet rooms	C-wing roof		X		Unknown	20 Years		Downblast	1	Ea.			x			
Roof/ Wing	B- EF-AA	Exhaust fan - Serves Toilet rooms	B-wing roof	X			2012	20 Years	12 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AB	Exhaust fan - Serves Toilet rooms	A-wing roof		X		1998	20 Years	-2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AC	Exhaust fan - Serves Storage	A-wing roof		X		1997	20 Years	-3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AD	Exhaust fan	A-wing roof		X		Unknown	20 Years		Swartwout, downblast	1	Ea.			x			
Roof/ Wing	G- EF-AE	Exhaust fan	G-wing roof		X		Unknown	20 Years		Downblast	1	Ea.			x			
Roof/ Wing	G- EF-AF	Exhaust fan	G-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	G- EF-AG	Exhaust fan	G-wing roof		X		Unknown	20 Years		Downblast	1	Ea.			x			
Roof/ Wing	B- EF-AH	Exhaust fan	B-wing roof		X		2002	20 Years	2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	B- EF-AI	Exhaust fan	B-wing roof		X		2002	20 Years	2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AJ	Exhaust fan	A-wing roof		X		1998	20 Years	-2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AK	Exhaust fan	A-wing roof		X		1998	20 Years	-2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	A- EF-AL	Exhaust fan	A-wing roof		X		1998	20 Years	-2 Years	Greenheck, downblast	1	Ea.			x			
Roof/ Wing	K- EF-AM	Exhaust fan - Serves Toilet rooms	K-wing roof		X		unknown	20 Years		Swartwout, Downblast	1	Ea.			x			
Roof/ Wing	J- EF-AN	Exhaust fan - Serves Toilet rooms	J-wing roof		X		2005	20 Years	5 Years	Greenheck, downblast, designed as 1/4 hp. 1100 cfm, 115V, 1ph, 60hz	1	Ea.			x			
Roof/ Wing	H- EF-AO	Exhaust fan - Serves Toilet rooms	H-wing roof		X		2005	20 Years	5 Years	Greenheck, downblast, designed as 1/4 hp. 1000 cfm, 115V, 1ph, 60hz	1	Ea.			x			
Roof/ Wing	P- EF-AP	Exhaust fan - Serves Womens toilet rooms, and locker room	P-wing roof		X		2003	20 Years	3 Years	Greenheck, upblast	1	Ea.			x			
Roof/ Wing	P- EF-AQ	Exhaust fan - Serves Mens toilet rooms, and locker room	P-wing roof		X		2003	20 Years	3 Years	Greenheck, upblast	1	Ea.			x			
Roof/ Wing	P- EF-AR	Exhaust fan	P-wing roof		X		Unknown	20 Years		upblast	1	Ea.			x			
Roof/ Wing	P- EF-AS	Exhaust fan	P-wing roof		X		2003	20 Years	3 Years	Greenheck, upblast	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Roof/ Wing	F- EF-AT	Exhaust fan - Serves JC and work room	F-wing roof	X			2013	20 Years	13 Years	Cook, downblast, 1/3 hp, 1125 cfm. 115V, 1ph, 60hz	1	Ea.					x	
Roof/ Wing	F- EF-AU	Exhaust fan - Serves Toilet rooms	F-wing roof	X			2013	20 Years	13 Years	Cook, downblast, 1/4 hp, 775 cfm. 115V, 1ph, 60hz	1	Ea.					x	
Roof/ Wing	F- EF-AV	Exhaust fan - Smoke evacuation fan	F-wing roof	X			2013	20 Years	13 Years	Greenheck, upblast: 480V, 3ph	1	Ea.					x	
Roof/ Wing	F- EF-AW	Exhaust fan - Smoke evacuation fan	F-wing roof	X			2013	20 Years	13 Years	Greenheck, upblast: 480V, 3ph	1	Ea.					x	
Roof/ Wing	S- EF-AX	Exhaust fan	S-wing roof		X		2003	20 Years	3 Years	Greenheck, downblast	1	Ea.					x	
Roof/ Wing	S- EF-AY	Exhaust fan	S-wing roof		X		unkown	20 Years		Jenn-air, upblast	1	Ea.					x	
Roof/ Wing	S- EF-AZ	Exhaust fan	S-wing roof		X		unkown	20 Years		Jenn-air, upblast	1	Ea.					x	
Roof/ Wing	S- EF-BA	Exhaust fan	S-wing roof		X		unkown	20 Years		Jenn-air, upblast	1	Ea.					x	
Roof/ Wing	S- EF-BB	Exhaust fan	S-wing roof		X		unkown	20 Years			1	Ea.					x	
Roof/ Wing	S- EF-BC	Exhaust fan	S-wing roof		X		unkown	20 Years			1	Ea.					x	
Roof/ Wing	S- EF-BD	Exhaust fan	S-wing roof		X		unkown	20 Years			1	Ea.					x	
Roof/ Wing	S- EF-BE	Exhaust fan	S-wing roof		X		unkown	20 Years			1	Ea.					x	
Roof/ Wing	S- EF-BF	Exhaust fan	S-wing roof		X		unkown	20 Years			1	Ea.					x	
Lower Level/ wing	D- EF-DD	Exhaust fan - Serves Substation room resides in DT02			X		1997	20 Years	-3 Years	Greenheck. From Serial Number assume 1997, Analog stat.	1	Ea.					x	
Second Floor/ D-Wing	EF-1D	Exhaust fan	D202			X	Assume 1998	20 Years	-2 Years	Greenheck. Base mounted.	1	Ea.					x	
Second Floor/ D-Wing	EF-2D	Exhaust fan	D202			X	Assume 1998	20 Years	-2 Years	Greenheck. Base mounted.	1	Ea.					x	
Second Floor/ M-Wing	EF-3	Exhaust fan	M201		X		unknown	20 Years			1	Ea.						
Second Floor/ P-Wing	EF-4	Exhaust fan	P225		X		Assume 2003	20 Years	3 Years	Greenheck inline.	1	Ea.					x	
Second Floor/ P-Wing	EF-5	Exhaust fan	P225		X		Assume 2003	20 Years	3 Years	Greenheck inline.	1	Ea.					x	
Second Floor/ P-Wing	EF-10	Exhaust fan	P225		X		Assume 2003	20 Years	3 Years	Greenheck inline.	1	Ea.					x	
Second Floor/ P-Wing	EF-18	Exhaust fan	P225		X		Assume 2003	20 Years	3 Years	Greenheck inline.	1	Ea.					x	
Third Floor/ N-Wing	EF-6	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Greenheck. Tagged Hoodz kitchen Exhaust Cleaning 1/3/13"	1	Ea.					x	
Third Floor/ N-Wing	EF-7	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Greenheck.	1	Ea.					x	
Third Floor/ N-Wing	EF-8	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Greenheck.	1	Ea.					x	
Third Floor/ N-Wing	EF-9	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Greenheck.	1	Ea.					x	
Third Floor/ N-Wing	EF-12	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Greenheck.	1	Ea.					x	
Third Floor/ N-Wing	EF-13	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Inline.	1	Ea.					x	
Third Floor/ N-Wing	EF-15	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Inline.	1	Ea.					x	
Third Floor/ N-Wing	EF-16	Exhaust fan	N300		X		Assume 2003	20 Years	3 Years	Inline.	1	Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Roof/wing Z-	EF-Z1	Exhaust fan	Boiler plant Roof		X		unkown	20 Years			1	Ea.				x		
Roof/wing Z-	EF-Z2	Exhaust fan	Boiler plant Roof		X		unkown	20 Years			1	Ea.			x			
Roof/wing Z-	EF-Z3	Exhaust fan	Boiler plant Roof		X		unkown	20 Years			1	Ea.			x			
Roof/wing Z-	EF-Z4	Exhaust fan	Boiler plant Roof		X		unkown	20 Years			1	Ea.			x			
Roof/wing Z-	EF-Z5	Exhaust fan	Boiler plant Roof		X		unkown	20 Years			1	Ea.			x			
Meter building	EF-BL	Sidewall Exhaust fan	Meter building		X		unkown	20 Years			1	Ea.			x			
<b>CHILLED WATER EQUIPMENT</b>																		
Z-Wing		Ice Storage Tank	Exterior to Z-Wing	X			2011	30 Years	21 Years	27 chests.	27	Ea.				x		
Z-Wing		Ice Storage Tank	Exterior to Z-Wing		X		1993	30 Years	3 Years	45 chests. Per College, one leaked so entire bank of 3 valved off and 9 more added with south group in 2003 (one tank burst)	54	Ea.			x			
Z-Wing	CT-1	Cooling Tower (East and West)	Exterior to Z-Wing		X		1993	20 Years	-7 Years	Centrifugal, Counterflow blow-through w/ single side air entry. 800 Ton, 1260 GPM (2) 30 HP fans, 480V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Z-Wing	CT-2	Cooling Tower (East and West)	Exterior to Z-Wing		X		1993	20 Years	-7 Years	Centrifugal, Counterflow blow-through w/ single side air entry. 800 Ton, 1260 GPM (2) 50 HP fans, 480V, 3 Ph. Design data taken from documents provided by the College. Per College, new filter and sealed seams 2019	1	Ea.			x			
Z-Wing	CT-3	Cooling Tower (East and West)	Exterior to Z-Wing		X		1993	20 Years	-7 Years	Centrifugal, Counterflow blow-through w/ single side air entry. 800 Ton, 1260 GPM (2) 50 HP fans, 480V, 3 Ph. Design data taken from documents provided by the College. Per College, sealed seams 2019.	1	Ea.			x			
Z-Wing	CT-4	Cooling Tower (North and South)	Exterior to Z-Wing	X			2011	20 Years	11 Years	Forced Draft, Centrifugal fan, Counterflow Cooling, Vertical Air Discharge. 800 Ton, 2400 GPM, (2) 50HP fans, 480V, 3 Ph. (w/ VFD). Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Z-Wing	CH-1Z (aka CH-2)	Chiller (Ice/Chilled Water)	Z101		X		1993 Rebuilt 2011	23 Years	5 Years	Trane Centrifugal Chiller, .465 Tons (Ice Mode), 750 Tons (Chilled Water Mode), 1320 GPM, 480V, 3 Ph. Tagged 2000 lbs R123. Design data taken from documents provided by College.	1	Ea.			x			
First Floor/ Z-Wing	CH-2Z (aka CH-3)	Chiller (Ice/Chilled Water)	Z101		X		1993 Rebuilt 2011	23 Years	5 Years	Trane Centrifugal Chiller, .465 Tons (Ice Mode), 750 Tons (Chilled Water Mode), 1320 GPM, 480V, 3 Ph. Tagged 2000 lbs R123. Design data taken from documents provided by College.	1	Ea.			x			
First Floor/ Z-Wing	CH-3Z	Chiller (Ice/Chilled Water)	Z101		X		2012	23 years	15 Years	Trane Centrifugal Chiller, .550 Tons (Ice Mode), 750 Tons (Chilled Water Mode), 450-2637 GPM (Design 1500 GPM), 480V, 3 Ph. Design data taken from documents provided by College.	1	Ea.			x			
First Floor/ Z-Wing	CH-4Z	Chiller (Ice/Chilled Water)	Z101		X		2012	23 Years	15 Years	Trane Centrifugal Chiller, .550 Tons (Ice Mode), 750 Tons (Chilled Water Mode), 450-2637 GPM (Design 1500 GPM), 480V, 3 Ph. Design data taken from documents provided by College.	1	Ea.			x			
First Floor/ Z-Wing	CWP-1Z	Condenser Water (Tower) Pump	Z101		X		2011	20 Years	11 Years	2250 GPM, 80 ft. Head. 60 HP, 208-230/480V, 3 Ph. W/ VFD.	1	Ea.			x			
First Floor/ Z-Wing	CWP-2Z	Condenser Water (Tower) Pump	Z101		X		2011	20 Years	11 Years	2250 GPM, 80 ft. Head. 60 HP, 208-230/480V, 3 Ph. W/ VFD.	1	Ea.			x			
First Floor/ Z-Wing	CWP-3Z	Condenser Water (Tower) Pump	Z101		X		2011	20 Years	11 Years	2250 GPM, 80 ft. Head. 60 HP, 208-230/480V, 3 Ph. W/ VFD.	1	Ea.			x			
First Floor/ Z-Wing	CWP-4Z	Condenser Water (Tower) Pump	Z101		X		2011	20 Years	11 Years	2250 GPM, 80 ft. Head. 60 HP, 208-230/480V, 3 Ph. W/ VFD.	1	Ea.			x			
First Floor/ Z-Wing	CHWP-1Z	Chilled Water Pump	Z102		X		2011	20 Years	11 Years	2000 GPM, 135 ft. Head. 100 HP, 230/460V, 3 Ph. W/ VFD.	1	Ea.			x			
First Floor/ Z-Wing	CHWP-2Z	Chilled Water Pump	Z102		X		2011	20 Years	11 Years	2000 GPM, 135 ft. Head. 100 HP, 230/460V, 3 Ph. W/ VFD.	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category	
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5		
First Floor/ Z-Wing	CHWP-3Z	Chilled Water Pump	Z102		X		2011	20 Years	11 Years	2000 GPM, 135 ft. Head, 100 HP, 230/460V, 3 Ph. W/ VFD.	1	Ea.					x		
First Floor/ Z-Wing	IWP-1Z	Ice Storage Pump	Z101		X		2011	20 Years	11 Years	2000 GPM, 65 ft. Head, 50 HP, 208-230/460V, 3 Ph. W/ VFD	1	Ea.					x		
First Floor/ Z-Wing	IWP-2Z	Ice Storage Pump	Z101		X		2011	20 Years	11 Years	2000 GPM, 65 ft. Head, 50 HP, 208-230/460V, 3 Ph. W/ VFD	1	Ea.					x		
First Floor/ Z-Wing	IWP-3Z	Ice Storage Pump	Z101		X		2011	20 Years	11 Years	2000 GPM, 65 ft. Head, 50 HP, 208-230/460V, 3 Ph. W/ VFD	1	Ea.					x		
First Floor/ Z-Wing	WT-1Z	Water Treatment	Z101		X		Unknown						1	Ea.					
First Floor/ Z-Wing	FP-1Z	Filter Pump	Z101		X		2011	20 Years	11 Years	Bell & Gossett. 550 GPM, 151 ft. Head, 40 HP, 230/460V, 3 Ph. W/ VFD	1	Ea.					x		
First Floor/ Z-Wing	AS-1Z	Air Separator	Z101			X	1993	30 Years	3 Years	Relocated 2011.	1	Ea.					x		
First Floor/ Z-Wing	FS-1Z	Filter/Strainer	Z101		X		2011	30 Years	21 Years				1	Ea.				x	
First Floor/ Z-Wing	ET-1Z	Expansion Tank	Z102			X	1993	30 Years	21 Years	Bell & Gossett B-800			1	Ea.				x	
First Floor/ Z-Wing	GF-1Z	Glycol Feed Unit	Z102		X		2011	30 Years	21 Years	1.8 GPM, 1/3 HP, 10V			1	Ea.				x	
First Floor/ Z-Wing	AS-2Z	Air Separator	Z102		X		2011	30 Years	21 Years				1	Ea.				x	
First Floor/ B-Wing	CH-1	Air Cooled Chiller	Exterior to B-Wing		X		Assume 2012	20 Years	12 Years	Unable to access space. No documents found.	1	Ea.					x		
First Floor/ B-Wing	FC-B (aka FC-1)	Package Drycooler and pumps - serves CRAC units #1 and #2	Exterior to B-Wing	X			2019	20 Years	19 Years	149.3 MBH, 6 fans, 29500 CFM, 1.7 HP each, 2 pumps 1.7 HP each, 460V, 3 Ph.	1	Ea.					x		
Lower Level/ B-Wing	GF-B	Glycol Feeder	BT01	X			2019	30 Years	29 Years	Axion Industries. Feeds process cooling supply.	1	Ea.					x		
Lower Level/ B-Wing	AS-1B	Air Separator	BT01	X			2019	30 Years	29 Years	Spirotherm. 110 GPM	1	Ea.					x		
Lower Level/ B-Wing	ET-1B	Expansion Tank - serves FC-1	BT01	X			2019	30 Years	29 Years	Amtrol. 21.7 gallons.	1	Ea.					x		
Lower Level/ B-Wing	CP-1B 1	Process Cooling Circulating Pump - Serves FC-1	BT01	X			2019	20 Years	19 Years	40 GPM, 60 ft. Head, 3 HP, 480V, 3 Ph. (w/ disconnect). Design data taken from document provided by the College.	1	Ea.					x		
Lower Level/ B-Wing	CP-2B 1	Process Cooling Circulating Pump - Serves FC-1	BT01	X			2019	20 Years	19 Years	40 GPM, 60 ft. Head, 3 HP, 480V, 3 Ph. (w/ disconnect). Design data taken from document provided by the College.	1	Ea.					x		
Lower Level/ A-Wing	GF-1A	Glycol Feeder	AT01	X				30 Years					1	Ea.				x	
Lower Level/ A-Wing	ET-1A	Expansion Tank	AT01		X		2011	30 Years	21 Years	Bell and Gossett. 21.7 gallon.	1	Ea.					x		
Lower Level/ A-Wing	CP-1A	Chilled Water Return Pump	AT01		X		Assume 2011	20 Years	11 Years	5 HP, 208/230-460V, 3 Ph. (w/ disconnect). Per model number believed to be 2011.	1	Ea.					x		
Lower Level/ A-Wing	CP-2A	Chilled Water Return Pump	AT01		X		Assume 2011	20 Years	11 Years	5 HP, 208/230-460V, 3 Ph. (w/ disconnect). Per model number believed to be 2011.	1	Ea.					x		
Lower Level/ A-Wing	SRS-1	Air Separator	AT01		X		Assume 2011	30 Years	21 Years		1	Ea.					x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>HEATING EQUIPMENT</b>																		
Upper Level/ Wing	Z-B-Z	Steam Boiler	Z1111			X	1987	24	0	Out of Service tag 2001, 4388#/hr, components open on boiler. Unknown if still used/needed.	1	Ea.		x				
Lower Level/ Wing	Z-B-2	Steam Boiler	ZT01		X		1996	24 Years	0 Years	Johnston Boiler Company, 9,625#/hr, 250 HP, Natural gas, 460V, 3 Ph, 10,490 MBH max, 1,046 MBH min. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-B-3	Steam Boiler	ZT01		X		1996	24 Years	0 Years	Johnston Boiler Company, 500 HP, 17,250#/hr, Natural gas, 460V, 3 Ph, 20,920 MBH max, 2,092 MBH min. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-B-4	Steam Boiler	ZT01		X		1996	24 Years	0 Years	Johnston Boiler Company, 500 HP, 17,250#/hr, Natural gas, 460V, 3 Ph, 20,920 MBH max, 2,092 MBH min. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	DA-BFP	Dearator and 3 Boiler Feed pumps (skid)	ZT01		X		1996	15 Years	-9 Years	Insulation peeling on system, (w/ control panel)	1	Ea.			x			
		- Dearator Tank			X		2008	30 Years	18 Years	130 c.f. (960 gal.) storage tank.	1	Ea.				x		
		- Pumps (P-1, P-2, P-3)			X		2008	15 Years	3 Years	Vertical Inline. In accessible to acquire information on pumps.	3	Ea.			x			
		- Dome			X		1996	30 Years	4 Years	47,732#/hr Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-ST	Surge Tank	ZT01		X		1996	30 Years	6 Years	1290 Gal. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-CTP-1	Condensate Transfer Base Mounted Pump	ZT01		X			20 Years		5 HP, 230/460V, 3 Ph.	1	Ea.			x			
Lower Level/ Wing	Z-CTP-2	Condensate Transfer Base Mounted Pump	ZT01		X			20 Years		5 HP, 230/460V, 3 Ph.	1	Ea.			x			
Lower Level/ Wing	Z-UH-1	Steam Unit Heater - Serves Boiler Area	ZT01		X		Assume 1996	20 Years	-4 Years	Up high. Inaccessible. Trane, 208#/hr. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-UH-2	Steam Unit Heater - Serves Boiler Area	ZT01		X		Assume 1996	20 Years	-4 Years	Up high. Inaccessible. Trane, 208#/hr. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-CRU-2	Condensate return tank and 3 pumps (system)	ZT01		X		Assume 1996	20 Years	-4 Years	Shipco, 30 GPM, 1/2 Hp, 460V, 3 Ph.Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	Z-ET-Z	Expansion Tank	ZT01		X			30 Years		Bell and Gossett.	1	Ea.			x			
Lower Level/ Wing	Z-BWCT	Boiler Water Chemical Treatment System	ZT01					30 Years			1	Ea.			x			
		- Treatment Tanks			X		Assume 1996	30 Years	6 Years	Stainless Steel Storage tanks	2	Ea.			x			
		- Pumps			X		Assume 1996	20 Years	-4 Years	4 base mounted pumps. Tags not easily accessible. Believed to all be approx. 1.5 HP, 115/208-230V, 1 Ph.	4	Ea.			x			
		- Water Softener Tanks			X		Unknown	30 Years			2	Ea.			x			
		- Brine Tank			X		Unknown	30 Years			1	Ea.			x			
Z-Wing		Oil Storage	Exterior to Wing		X		Assume 1996			Per College - Never been used	1	Ea.			x			
Lower Level/ Wing	Z-FOP	Fuel Oil Pumps	ZT01		X		Assume 1996	20 Years	-4 Years	Per College - Never been used	3	Ea.			x			
Lower Level/ Wing	C-CRU-7	Condensate return tank and 2 pumps (system)	CT01		X		Assume 2005	20 Years	5 Years	Bell and Gossett. 12 GPM, 208V, 3 Ph. Making bubbling noises.	1	Ea.			x			
Lower Level/ Wing	C-HX-C	Heat Exchanger	CT01		X		Assume 2005	20 Years	5 Years	Bell and Gossett.	1	Ea.			x			
Lower Level/ Wing	C-ET-C	Expansion Tank	CT01		X		Assume 2005	30 Years	15 Years	Stickered with '2005'	1	Ea.			x			
Lower Level/ Wing	C-AS-C	Air Separator	CT01		X		Assume 2005	30 Years	15 Years		1	Ea.			x			
Lower Level/ Wing	C-HHW-P-1C (aka CP-1)	Heating Hot Water Base Mounted Pump	CT01		X		Assume 2005	20 Years	5 Years	R.L. Deppman. 140 GPM, 40 ft. Head, 3 HP. 230/460V, 3 Ph. (w/ disconnect and VFD)	1	Ea.			x			
Lower Level/ Wing	C-HHW-P-2C (aka CP-2)	Heating Hot Water Base Mounted Pump	CT01		X		Assume 2005	20 Years	5 Years	R.L. Deppman. 140 GPM, 40 ft. Head, 3 HP. 230/460V, 3 Ph. (w/ disconnect and VFD)	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required
Priority 1									
Priority 2									
Priority 3									
Priority 4									
Priority 5									

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category	
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5		
Lower Level/ Wing	D	HEX-ET	Heat Exchanger System (packaged system)	DT01													
		- Heat Exchanger	DT01			X		Stacked system on steel rails between air handlers. Would need to be replaced in similar configuration due to limitations on space. Steel showing signs of corrosion. System draining to floor through flex hose with rust on it (tripping hazard).	1	Ea.			x				
		- Expansion Tank	DT01			X		May have leaked at one time. Items below HEX showing signs that HEX leaked on them. Insulation torn. Flanges corroding.	1	Ea.			x				
		- Pumps	DT01			X		24 Years	30 Years								
		- Air Separator	DT01			X		Bell and Gossett, 125 GPM, 65 ft. Head, 5 HP, 230/460V, 3 Ph. Piping and flanges heavily corroded. (w/ VFD's)	2	Ea.			x				
Lower Level/ Wing	D	CP-1/2	Condensate Pumps - Serves AHUs via trench drain in room and HEX via piping	DT01		X	Assume 2006	20 Years	6 Years	Bell and Gossett, 50 GPM, 1.5 HP, 208-230/460V, 3 Ph. From model # assume 2006.	2	Ea.			x		
Lower Level/ Wing	D	HX-1D	Heat Exchanger	DT01	X		Assume 2015	24 Years		Califacito	1	Ea.			x		
Lower Level/ Wing	D	GF-2D	Glycol Feed	DT01	X		Assume 2015	30 Years	15 Years	Bell and Gossett, 53 gal.	1	Ea.			x		
Lower Level/ Wing	D	ET-1D	Expansion Tank	DT01	X		2015	30 Years	15 Years	Plastic. Approx. 50 gal.	1	Ea.			x		
Lower Level/ Wing	D	DT-1D	Drip Tank	DT01	X		Assume 2015	30 Years	25 Years		1	Ea.			x		
Lower Level/ Wing	D	AS-1D	Air Separator	DT01	X		Assume 2015	30 Years	25 Years		1	Ea.			x		
Lower Level/ Wing	D	HHWP-1D (aka CP-1)	Heating Hot Water Base Mounted Pump	DT01	X		Assume 2015	20 Years	15 Years	Bell and Gossett, 200 GPM, 45 ft. Head, 5 HP, 208-230/460V, 3 Ph. Per serial number assume 2015.	1	Ea.			x		
Lower Level/ Wing	D	HHWP-2D (aka CP-2)	Heating Hot Water Base Mounted Pump	DT01	X		Assume 2015	20 Years	15 Years	Bell and Gossett, 200 GPM, 45 ft. Head, 5 HP, 208-230/460V, 3 Ph. Per serial number assume 2015.	1	Ea.			x		
Lower Level/ Wing	D	CF-1D	Chemical Feeder	DT01	X		Assume 2015	30 Years	25 Years		1	Ea.			x		
Lower Level/ Wing	F	AS-1F	Air Separator - Serves HX-1F and HX-2F	FT01	X		2013	30 Years	23 Years		1	Ea.			x		
Lower Level/ Wing	F	AS-2F	Air Separator - Serves HX-3F	FT01	X		2013	30 Years	23 Years		1	Ea.			x		
Lower Level/ Wing	F	ET-1F	Expansion Tank	FT01	X		2013	30 Years	23 Years	Armstrong 80 gal.	1	Ea.			x		
Lower Level/ Wing	F	ET-2F	Expansion Tank	FT01	X		2013	30 Years	23 Years	Armstrong 211 gal.	1	Ea.			x		
Lower Level/ Wing	F	CT-1F	Chemical Feeder	FT01	X		Assume 2013	30 Years	23 Years		1	Ea.			x		
Lower Level/ Wing	F	HHWP-1F (aka CP-1)	Heating Hot Water Base Mounted Pump	FT01	X		2013	20 Years	13 Years	Armstrong, 405 GPM, 80 ft Head, 15 HP, 208/230-460V, 3 Ph. (w/ VFD)	1	Ea.			x		
Lower Level/ Wing	F	HHWP-2F (aka CP-2)	Heating Hot Water Base Mounted Pump	FT01	X		2013	20 Years	13 Years	Armstrong, 405 GPM, 80 ft Head, 15 HP, 208/230-460V, 3 Ph. (w/ VFD)	1	Ea.			x		
Lower Level/ Wing	F	HHWP-3F (aka CP-3)	Heating Hot Water Circulating Pump	FT01	X		2013	20 Years	13 Years	Armstrong, 65 GPM, 75 ft. Head, 3 HP, 480V, 3 Ph. (w/ VFD). Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	F	HHWP-4F (aka CP-4)	Heating Hot Water Circulating Pump	FT01	X		2013	20 Years	13 Years	Armstrong, 65 GPM, 75 ft. Head, 3 HP, 480V, 3 Ph. (w/ VFD). Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	F	HX-1F	Heat Exchanger	FT01	X		2013	24 Years	17 Years	389 MBH, 265 GPM. Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	F	HX-2F	Heat Exchanger	FT01	X		2013	24 Years	17 Years	389 MBH, 265 GPM. Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	F	HX-3F	Heat Exchanger	FT01	X		2013	24 Years	17 Years	798 MBH, 65 GPM. Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	F	CRU-1F	Condensate return tank and 2 pumps (system)	FT01	X		2013	30 Years	23 Years	Each pump 22 GPM, 1.5 HP, 480V, 3 Ph. (W/ control panel). Design data taken from documents provided by College.	1	Ea.			x		
Lower Level/ Wing	S-	CRU-S	Condensate return tank and 2 pumps (system)	ST01		X	Unknown	20 Years		40 GPM, 50 ft Head, 3 HP, 230/460V, 3 Ph. (with two disconnects). Water in the floor, appears to have leaks.	1	Ea.			x		
Lower Level/ Wing	S-	HX-1	Heat exchanger and pump skid (aka HW Circ Pump #2 - West) - Serves S-Wing Perimeter Heating including Classroom UV's, CUH's, Perimeter Fin Tube	ST01		X	1967	24 Years	-21 Years	22000/hr. System heavily corroded. Design data taken from documents provided by College.	1	Ea.		x			
Lower Level/ Wing	S-	HX-2	Heat exchanger and pump skid (aka HW Circ Pump #1 - East) - Unknown serves	ST01		X	1967	24 Years	-21 Years	14250/hr. System heavily corroded. Design data taken from documents provided by College.	1	Ea.		x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ Wing	B-	CRU-B	Condensate return tank and 2 pumps (system)	BT01		X	Unknown	20 Years		9 GPM. System heavily corroded. No date found. (w/ disconnects). Design data taken from documents provided by College.	1	Ea.		x				
Lower Level/ Wing	B-	HX-B	Heat Exchanger	BT01		X	Unknown	24 Years		System heavily corroded. No date found.	1	Ea.		x				
Lower Level/ Wing	B-	ET-1B	Expansion Tank	BT01		X	Unknown	30 Years		Bell and Gossett. Too high to review tag for info.	1	Ea.			x			
Lower Level/ Wing	B-	CP-3B	Heating Hot Water Circulating Pump	BT01		X	Unknown	20 Years		Inaccessible. Above piping. Piping heavily corroded in area. Assume older. (w/ disconnect)	1	Ea.		x				
Lower Level/ Wing	A-	CP-17A	Heating Hot Water Circulating Pump	AT01		X	2010	20 Years	10 Years	Bell and Gossett. 65 GPM, 2 HP, 200V, 3 Ph. Based on serial number believed to be 2010. (w/ VFD). 40 ft Head taken from documents provided by the College.	1	Ea.					x	
Lower Level/ Wing	A-	CP-17B	Heating Hot Water Circulating Pump	AT01		X	2010	20 Years	10 Years	Bell and Gossett. 65 GPM, 2 HP, 200V, 3 Ph. Based on serial number believed to be 2010 (w/ VFD). 40 ft Head taken from documents provided by the College.	1	Ea.					x	
Lower Level/ Wing	A-	AS-1A	Air Seperator	AT01		X	2010	30 Years	20 Years		1	Ea.					x	
Lower Level/ Wing	A-	HX-1A	Heat Exchanger	AT01		X	2010	24 Years	14 Years	7.5 PSIG Steam Input, 953.9 MBH Hot water output. Design data taken from documents provided by the College.	1	Ea.					x	
Lower Level/ Wing	A-	ET-1A	Expansion Tank	AT01		X	2010	30 Years	20 Years	Bell and Gossett B300, 80 gal.	1	Ea.					x	
Lower Level/ Wing	A-	CRU-A1	Condensate return tank and 2 pumps (system)	AT01		X	2010	20 Years	10 Years	Bell and Gossett. 14 Gal. receiver tank w/ 2 pumps. Each pump 9 GPM, 1.5 HP, 208V, 3 Ph.	1	Ea.					x	
Lower Level/ Wing	A-	CRU-A2	Condensate return tank and 2 pumps (system)	AT01		X	Unknown	20 Years		Aurora. 1/2HP. Appears older than others and may have leaked at one time.	1	Ea.			x			
Lower Level/ Wing	A-	CRU-A3	Condensate return tank and 2 pumps (system)	AT05		X	Unknown	20 Years		Bell and Gossett. 9 GPM.	1	Ea.			x			
Lower Level/ Wing	A-	HX-2A	Heat exchanger and pump skid with air seporator	AT05		X	Assume 1998	24 Years	2 Years		1	Ea.			x			
Lower Level/ Wing	A-	CRU-A4 (aka Cond 3)	Condensate return tank and 2 pumps (system)	AT07		X	Assume 1998	20 Years	-2 Years	Bell and Gossett. 9 GPM, 1/2 HP, 460V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	A-	CRU-A5	Condensate return tank and 2 pumps (system)	AT08		X	Assume 2011	20 Years	11 Years	Based on serial number believed to be 2011 (with disconnects)	1	Ea.					x	
Second Floor/ A-Wing		ET-2A	Expansion Tank	A221	X		2017	30 Years	27 Years	Bell and Gossett, 1702 MBH, 116 GPM	1	Ea.					x	
Second Floor/ A-Wing		AS-2A	Air Seperator	A221	X		2017	30 Years	27 Years	Bell and Gosset	1	Ea.					x	
Second Floor/ A-Wing		HHWP-1A (aka CP-1)	Heating Hot Water Circulating Pump (Base mounted)	A221	X		2017	20 Years	17 Years	Bell and Gossett. 116 GPM, 40 Ft. Head, 2 HP, 208V, 3 Ph. Design data taken from documents provided by the College	1	Ea.					x	
Second Floor/ A-Wing		HHWP-2A (aka CP-2)	Heating Hot Water Circulating Pump (Base mounted)	A221	X		2017	20 Years	17 Years	Bell and Gossett. 116 GPM, 40 Ft. Head, 2 HP, 208V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.					x	
Second Floor/ A-Wing		HX-3A (aka HX-1)	Heat Exchanger	A221	X		2017	20 Years	17 Years	Bell and Gossett, D40V	1	Ea.					x	
Second Floor/ G-Wing		HHWP-1G (aka CP-3)	Heating Hot Water Circulating Pump (inline)	G229	X		2017	20 Years	17 Years	Bell and Gossett. 12GPM, 25 Ft. Head, 1/6 HP, 120V, 1 Ph. Design data taken from documents provided by the College.	1	Ea.					x	
Lower Level/ Wing	A-	HES-5	Heat Exchanger	HT05		X	Assume 2005	24 Years	4 Years		1	Ea.			x			
Lower Level/ Wing	H-	CRU-5	Condensate return tank and 2 pumps (system)	HT01		X	Assume 2005	20 Years	4 Years	Bell and Gossett. 9 GPM, 1/2 HP, 208V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	H-	HHWP-1H	Heating Hot Water Base Mounted Pump	HT01		X	Assume 2004	20 Years	4 Years	Bell and Gossett. 40 GPM, 30 Ft. Head, 1 HP, 200V, 3 Ph. Based on serial number believed to be 2004. (w/ VFD and disconnect).	1	Ea.			x			
Lower Level/ Wing	H-	HHWP-2H	Heating Hot Water Base Mounted Pump	HT01		X	Assume 2004	20 Years	4 Years	Bell and Gossett. Assumed matched HHWP1H at 40 GPM and 30 ft. Head. 1 HP, 200V, 3 Ph. Based on serial number believed to be 2004. (w/ VFD and disconnect).	1	Ea.			x			
Lower Level/ Wing	H-	SF-H	Shot Feeder	HT01		X	Assume 2004	20 Years	4 Years		1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ Wing	J-CRU-20	Condensate return tank and 2 pumps (system)	JT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 9 GPM, 1/2 HP, 208V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	J-HHWP-1J	Heating Hot Water Base Mounted Pump	JT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 87 GPM, 35 ft. Head, 1.5 HP, 200V, 3 Ph. Based on serial number believed to be 2005. (w/ VFD and disconnect).	1	Ea.						x
Lower Level/ Wing	J-HHWP-2J	Heating Hot Water Base Mounted Pump	JT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 87 GPM, 35 ft. Head, 1.5 HP, 200V, 3 Ph. Based on serial number believed to be 2005. (w/ VFD and disconnect).	1	Ea.						x
Lower Level/ Wing	J-HES-20	Heat Exchanger	JT01	X			2005	24 Years	9 Years	Bell and Gossett, 888#/hr. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	J-SF-J	Shot Feeder	JT01	X			Assume 2005	20 Years	5 Years		1	Ea.						x
Lower Level/ Wing	K-HES-4	Heat Exchanger	KT01	X			2005	24 Years	9 Years	Bell and Gossett, 1225#/hr. Piping showing signs of corrosion. System may have leaked at one time.	1	Ea.						x
Lower Level/ Wing	K-ET-K	Expansion Tank	KT01	X			2005	30 Years	15 Years	Bell and Gossett, 100 gal.	1	Ea.						x
Lower Level/ Wing	K-HHWP-1K	Heating Hot Water Base Mounted Pump	KT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 120 GPM, 40 ft. Head, 3 HP, 200V, 3 Ph. Tag unreadable. Assumed same as HHWP-2K. (w/ VFD and disconnect)	1	Ea.						x
Lower Level/ Wing	K-HHWP-2K	Heating Hot Water Base Mounted Pump	KT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 120 GPM, 40 ft. Head, 3 HP, 200V, 3 Ph. (w/ VFD and disconnect)	1	Ea.						x
Lower Level/ Wing	K-CRU-4	Condensate return tank and 2 pumps (system)	KT01	X			Assume 2005	20 Years	5 Years	Bell and Gossett, 12 GPM, 208V, 3 Ph.	1	Ea.						x
Lower Level/ Wing	L-CP-1	Condensate return tank and 2 pumps (system)	LT01	X			Assume 2003	20 Years	3 Years	Bell and Gossett, 22 GPM, 1 HP, 208V, 3 Ph. (w/ disconnects)	1	Ea.						x
Lower Level/ Wing	L-HES-L	Heat Exchanger	LT01		X		Unknown	24 Years		Heavily corroded. Signs of leakage at one time. Insulation torn.	1	Ea.			x			
Lower Level/ Wing	L-SH-7	Humidifier	LT01	X			2003	20 Years	3 Years	DriSteem, 15 psig, 85#/hr. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	L-WH-1	Storage Water Heater (Steam)	LT01	X			Assume 2003	20 Years	3 Years	QuickDraw, 125 gal, 830 GPH, 750,000 Btu/h input, 115V, 1 Ph. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	L-WH-2	Storage Water Heater (Steam)	LT01	X			Assume 2003	20 Years	3 Years	QuickDraw, 125 gal, 830 GPH, 750,000 Btu/h input, 115V, 1 Ph. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	L-EXP-2	Expansion Tank	LT01	X			2003	30 Years	13 Years	Approx. 27 gal.	1	Ea.						x
Lower Level/ Wing	L-CP-4	Condensate return tank and 2 pumps (system)	LT01	X			Assume 2003	20 Years	3 Years	Bell and Gossett, 60 GPM, 3 HP, 208V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing	L-EXP-1	Expansion Tank	LT01	X			2003	30 Years	13 Years	Size 400L, (106 gal), 2750 MBH, 2750#/hr. Design data taken from documents provided by the College.	1	Ea.						x
Lower Level/ Wing	L-HX-1L	Heat Exchanger	LT01	X			2003	24 Years	7 Years	Insulation torn.	1	Ea.						x
Lower Level/ Wing	L-HHW-P-1L (aka HP-1)	Heating Hot Water Base Mounted Pump	LT01	X			Assume 2003	20 Years	3 Years	Bell and Gossett, 226 GPM, 70 ft. Head, 7.5 HP, 200V, 3 Ph. (w/ disconnect and VFD)	1	Ea.						x
Lower Level/ Wing	L-HHW-P-2L (aka HP-2)	Heating Hot Water Base Mounted Pump	LT01	X			Assume 2003	20 Years	3 Years	Bell and Gossett, Assume 226 GPM, 70 ft. Head, 7.5 HP, 200V, 3 Ph. to match HHW-1L. (w/ disconnect and VFD)	1	Ea.			x			
Lower Level/ Wing	L-AS-L	Air Seperator	LT01	X			Assume 2003	30 Years	13 Years		1	Ea.					x	
Lower Level/ Tunnel	P-AS-1P	Air Seperator	PT01		X		1990	30 Years	0 Years	Bell and Gossett, Small (at floor line)	1	Ea.			x			
Lower Level/ Tunnel	P-ET-1P	Expansion Tank	PT01				Unknown	30 Years		Up high. Inaccessible.	1	Ea.			x			
Lower Level/ Tunnel	P-HX-1P	Heat Exchanger	PT01		X		1967	24 Years	-29 Years	Up high. Inaccessible.	1	Ea.		x				
Lower Level/ Tunnel	P-HHWP-P-5	Heating Hot Water Pump	PT01	X			Unknown	20 Years		Tagged 'New motor and seal 10-10-17. 2 HP, 200-230/460V, 3 Ph. (w/ disconnect)	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concern and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Lower Level/ Wing	P	HX-2P	Heat Exchanger	P020		X	Assume 2003	24 Years	7 Years		1	Ea.					x	
Lower Level/ Wing	P	ET-2P	Expansion Tank	P020		X	2003	30 Years	3 Years		1	Ea.					x	
Lower Level/ Wing	P	CF-P	Chemical Feed	P020		X	Assume 2003	30 Years	3 Years	Tied to Heating Hot Water piping	1	Ea.			x			
Lower Level/ Wing	P	CP-4	Condensate return tank and 2 pumps (system)	P020		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 30 GPM, 460V, 3 ph.	1	Ea.			x			
Lower Level/ Wing	P	CP-5	Condensate return tank and 2 pumps (system)	P020		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 9 GPM, 460V, 3 ph.	1	Ea.			x			
Lower Level/ Wing	P	CP-8	Condensate return tank and 2 pumps (system)	P020		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 9 GPM, 460V, 3 ph.	1	Ea.			x			
Lower Level/ Wing	P	CP-9	Condensate return tank and 2 pumps (system)	P020		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 15 GPM, 460V, 3 ph.	1	Ea.			x			
Lower Level/ Wing	P	HHWP-1P (aka HP-1)	Heating Hot Water Base Mounted Pump	P020		X	Assume 2003	20 Years	3 Years	Assume matches CP-1. 7.5 HP, 208-230/460V, 3 Ph. Very loud, unable to get close to for long period to obtain pump info. (w/ disconnect and VFD). Flanges heavily corroded.	1	Ea.			x			
Lower Level/ Wing	P	HHWP-2P (aka HP-2)	Heating Hot Water Base Mounted Pump	P020		X	Assume 2003	20 Years	3 Years	7.5 HP, 208-230/460V, 3 Ph. (w/ disconnect and VFD). Flanges heavily corroded.	1	Ea.			x			
Lower Level/ Wing	P	ST-P	Storage Tank	P020		X	Assume 2003	30 Years	13 Years		1	Ea.			x			
Lower Level/ M-Tunnel		CRU-M	Condensate return tank and 2 pumps (system)	MT01		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 45 GPM, 1.5 HP, 460V, 3 Ph. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ M-Wing		ET-M	Expansion Tank	M201		X	Assume 2003	30 Years	13 Years	400L	1	Ea.			x			
Second Floor/ M-Wing		AS-M	Air Separator	M201		X	Assume 2003	30 Years		Flanges corroded.	1	Ea.			x			
Second Floor/ M-Wing		HXM-M (aka HX-1)	Heat Exchanger	M201		X	2003	24 Years	8 Years		1	Ea.			x			
Second Floor/ M-Wing		SF-M	Shot Feeder	M201		X	Assume 2003	20 Years	3 Years		1	Ea.			x			
Second Floor/ M-Wing		HHWP-1M (aka HP-1)	Heating Hot Water Base Mounted Pump	M201		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 210 GPM, 80 FT Head, 7.5 HP, 208-230/460V, 3 Ph. (w/ VFD and disconnect)	1	Ea.			x			
Second Floor/ M-Wing		HHWP-2M (aka HP-2)	Heating Hot Water Base Mounted Pump	M201		X	Assume 2003	20 Years	3 Years	Bell and Gossett, 210 GPM, 80 FT Head, 7.5 HP, 208-230/460V, 3 Ph. (w/ VFD and disconnect). Appears to have leaked at one time, excessive corrosion.	1	Ea.			x			
Lower Level/ Wing	E	HHWP-1E (aka HES2A)	Heating Hot Water Base Mounted Pump	ET01		X	Assume 2005	20	5 Years	R. L. Deppman, 150 GPM, 78 ft. Head, 7.5 HP, 230/460V, 3 Ph. (w/ disconnect)	1	Ea.			x			
Lower Level/ Wing	E	HHWP-2E (aka HES2B)	Heating Hot Water Base Mounted Pump	ET01		X	Assume 2005	20	5 Years	R. L. Deppman, 150 GPM, 78 ft. Head, 7.5 HP, 230/460V, 3 Ph. (w/ disconnect)	1	Ea.			x			
Lower Level/ Wing	E	AS-E	Air Separator	ET01		X	Assume 2005	30	15 Years		1	Ea.			x			
Lower Level/ Wing	E	HX-1E	Heat Exchanger	ET01		X	Assume 2005	24	9 Years		1	Ea.			x			
Lower Level/ Wing	E	ET-E	Expansion Tank	ET01		X	Assume 2005	30	15 Years		1	Ea.			x			
Lower Level/ Wing	E	CRU-6	Condensate return tank and 2 pumps (system)	ET01		X	Assume 2005	20	5 Years	Bell and Gossett, 12 GPM, 1/2 HP, 208V, 3 Ph.	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
EXTRANCE CABINET UNIT HEATERS																		
Lower Level/ A- Wing	CUH-1A	Cabinet Unit Heater	Corridor A096A - Wall Recessed	X			Unknown	20 Years			1	Ea.			x			
Lower Level/ A- Wing	CUH-2A	Cabinet Unit Heater	Corridor A096B - Wall Recessed	X			Unknown	20 Years			1	Ea.			x			
Lower Level/ N- Wing	CUH-1N	Cabinet Unit Heater	Break Area N005G - Wall Recessed	X			Unknown	20 Years		Trane, Analog Stat.	1	Ea.			x			
Lower Level/ N- Wing	CUH-2N	Cabinet Unit Heater	Corridor N095C - Wall Recessed	X			Unknown	20 Years			1	Ea.			x			
Lower Level/ N- Wing	CUH-3N	Cabinet Unit Heater	Break Area N005f - Wall Recessed	X			Unknown	20 Years		Trane.	1	Ea.			x			
First Floor/ N- Wing	CUH-4N	Cabinet Unit Heater	Vestibule N195C - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.				x		
First Floor/ N- Wing	CUH-5N	Cabinet Unit Heater	Vestibule N195C - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-6N	Cabinet Unit Heater	Vestibule N195C - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-7N	Cabinet Unit Heater	Vestibule N195C - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-8N	Cabinet Unit Heater	Vestibule N195A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-9N	Cabinet Unit Heater	Vestibule N195A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-10N	Cabinet Unit Heater	Vestibule N195A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-11N	Cabinet Unit Heater	Vestibule N195A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 660 CFM, 62 MBH 5.0 GPM Heating Hot Water, 0.22 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
First Floor/ N- Wing	CUH-12N	Cabinet Unit Heater	Vestibule N196e - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo. 340 CFM, 31 MBH 2.0 GPM Heating Hot Water, 0.13 HP, 120V, 1Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
											1	Ea.						
Lower Level/ F- Wing	CUH-1F (aka CH-1)	Cabinet Unit Heater	Stairs F097B - Wall Recessed	X			2013	20 Years	13 Years	Trane Force Flo 365 CFM, 30.1 MBH, 2.2 GPM Hot Water Heating, 1/12 HP, 120V, 1 Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
Lower Level/ F- Wing	CUH-2F (aka CH-3)	Cabinet Unit Heater	Stairs F197A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo 605 CFM, 47 MBH, 3.4 GPM Hot Water Heating, 1/16 HP, 120V, 1 Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
Lower Level/ F- Wing	CUH-3F (aka CH-2)	Cabinet Unit Heater	Vestibule F196A - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo 605 CFM, 47 MBH, 3.4 GPM Hot Water Heating, 1/16 HP, 120V, 1 Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
Lower Level/ F- Wing	CUH-4F (aka CH-4)	Cabinet Unit Heater	Vestibule F196B - Wall Recessed	X			2013	20 Years	13 Years	Trane Force Flo 365 CFM, 30.1 MBH, 2.2 GPM Hot Water Heating, 1/12 HP, 120V, 1 Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			
Lower Level/ F- Wing	CUH-5F (aka CH-5)	Cabinet Unit Heater	Storage F267 - Ceiling Recessed	X			2013	20 Years	13 Years	Trane Force Flo 365 CFM, 30.1 MBH, 2.2 GPM Hot Water Heating, 1/12 HP, 120V, 1 Ph. Design data taken from ddocuments provided by the College.	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
First Floor/ Wing	S CUH-1-S (aka CUH #10)	Cabinet Unit Heater	Stairs 197A - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 38,200 BTU/hr, 2 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-2-S (aka CUH #11)	Cabinet Unit Heater	Lobby S175 - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 45,200 BTU/hr, 4 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-3-S (aka CUH #12)	Cabinet Unit Heater	Corridor S195C - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 395 CFM, 15,000 BTU/hr, 1.5 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-4-S (aka CUH #13)	Cabinet Unit Heater	Stairs 197C - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 45,200 BTU/hr, 4 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-5-S (aka CUH #8)	Cabinet Unit Heater	Stairs 197B - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 38,200 BTU/hr, 2 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-6-S (aka CUH #7)	Cabinet Unit Heater	Lobby S175 - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 45,200 BTU/hr, 4 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-7-S (aka CUH #6)	Cabinet Unit Heater	Corridor S195E - Wall recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 395 CFM, 15,000 BTU/hr, 1.5 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-8-S (aka CUH #5)	Cabinet Unit Heater	Stairs 197D - Wall Recessed	X			Assume 1970	20 Years	-30 Years	Nesbitt. 490 CFM, 43,000 BTU/hr, 3 GPM, 1/20 HP. Design data taken from documents provided by the College.	1	Ea.			x	
First Floor/ Wing	S CUH-9-S	Cabinet Unit Heater - Ceiling Surface Mounted Above Overhead doors	S139 - Ceiling Surface Mounted		X		Unknown	20 Years		Trane. Door open. Not on at time of survey.	1	Ea.		x		
First Floor/ Wing	G CUH-1-G	Cabinet Unit Heater	CORRIDOR G195C - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	G CUH-2-G	Cabinet Unit Heater	Stairs G197B - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	G CUH-3-G	Cabinet Unit Heater	Stairs G197A - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	H CUH-1-H	Cabinet Unit Heater	Corridor H195B - Wall Recessed	X			2005	20 Years	5 Years		1	Ea.		x		
First Floor/ Wing	H CUH-2-H	Cabinet Unit Heater	Vestibule H196A - Wall Recessed	X			2005	20 Years	5 Years		1	Ea.		x		
First Floor/ Wing	J CUH-1-J	Cabinet Unit Heater	Vestibule J196A - Wall Recessed	X			2005	20 Years	5 Years		1	Ea.		x		
First Floor/ Wing	J CUH-2-J	Cabinet Unit Heater	Corridor J195B - Wall Recessed	X			2005	20 Years	5 Years		1	Ea.		x		
First Floor/ Wing	K CUH-1-K	Cabinet Unit Heater	Vestibule K195B - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	K CUH-2-K	Cabinet Unit Heater	Corridor K195B - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	L CUH-1-L	Cabinet Unit Heater	Vestibule L196A - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	M CUH-1-M	Cabinet Unit Heater	Vestibule M196A - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	M CUH-2-M	Cabinet Unit Heater	Vestibule M196B - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	M CUH-2-M	Cabinet Unit Heater	Vestibule M195C - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	P CUH-1-P	Cabinet Unit Heater	Corridor P196B - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		
First Floor/ Wing	P CUH-2-P	Cabinet Unit Heater	Corridor P160 - Wall Recessed	X			Assum 1993	20 Years	-7 Years		1	Ea.		x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>UNIT HEATERS (UH)</b>																		
Lower Level/ B-Wing	UH-B	Unit Heater - Serves IDF room located in	BT02		X		Unknown	20 Years		American Standard. Fed off steam. Analog stat.	1	Ea.				x		
Second Floor/ D-Wing	UH-1D	Unit Heater - Serves Mechanical Room located in	DT01		X		Unknown	20 Years		Trane. Heating hot water.	1	Ea.				x		
Second Floor/ D-Wing	UH-2D	Unit Heater - Serves Substation Room located in	DT02		X		Unknown	20 Years		Trane. Heating hot water. Analog stat.	1	Ea.				x		
Second Floor/ D-Wing	UH-3D	Unit Heater	D202		X		Unknown	20 Years		Up high.	1	Ea.				x		
First Floor/ M-Wing	UH-1-M	Unit heater	M162		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-2-M	Unit heater	M156		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-3-M	Unit heater	M150B		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-4-M	Unit heater	M150D		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-6-M	Unit heater	M115		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-6-M	Unit heater	M114		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-7-M	Unit heater	M110		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ M-Wing	UH-8-M	Unit heater	M106		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
Grade Level/ M-Wing	UH-9-M	Unit heater	M106 (M105)		X		Assum 2003	20 Years	3 Years	Trane	1	Ea.				x		
First Floor/ L-Wing	L-UH-1-L	Unit heater	L140		X		Assum 2003	20 Years	3 Years		1	Ea.				x		
First Floor/ Z-Wing	UH-1-Z	Unit heater - Serves Room Located in	Z110		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-2-Z	Unit heater - Serves Room Located in	Z108		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-3-Z	Unit heater - Serves Room Located in	Z102		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-4-Z	Unit heater - Serves Room Located in	Z102		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-5-Z	Unit heater - Serves Room Located in	Z101		X		Unknown	20 Years		Dayton, Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-6-Z	Unit heater - Serves Room Located in	Z101		X		Unknown	20 Years		Dayton, Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-7-Z	Unit heater - Serves Room Located in	ZT01		X		Unknown	20 Years			1	Ea.				x		
First Floor/ Z-Wing	UH-8-Z	Unit heater - Serves Room Located in	Z101		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-9-Z	Unit heater - Serves Room Located in	High Bay ZT01		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ Z-Wing	UH-10-Z	Unit heater - Serves Room Located in	High Bay ZT01		X		Unknown	20 Years		Up high, Inaccessible	1	Ea.				x		
First Floor/ P-Wing	P-UH-1-P	Unit heater	P105		X		Unknown	20 Years			1	Ea.				x		
First Floor/ P-Wing	P-UH-2-P	Unit heater	P105		X		Unknown	20 Years			1	Ea.				x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>UNIT VENTILATOR</b>																		
First Floor/ Wing	S- UV-18 (aka UV-A-16)	Unit Ventilator	Classroom S125		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 40,600 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-28 (aka UV-A-15)	Unit Ventilator	Classroom S125		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 40,600 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-3S (aka UV-A-11)	Unit Ventilator	Classroom S101		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-4S (aka UV-A-10)	Unit Ventilator	Classroom S101		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-5S (aka UV-A-9)	Unit Ventilator	Area S103		X		2003	20 Years	13 Years	500 CFM, 25% OA, 15,500 BTU/hr cooling, 36,720 BTU/hr heating, 1.5 GPM, 1/2 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-6S (aka UV-A-8)	Unit Ventilator	Classroom S104		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 48,600 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-7S (aka UV-A-7)	Unit Ventilator	Classroom S104		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-8S (aka UV-A-6)	Unit Ventilator	Classroom S132		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 51,280 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-9S (aka UV-A-5)	Unit Ventilator	Classroom S134		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 50,000 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-10S (aka UV-A-4)	Unit Ventilator	Classroom S142			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 2 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-11S (aka UV-A-3)	Unit Ventilator	Classroom S140			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 48,600 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-12S (aka UV-A-2)	Unit Ventilator	Classroom S140			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 48,600 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-13S (aka UV-A-2)	Unit Ventilator	Classroom S131			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 2 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-14S (aka UV-A-1)	Unit Ventilator	Classroom S131			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,000 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-15S (aka UV-A-14)	Unit Ventilator	Classroom S130			X	2003	20 Years	13 Years	1000 CFM, 25% OA, 55,400 BTU/hr cooling, 32,400 BTU/hr heating, 1 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	S- UV-16S (aka UV-A-1)	Cabinet Unit Heater - Ceiling Surface Mounted Above Overhead doors	S139 - Ceiling Surface Mounted			X	Unknown	20 Years		Trane. Door open. Not on at time of survey. 1500 CFM, 25% OA, 52,500 BTU/hr cooling, 56,700 BTU/hr heating, 1.5 GPM, 1/6 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-16	Unit Ventilator	Classroom S228			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-17	Unit Ventilator	Classroom S226			X	2003	20 Years	13 Years	300 CFM, 25% OA, 8600 BTU/hr cooling, 16,875 BTU/hr heating, 2.5 GPM, 1/35 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-18	Unit Ventilator	Classroom S226			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-19	Unit Ventilator	Classroom S225			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-20	Unit Ventilator	Classroom S223			X	2003	20 Years	13 Years	500 CFM, 25% OA, 15,800 BTU/hr cooling, 21,600 BTU/hr heating, 1 GPM, 1/12 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-21	Unit Ventilator	Classroom S221			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-9	Unit Ventilator	Classroom S201			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,400 BTU/hr heating, 2 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-8	Unit Ventilator	Classroom S201			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 54,400 BTU/hr heating, 2 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-35S	Unit Ventilator	Area S203			X	2003	20 Years	13 Years	500 CFM, 25% OA, 15,500 BTU/hr cooling, 30,240 BTU/hr heating, 1 GPM, 1/12 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-39S	Unit Ventilator	Classroom S204			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 51,280 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-40S	Unit Ventilator	Classroom S204			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 51,280 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-41S (aka UV-B-4)	Unit Ventilator	Classroom S231			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 51,280 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-42S (aka UV-B-2)	Unit Ventilator	Classroom S253			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 50,000 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-43S (aka UV-B-1)	Unit Ventilator	Classroom S253			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-44S (aka UV-B-15)	Unit Ventilator	Classroom S258			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-45S (aka UV-B-14)	Unit Ventilator	Room S259			X	2003	20 Years	13 Years	500 CFM, 25% OA, 21,000 BTU/hr cooling, 12,000 BTU/hr heating, 1 GPM, 1/2 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-46S (aka UV-B-13)	Unit Ventilator	Classroom S260			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-47S (aka UV-B-12)	Unit Ventilator	Classroom S263			X	2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 52,600 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
Second Floor/ S-Wing	S- UV-B-48S (aka UV-B-11)	Unit Ventilator	Classroom S263			X	2003	20 Years	13 Years	500 CFM, 25% OA, 8600 BTU/hr cooling, 16,875 BTU/hr heating, 2.5 GPM, 1/35 HP. Design data taken from documents provided by the College.	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area:	899,682 SF
No. of Floors:	3
Year Built:	1961
Year Renovated:	Various -- see A001, A002 and A003
Evaluated:	First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Second Floor/ S-Wing	UV-49S (aka U.V. B-10)	Unit Ventilator	Classroom S266		X		2003	20 Years	13 Years	1250 CFM, 25% OA, 45,000 BTU/hr cooling, 50,000 BTU/hr heating, 1.5 GPM, 1/4 HP. Design data taken from documents provided by the College.	1	Ea.			x			
First Floor/ Wing	K	UV-1-K	Unit Ventilator	Classroom K103				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-2-K	Unit Ventilator	Classroom K105				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-3-K	Unit Ventilator	Classroom K107				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-4-K	Unit Ventilator	Classroom K109				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-5-K	Unit Ventilator	Classroom K111				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-6-K	Unit Ventilator	Classroom K116				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-7-K	Unit Ventilator	Classroom K114				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-8-K	Unit Ventilator	Classroom K110				Assum 1993	20 Years	-7 Years		1	Ea.			x		
First Floor/ Wing	K	UV-9-K	Unit Ventilator	Classroom K104				Assum 1993	20 Years	-7 Years		1	Ea.			x		
<b>SPLIT SYSTEMS</b>																		
First Floor/ F-Wing	AC-1F/ ACCU-1F	IDF Room AC Unit	F155		X		2013	20 Years	13 Years	Daikin, 9000 BTUH Cooling only with condensate pump.	1	Ea.				x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category		
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5			
<b>SPECIALTY SYSTEMS</b>																				
Lower Level/ Wing S-	PSF-1	Pool Sand Filter with Pump (Skid)	ST01		X		2011	20 Years	11 Years	Triton II System with 3 HP, 208-230/460V, 3ph.	1	Ea.			x					
Lower Level/ Wing S-	AC-S	Air Compressor	ST01		X		unknown	20 Years	(Not being used)	Serves pneumatic controls on wall. No pressure at time of survey on gauge (w/ disconnect). Per College, not being used.	1	Ea.				x				
Lower Level/ Wing B-	AC-B	Air Compressor - Serves dry fire suppression for data center.	BT01		X		unknown	20 Years	(Not being used)	Emgo: Serves dry fire suppression for data center.	1	Ea.		x						
Lower Level/ Wing A-	AC-A	Air Compressor	AT01			X	unknown	20 Years	(Not being used)	DevBiliss. Serves pneumatic controls on wall. (w/ disconnect). Appears older. Per College, not being used.	1	Ea.			x					
Lower Level/ Wing L-	AC-L	Air Compressor	LT01			X	unknown	20 Years	(Not being used)	DevBiliss. Serves pneumatic controls on wall. (w/ disconnect). Appears disconnected. Per College, not being used.	1	Ea.			x					
Lower Level/ Wing Z-	CA-DR	Compressed Air Dryer	ZT01		X		unknown	20 Years		Parker Airtak	1	Ea.			x					
Lower Level/ Wing Z-	AC-1	Air Compressor	ZT01	X			1996 Rebuilt 2019	20 Years	19 Years	Quincy 200 gal. (w/ disconnect)	1	Ea.			x					
Lower Level/ Wing Z-	AC-2	Air Compressor	ZT01	X			1997 Rebuilt 2019	20 Years	20 Years	Quincy 200 gal. (w/ disconnect)	1	Ea.			x					
Lower Level/ Wing Z-	AC-3	Air Compressor	ZT01	X			1998 Rebuilt 2019	20 Years	21 Years	Quincy 200 gal. (w/ disconnect)	1	Ea.			x					
Lower Level/ Wing P	PFP	Pool Filter Pump (Main Pool Pump)	P020		X		2011	20 Years	11 Years	Marlow. 40 HP, 230-460V, 3 Ph. (w/ disconnect)	1	Ea.			x					
Lower Level/ Wing P	OP	Ozone Pump	P020			X	2013	20 Years	0 Years (See remarks)	Aurora. 535 GPM, 110 ft. Head, 20 HP, 208-230/460V, 3 Ph. Per Id # assume 2013. Per College, not operational since 2018	1	Ea.	x							
Lower Level/ Wing P	PAP	Pool Activities Pump	P020		X		2003	20 Years	3 Years	Marlow. 7.5 HP, 230/460V, 3 Ph. (w/ disconnect).	1	Ea.		x						
Lower Level/ Wing P	PCP	Pool Current Pump	P020		X		2003	20 Years	3 Years	Marlow. 15 HP, 208-230/460V, 3 Ph. (w/ disconnect).	1	Ea.		x						
Lower Level/ Wing P	PSP	Pool Slide Pump	P020		X		2003	20 Years	3 Years	Marlow. 10 HP, 208-230/460V, 3 Ph. (w/ disconnect).	1	Ea.		x						
Lower Level/ Wing P	SFP	Spa Filter Pump	P020		X		2003	20 Years	3 Years	Marlow. 7.5 HP, 230/460V, 3 Ph. (w/ disconnect).	1	Ea.		x						
Lower Level/ Wing P	SJP	Spa Jet Pump	P020		X		2003	20 Years	3 Years	Marlow. 15 HP, 208-230/460V, 3 Ph. (w/ disconnect).	1	Ea.		x						
Lower Level/ Wing P	PHX1&2	Pool Heat Exchangers	P020	X			2010	24 Years	14 Years	1281 MBH, 57 GPM. Design data taken from documents provided by the College.	1	Ea.			x					
Lower Level/ Wing P	SHX1&2	Spa Heat Exchangers	P020		X		2003	24 Years	7 Years	199 MBH, 16 GPM. Design data taken from documents provided by the College.	1	Ea.			x					
Lower Level/ Wing P	CP-6	Condensate return tank and 2 pumps (system)	P020		X		2003	20 Years	3 Years	Bell and Gossett. 12 GPM, 460V, 3 Ph.	1	Ea.		x						
Lower Level/ Wing P	CP-7	Condensate return tank and 2 pumps (system)	P020		X		2003	20 Years	3 Years	Bell and Gossett. 9 GPM, 460V, 3 Ph. Water on floor underneath.	1	Ea.		x						
Lower Level/ Wing P	PST-1&2	Pool Water Storage Tanks	P020	X			2003	30 Years	13 Years		2	Ea.			x					
Lower Level/ Wing P	SF-1&2	Spa Filter Tanks	P020	X			2003	30 Years	13 Years		2	Ea.			x					
Lower Level/ Wing A-	CT-1A	Chemical Treatment	Corridor A059 (Below Stairs)																	
		- Tanks			X		2003	30 Years	13 Years		4	Ea.			x					
		- Pumps			X		2003	20 Years	3 Years (w/ 2 disconnects)		2	Ea.		x						
Exterior Grade	DC-1	Dust Collector - Serves Welding Lab L140	Exterior to L-Wing		X		2003			Torit (w/ 2 disconnects). Heavily corroded.	1	Ea.		x						
First Floor/ L-Wing	RCF-1 (aka FC 1)	Fume Collector	Exterior to Wing				2020	20 Years	20 Years	Welding Lab recirculation fan, 7000 CFM, 20 HP, 480V, 3 Ph. (w/ VFD)	1	Ea.			x					

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category	
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5		
<b>HVAC CONTROLS</b>																			
A-Wing	DDC-1	Local control panels	For each AHU		X		Assume 2010			Local Trane and American Automatrix control panels in mechanical room AT01. Assumed date 2010 based on Trane AHU's installed.							x		
A-Wing	DDC-2	Local controllers	Each piece of equipment		X					Some local Bellimo controllers	1	Ea.						x	
A-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
B-Wing	DDC-1	Local control panels	For each AHU															x	
B-Wing	DDC-2	Local controllers	Each piece of equipment															x	
B-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
C-Wing	DDC-1	Local control panels	For each AHU															x	
C-Wing	DDC-2	Local controllers	Each piece of equipment															x	
C-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
D-Wing	DDC-1	Local control panels	For each AHU															x	
D-Wing	DDC-2	Local controllers	Each piece of equipment															x	
D-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
E-Wing	DDC-1	Local control panels	For each AHU															x	
E-Wing	DDC-2	Local controllers	Each piece of equipment															x	
E-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
F-Wing	DDC-1	Local control panels	For each AHU															x	
F-Wing	DDC-2	Local controllers	Each piece of equipment															x	
F-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
G-Wing	DDC-1	Local control panels	For each AHU															x	
G-Wing	DDC-2	Local controllers	Each piece of equipment															x	
G-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
H-Wing	DDC-1	Local control panels	For each AHU															x	
H-Wing	DDC-2	Local controllers	Each piece of equipment															x	
H-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	
J-Wing	DDC-1	Local control panels	For each AHU															x	
J-Wing	DDC-2	Local controllers	Each piece of equipment															x	
J-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
K-Wing	DDC-1	Local control panels	For each AHU															x
K-Wing	DDC-2	Local controllers	Each piece of equipment															x
K-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x
L-Wing	DDC-1	Local control panels	For each AHU															x
L-Wing	DDC-2	Local controllers	Each piece of equipment															x
L-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x
M-Wing	DDC-1	Local control panels	For each AHU															x
M-Wing	DDC-2	Local controllers	Each piece of equipment															x
M-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x
N-Wing	DDC-1	Local control panels	For each AHU															x
N-Wing	DDC-2	Local controllers	Each piece of equipment															x
N-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x
P-Wing	DDC-1	Local control panels	For each AHU															x
P-Wing	DDC-2	Local controllers	Each piece of equipment															x
P-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x
S-Wing	DDC-1	Local control panels	For each AHU		X	Assume 1970				Johnson Controls panel located in ST01. Appears to be pneumatic controls only for AHU-22. See above for air compressor info.							x	
S-Wing	DDC-2	Local controllers	Each piece of equipment							No obvious controllers at equipment								x
S-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's		X	Assume 1970				Local stats/sensors in rooms/areas, with some dial controls. Some stats broken.							x	
Z-Wing	DDC-1	Local control panels	For each AHU															x
Z-Wing	DDC-2	Local controllers	Each piece of equipment															x
Z-Wing	DDC-3	Local Controls	FCU's, Conv., and CUH's															x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>DOMESTIC WATER HEATING EQUIPMENT</b>																		
Lower Level/ Tunnel	L	DHW-CP-1	Domestic Hot Water Circulating Pump	LT02		X		Unknown	20 Years		Bell and Gossett. Inaccessible to read tag, but appears newer	1	Ea.			x		
Lower Level/ Wing	M	WH-1Z	Domestic Hot Water Heater	ZT01	X			2014	20 Years	14 Years	Aerco Fire Tube	1	Ea.			x		
Lower Level/ Wing	M	WH-2Z	Domestic Hot Water Heater	ZT01	X			2014	20 Years	14 Years	Aerco Fire Tube	1	Ea.			x		
Lower Level/ Wing	M	WH-3Z	Domestic Hot Water Heater	ZT01	X			2014	20 Years	14 Years	Aerco Fire Tube	1	Ea.			x		
First Floor/ Wing	Z	DWP-1	Domestic Water Pump	Z104			X	1990	20 Years	-10 Years	Goulds, 15 HP230/460V	1	Ea.		x			
First Floor/ Wing	Z	DWP-2	Domestic Water Pump	Z104			X	1990	20 Years	-10 Years	Goulds, 15 HP230/460V	1	Ea.		x			
Second Floor/ G-Wing		WH-1G	Domestic Hot Water Heater	G229		X		2003	20 Years	3 Years	Bradford White. 50 gallon, 184,300 BTU/hr, 208V, 3 Ph.	1	Ea.			x		
<b>ELEVATOR EQUIPMENT:</b>																		
G-Wing		Elevator Equipment (Passenger)			X		unknown			ThyssenKrupp Hydraulic.	1	Ea.			x			
N-Wing		Elevator Equipment (Passenger)			X			2003		ThyssenKrupp. 150 GPM, 40 HP, 200V, 3 Ph.	1	Ea.			x			
P-Wing		Elevator Equipment (Freight)			X					ThyssenKrupp Hydraulic.	1	Ea.			x			
S-Wing		Elevator Equipment			X		unknown			Hydraulic. 30HP pump, 230/460V, 3 Ph.	1	Ea.			x			
<b>FIRE PROTECTION</b>																		
Lower Level/ Wing	S-	FP-1	Fire Pump (vertical)	ST01		X			20 Years		Reliance motor, 40 HP, 230/460V, 3 Ph.	1	Ea.			x		
Lower Level/ Wing	S-	FP-2	Fire Pump (horizontal)	ST01	X		Assumed 2006	20 Years	6 Years	Baldor motor, 2 HP, 208-230/460V, 3 Ph. Based on Serial number could be 2006. (with disconnect)	1	Ea.			x			
<b>PLUMBING FIXTURES</b>																		
Lower Level/ Wing	S-	NG-S	Natural Gas Meter	ST01		X				Rockwell Meter. Meter read 340350 CF	1	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>SUMP PUMPS</b>																		
Lower Level/ Wing S-	SP-1/2	Sumps Pumps - Serves S-Wing Mechanical Room located in	ST01			X	Assume 1970	10 Years	-40 Years	Below Grade (with 2 disconnects)	1	Ea.			x			
Lower Level/ Wing S-	SP1	Sump Pump - Serves Tunnel located in	ST03			X	Assume 1970	10 Years	-40 Years	Below Grade	1	Ea.			x			
Lower Level/ Wing B-	SP-1/2	Sumps Pumps - Serves B-Wing Mechanical Room located in	BT01					10 Years		(with 2 disconnects)	1	Ea.			x			
Lower Level/ Wing A-	SP-1/2	Sumps Pumps - Serves A-Wing Mechanical Room located in	AT07				Unknown	10 Years		Below Grade. (with 1 disconnect)	1	Ea.			x			
Lower Level/ Wing A-	SP-1/2	Sump Pumps - Serves Tunnel located in	AT08					10 Years		(with 2 disconnects)	1	Ea.			x			
Lower Level/ Wing L-	SP-1/2	Sumps Pumps - Serves L-Wing Mechanical Room located in	LT01				Unknown	10 Years		Below Grade. 15 GPM Design data aken from documents provided by the College.	1	Ea.			x			
Lower Level/ Wing M-Wing	SE-1/2	Sewage Ejectors	MT01					10 Years			1	Ea.			x			
Lower Level/ Wing Z	SP-1/2	Sumps Pumps - Serves Z-Wing Mechanical Room located in	ZT01					10 Years		(with 2 disconnects)	1	Ea.			x			
Lower Level/ Wing F	SP-1/2	Sumps Pumps - Serves F-Wing Mechanical Room located in	FT01			X	Assume 2013	10 Years	3 Years	5 HP, 208-230/460V, 3 Ph. (with 2 disconnects). Water in well.	1	Ea.			x			
Lower Level/ Wing F	SE-1/2	Sewage Ejectors	FT01			X	Assume 2013	10 Years	3 Years		1	Ea.			x			
Lower Level/ Wing D	SP-1/2	Sumps Pumps - Serves D-Wing Mechanical Room located in	DT01					10 Years		(with 1 disconnect)	1	Ea.			x			
Lower Level/ Wing D	SP-1/2	Sumps Pumps - Serves D-Wing Mechanical Room located in	DT01					10 Years		(with 1 disconnect)	1	Ea.			x			
Lower Level/ Wing P	SP-1/2	Sumps Pumps	P020			X	Assume 1977	10 Years	-33 Years	Below grade.(with 2 disconnects - North SP disconnect in off position)	1	Ea.			x			
Lower Level/ Wing P	SE-1/2	Sewage Ejectors	P020			X	Assume 2002	10 Years	-8 Years	5 HP, 230/460V, 3 Ph. (Pump 1 disconnect in off position, Pump 2 in on position). Per serial number assume 2002.	1	Ea.			x			
Elevator Pit	SP2	Sump Pump	F09A	X			2013	10 Years	3 Years		1	Ea.						

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>FIRE ALARM</b>																		
A Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years	Conference Room A112 and Pantry A113 require notification devices	153400	SF			x			
B Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		25,500	SF			x			
C Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years	Corridor C195A requires notification devices within 15 ft at the end of the corridor	39,800	SF	1		x			
D Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		40,300	SF			x			
E Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years	Corridors E195A requires notification device within 15 ft at the end of the corridor	28,400	SF	1		x			
F Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		93,400	SF			x			
G Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		20,700	SF			x			
H Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years	Conference Rooms H101 and H103 require notification devices	11,630	SF	1		x			
J Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		27,150	SF			x			
K Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years	Classrooms and Room K100 require notification devices	16,250	SF	1		x			
L Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		35,100	SF			x			
M Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		70,800	SF			x			
N Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		126,100	SF			x			
P Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		176,100	SF			x			
S Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		79,900	SF			x			
Z Wing		F.A. Notification/Initiation	Throughout		X		1998	15 Years	-7 Years		14,100	SF			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
BRANCH PANELS (LIGHTING AND RECEPTACLE)																		
A WING																		
	PP-10A	Panelboard	Room AT02	X			2010	25 Years	15 Years	Square D. 120/208V. 3PH. 4W. 1200A. M.L.O.	1	Ea.				x	No deficiency observed	
	LP-RR-1	Load Center	Room AT02	X			2010	25 Years	15 Years	Square D. 120/208V. 3PH. 4W	1	Ea.				x	No deficiency observed	
	LP-RR	Load Center	Room AT02		X		1961	25 Years	-34 Years	G.E.120/208V 3PH 4W 100A M.L.O.	1	Ea.				x	No deficiency observed	
	LP-RRA	Load Center	Room AT02				1965	25 Years	-30 Years	Square D. 120/208V M.L.O.	1	Ea.				x	No deficiency observed	
	PP-10	Panelboard	Room AT02		X		1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W. Rusted	1	Ea.		x				
	GDP-EL	Panelboard	Room AT02	X			2015	25 Years	20 Years	Square D. 480/277V. 3PH. 4W 400A 3P. M.C.B., 200A. Nameplate Main breaker size is larger than PNL mains	1	Ea.	x					
	EM-B	Panelboard	Room AT02	X			2015	25 Years	20 Years	Square D. 120/208V. 3PH. 4W 100A M.L.O.	1	Ea.				x	No deficiency observed	
	GDP-EM	Panelboard	Room AT02	X			2015	25 Years	20 Years	Square D. 480/277V. 3PH. 4W 250A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	EM-DPA	Panelboard	Room AT06	X			2014	25 Years	19 Years	Square D. 480V. 3 PH 3W 100A. M.L.O.	1	Ea.				x	No deficiency observed	
	EM-DPB	Panelboard	Room AT06	X			2014	25 Years	19 Years	Square D. 480V. 3 PH 3W 225A. M.L.O.	1	Ea.				x	No deficiency observed	
	PP-17	Panelboard	Room AT06		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 600A 3P M.S.W.	1	Ea.				x	No deficiency observed	
	PP-15	Panelboard	Room AT06		X		1998	25 Years	3 Years	Square D. 480V. 3 PH 3W 600A. M.L.O.	1	Ea.				x	No deficiency observed	
	PP-16	Panelboard	Room AT06		X		1998	25 Years	3 Years	Square D. 480V. 3 PH 3W 600A. M.L.O.	1	Ea.				x	No deficiency observed	
	PP-18	Panelboard	Room AT06		X		1998	25 Years	3 Years	Square D. 120/208V. 3PH. 4W. 800A 3P M.S.W.	1	Ea.				x	No deficiency observed	
	EM-PP	Panelboard	Room AT06	X			2014	25 Years	19 Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.				x	No deficiency observed	
	GEN-A	Generator	Room AT06						20 Years	Cummins 20KW 480/277V	1	Ea.				x	No deficiency observed	
	ATS-EL-A	ATS	Room AT06	X			2014	25 Years	19 Years	Cummins 40A., 480V	1	Ea.				x	No deficiency observed	
	ATS-EM-A	ATS	Room AT06	X			2014	25 Years	19 Years	Cummins 40A., 480V	1	Ea.				x	No deficiency observed	
	ATS-EMB	ATS	Room AT06	X			2014	25 Years	19 Years	Kohler	1	Ea.				x	No deficiency observed	
	IG-AC (1)	Panelboard	Room A127		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 400A. M.L.O.	1	Ea.				x	No deficiency observed	
	IG-AC (2)	Panelboard	Room A127		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 400A. M.L.O.	1	Ea.				x	No deficiency observed	
	IG-ACA	Panelboard	Room A127		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W M.L.O.	1	Ea.				x	No deficiency observed	
	LP-AC (1)	Panelboard	Room A127		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 400A M.L.O.	1	Ea.				x	No deficiency observed	
	LP AC (2)	Panelboard	Room A127		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 400A M.L.O.	1	Ea.				x	No deficiency observed	
	EM-A	Panelboard	Room A127	X			2015	25 Years	20 Years	Square D. 120/208V. 3 PH 4W 125A M.L.O.	1	Ea.				x	No deficiency observed	
	EL-A	Panelboard	Room A127	X			2015	25 Years	20 Years	Square D. 120/208V. 3 PH 4W 100A M.L.O.	1	Ea.				x	No deficiency observed	
	IG-AE	Panelboard	Room A116		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W M.L.O.	1	Ea.				x	No deficiency observed	
	LP-AE-2A	Load Center	Room A100	X			2015	25 Years	20 Years	Square D. 120/208V. 1 PH 3W 125A M.L.O.	1	Ea.				x	No deficiency observed	
	LP-AE(1)	Panelboard	Room A116		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 225A M.L.O.	1	Ea.				x	No deficiency observed	
	LP-AE(2)	Panelboard	Room A116		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 225A M.L.O.	1	Ea.				x	No deficiency observed	
	LP-U	Panelboard	Room A016		X		2005	25 Years	10 Years	Square D. 120/208V, 3ph, 4W, 200A, MCB	1	Ea.				x	No deficiency observed	
	IG-Y	Panelboard	Room A131		X		1998	25 Years	3 Years	Square D. 120/208V. 3 PH 4W 100A M.L.O.	1	Ea.				x	No deficiency observed	



<b>Delta College Main Campus</b>	
Building Area:	899,682 SF
No. of Floors:	3
Year Built:	1961
Year Renovated:	Various -- see A001, A002 and A003
Evaluated:	First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed
Fair	In the second half of its life, minor repairs needed or higher than routine maintenance required
Poor	Exceeded its useful life AND extremely worn, damaged or not functional (run high maintenance and costs)

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered or no immediate action required

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
B WING																		
	LP-ZZA1	Load Center	Room BT01			X	1961	25 Years	-34 Years	G.E. 120/208V 1 PH 3W	1	Ea.					x	No deficiency observed
	PP-11	Panelboard	Room BT01			X	1961	25 Years	-34 Years	G.E. 120/208V 3 PH 4W 400A	1	Ea.					x	No deficiency observed
	EL-B	Panelboard	Room B123	X			2014	25 Years	19 Years	Square D. 120/208V 3PH. 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-NN	Panelboard	Room B123	X			2014	25 Years	19 Years	Square D. 120/208V 3PH. 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-YY1	Panelboard	Room B127			X	1961?	25 Years	-34? Years	G.E. 120/208V 3 PH 4W 100A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	PNL-UP6	Panelboard	Room B127		X		2004?	25 Years	9? Years	Square D. 120/208V 3PH 4W 100A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	LP-ZZB	Panelboard			X		2004?	25 Years	9? Years	Square D. 120/208V 3PH. 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-ZZ	Panelboard	Room B150B	X			2004?	25 Years	9? Years	Square D. 120/208V 3PH. 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-ZZA	Panelboard	Room B150B	X			2004?	25 Years	9? Years	Square D. 120/208V 3PH. 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	GEN-B/S	Generator	Outdoor						20 Years	Kohler 200kW 480/277V.	1	Ea.					x	No deficiency observed
	LP-YY	Panelboard	room B127						25 Years		1	Ea.						
C WING																		
	PP-9	Panelboard	Room CT01	X			2015	25 Years	20 Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-QQ	Panelboard	Room CT01			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed
	EM-C	Panelboard	Room CT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed
	LP-UU	Panelboard	Room CT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 200A M.L.O.	1	Ea.					x	No deficiency observed
	EM-DP-C	Panelboard	Room CT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 70A. 3.P.M.C.B.	1	Ea.					x	No deficiency observed
	EL-DP-C	Panelboard	Room CT01	X			2015	25 Years	20 Years	Square D 120/208V 3PH 4W 70A. 3.P.M.C.B.	1	Ea.					x	No deficiency observed
	Subst C	Substation	Room CT01			X	1961	25 Years	-34 Years	G.E. 500KVA 120/208V	1	Ea.				x		
	ATS-EL-C	ATS	Room CT01	X			2015	25 Years	20 Years	Kohler 40A 120/208V	1	Ea.					x	No deficiency observed
	ATS-EM-C	ATS	Room CT01	X			2015	25 Years	20 Years	Kohler 70A 120/208V	1	Ea.					x	No deficiency observed
	LP-LL	Panelboard	Room C104			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	EL-C	Panelboard	Room C104	X			2015	25 Years	20 Years	Square D. 120/208V 3 PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	IG-LL	Panelboard	Room C106		X		1998	25 Years	3 Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-MM1 (1)	Panelboard	Room C115		X		1998	25 Years	3 Years	Square D. 120/208V 3 PH 4W	1	Ea.					x	No deficiency observed
	LP-MM1 (2)	Panelboard	Room C115		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	IG-MMI	Panelboard	Room C115		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	LP-MM2A	Panelboard	Room C128	X			2013±	25 Years	18± Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	LP-MM2 (1)	Panelboard	Room C128		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	LP-MM2 (2)	Panelboard	Room C128		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	IG-MM2 (1)	Panelboard	Room C128		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	IG-MM2 (2)	Panelboard	Room C128		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	T-EMC	Transformer	Room CT01	X			2014	25 Years	19 Years	Square D. 480-120/208V 30 KVA	1	Ea.					x	
	T-ELC	Transformer	Room CT01	X			2014	25 Years	19 Years	Square D. 480-120/208V 15 KVA	1	Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
D WING																		
	LP-BBB	Panelboard	Room DT02		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed
	PP-12	Panelboard	Room DT02		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 600A M.S.W.	1	Ea.					x	No deficiency observed
	EM-DP-D	Panelboard	Room DT02		X		1998	25 Years	3 Years	Square D. 480V, 3PH, 3W, 100A, M.L.O.	1	Ea.					x	No deficiency observed
	PP-11	Panelboard	Room DT02		X		1998	25 Years	3 Years	Square D. 120/208V 3PH, 4W, 1200A M.S.W	1	Ea.					x	No deficiency observed
	Subst- D	Substation	Room DT02		X		1998	25 Years	3 Years	Square D. 1000 KVA 480/277V	1	Ea.					x	No deficiency observed
	Gen-D	Generator	Room DT02						25 Years	Cummins 40 KW 480/277V	1	Ea.					x	No deficiency observed
	ATS-EM-D	ATS	Room DT02	X			2014	25 Years	19 Years	Cummins 70A 480/277V	1	Ea.					x	No deficiency observed
	ATS-EL-D	ATS	Room DT02	X			2014	25 Years	19 Years	Cummins 40A 480/277V	1	Ea.					x	No deficiency observed
	LP-CCC (2)	Panelboard	Room D154		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	LP-CCC (1)	Panelboard	Room D154		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	IG-CCC (2)	Panelboard	Room D154		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	IG-CCC (1)	Panelboard	Room D154		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	LP-EEE	Panelboard	Room D154		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	EM-D	Panelboard	Room D154	X			2014	25 Years	19 Years	Square D. 120/208V 3PH 4W 60A, M.C.B.	1	Ea.					x	No deficiency observed
	EL-D	Panelboard	Room D154	X			2014	25 Years	19 Years	Square D. 120/208V 3PH 4W 40A,3P, M.C.B.	1	Ea.					x	No deficiency observed
	PP-8ALP1	Panelboard	Room D137			X	1968	25 Years	-27 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	IG-A	Panelboard	Room D137		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	PP-8ALP2B	Load Center	Room D131			X	1968	25 Years	-27 Years	Square D.120/208V	1	Ea.					x	No deficiency observed
	PP-8ALP2A	Load Center	Room D131			X	1968	25 Years	-27 Years	Square D. 120/208V 1PH 3W	1	Ea.					x	No deficiency observed
	PP-8ALP2	Panelboard	Room D131			X	1968	25 Years	-27 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed
	PP-8A	Panelboard	Room D131			X	1968	25 Years	-27 Years	Square D. 120/208V 3PH 4W 400A M.L.O.	1	Ea.					x	No deficiency observed
	PP-8B	Panelboard	Room D201		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 400A M.L.O.	1	Ea.					x	No deficiency observed
	LP-TT	Panelboard	Room D103		X		1991	25 Years	-4 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	T12	Transformer	Room DT02		X		1998	25 Years	3 Years	Square D. 480-120/208V 300kVA	1	Ea.					x	No deficiency observed
	T-11	Transformer	Room DT02		X		1998	25 Years	3 Years	Square D. 480-120/208V 500kVA	1	Ea.					x	No deficiency observed
	LP-DD	Panelboard	Room D102		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A, M.L.O.	1	Ea.					x	No deficiency observed
	T-EMD	Transformer	Room DT02	X			2014	25 Years	19 Years	Square D. 480-120/208V 30 kVA	1	Ea.					x	No deficiency observed
	T-ELD	Transformer	Room DT02	X			2014	25 Years	19 Years	Square D. 480-120/208V 15 kVA	1	Ea.					x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
E WING																		
	LP-AA	Panelboard	Room ET01		X		1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	PP-8	Panelboard	Room ET01		X		2005±	25 Years	5± Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	Subst-E	Substation	Room ET01			X	1961	25 Years	-34 Years	G.E. 500KVA 120/208V	1	Ea.			x			
	IG-DD	Panelboard	Room E195A		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.				x	No deficiency observed	
	LP-BB	Panelboard	Room E104			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.			x		No deficiency observed	
	IG-EEE	Panelboard	Room E115		X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.			x		No deficiency observed	
	LP-EEE	Panelboard	Room E115			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.			x		No deficiency observed	
	LP-KK	Panelboard	Room E122			X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.			x		No deficiency observed
	IG-KK	Panelboard	Room E122			X		1998	25 Years	3 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.			x		No deficiency observed
F WING																		
	MCC	Panelboard	Room FT01		X		1976	25 Years	-19 Years	Square D. 480V. 3PH. 3W. 600A. M.L.O.	1	Ea.				x	No deficiency observed	
	EMDP	Panelboard	Room FT01		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 150A M.L.O.	1	Ea.			x		No deficiency observed	
	ELDP	Panelboard	Room FT01		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 100A 3P.M.C.B.	1	Ea.			x		No deficiency observed	
	GDP-EM	Panelboard	Room FT01		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 200A 3P.M.C.B.	1	Ea.			x		No deficiency observed	
	GDP-EL	Panelboard	Room FT01		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 100A 3P.M.C.B.	1	Ea.			x		No deficiency observed	
	Subst-F1	Substation	Room FT01			X	1977	25 Years	-18 Years	Square D. 480/277V 3PH 4W 1000KVA	1	Ea.			x		No deficiency observed	
	Subst-F2	Substation Assembly	Room FT01		X		2013	25 Years	18 Years	Square D. 120/208V 3PH. 4W. 1600A 3P M.C.B. V/A 500KVA Tx	1	Ea.			x		No deficiency observed	
	Gen-F	Generator	Outdoor		X		2013	20 Years	18 Years	Kohler 125KW 480/277V	1	Ea.			x		No deficiency observed	
	RP-E	Panelboard	Room F022			X	1976	25 Years	-19 Years	Square D 120/208V 3PH 4W 3P. 100A 3P. M.C.B.	1	Ea.			x		No deficiency observed	
	RP-D	Panelboard	Room F022			X	1976	25 Years	-19 Years	Square D 120/208V 3PH 4W 100A M.L.O.	1	Ea.			x		No deficiency observed	
	LP-A	Panelboard	Room F022		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 250A M.L.O.	1	Ea.			x		No deficiency observed	
	RP-M	Panelboard	Room F022		X		2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.			x		No deficiency observed	
	EM-FL	Panelboard	Room F022		X		2013	25 Years	18 Years	Square D. 120/277V 3PH 4W 100A 3P.M.C.B.	1	Ea.			x		No deficiency observed	
	EL-FL	Panelboard	Room F022		X		2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.			x		No deficiency observed	
	RP-K	Panelboard	Room F122		X		2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 400A M.L.O.	1	Ea.			x		No deficiency observed	
	LP-B	Panelboard	Room F122A		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 250A M.L.O.	1	Ea.			x		No deficiency observed	
	EL-F1	Panelboard	Room F122		X		2013	25 Years	18 Years	Square D. 480/277V 1PH 3W 125A M.L.O.	1	Ea.			x		No deficiency observed	
	RP-F	Panelboard	Room F122			X	1976	25 Years	-19 Years	Square D. 120/208V 3PH 4W 125A.3P. M.C.B.	1	Ea.			x		No deficiency observed	
	RP-G	Panelboard	Room F122			X	1976	25 Years	-19 Years	Square D 120/208V 3PH 4W 125A.3P. M.C.B.	1	Ea.			x		No deficiency observed	
	EM-F1	Panelboard	Room F122		X		2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.			x		No deficiency observed	
	LP-C	Panelboard	Room F266A		X		2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 250A M.L.O.	1	Ea.			x		No deficiency observed	
	EL-F2	Panelboard	Room F266A		X		2013	25 Years	18 Years	Square D. 480/277V 1PH 3W 125A M.L.O.	1	Ea.			x		No deficiency observed	
	ATS-EM	ATS	Room FT01		X		2013	25 Years	18 Years	Kohler 480/277V 150A.	1	Ea.			x		No deficiency observed	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
	ATS-EL	ATS	Room FT01	X			2013	25 Years	18 Years	Kohler 480/277V 70A.	1	Ea.					x	No deficiency observed
	RP-H	Panelboard	Room F266A		X		1976	25 Years	-19 Years	Square D. 120/208V 3PH 4W 200A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	RP-J	Panelboard	Room F266A		X		1976	25 Years	-19 Years	Square D. 120/208V 3PH 4W 200A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	EM-F2	Panelboard	Room F122	X			2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-L	Panelboard	Room F266A	X			2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	EL-FL	Panelboard	Room F021	X			2013	25 Years	18 Years	Square D. 480/277V 3PH 4W 125A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-K1	Panelboard	Room F195C	X			2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-L1	Panelboard	Room F267	X			2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 100A.	1	Ea.					x	No deficiency observed
	T-EM	Transformer	Room F022	X			2013	25 Years	18 Years	Square D. 480-12/208V 30 KVA	1	Ea.					x	No deficiency observed
G WING																		
	LP-ZA	Panelboard	Room G262		X		2009?	25 Years	14? Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-ZA1	Load Center	Room G161		X		2009?	25 Years	14? Years	Square D. 120/208V 3 PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-X	Panelboard	Room G160A	X			2005?	25 Years	10? Years	Square D. 120/208V 3 PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	PP-7A	Panelboard	Room G229	X			2017	25 Years	22 Years	Square D. 120/208V 3 PH 4W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-7A1	Panelboard	Room G229		X		1970	25 Years	-25 Years	Square D. 120/208V 3 PH 4W (Locked PNL Cover)	1	Ea.					x	No deficiency observed
	LP-7A2	Panelboard	Room G229		X		1970	25 Years	-25 Years	Square D. 120/208V 3 PH 4W (Locked PNL Cover)	1	Ea.					x	No deficiency observed
	EL-G	Panelboard	Room G229		X		1970	25 Years	-25 Years	Square D. 120/208V 3 PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
H WING																		
	LP-T1	Panelboard	Room H104		X		2005	25 Years	10 Years	Square D. 120/208V 3 PH 4W 200A. M.C.B.	1	Ea.					x	No deficiency observed
	LP-T2	Panelboard	Room H104		X		2005	25 Years	10 Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	EL-H	Panelboard	Room H102	X			2015	25 Years	20 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.					x	No deficiency observed
	EM-H	Panelboard	Room H102	X			2005	25 Years	20 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.					x	No deficiency observed
	Gen-H	Generator	Outdoor						20 Years	Kohler 350kW, 120/208V	1	Ea.					x	No deficiency observed
	PP-6	Panelboard	Room HT01		X		2005	25 Years	10 Years	Square D. 120/208V 3PH 4W 255A M.L.O.	1	Ea.					x	No deficiency observed
	PP-S	Panelboard	Room HT01			X	1961	25 Years	-34 Years	G. E. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	GDP-EL-H	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 300A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	GDP-EM-H	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 1200A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	EM-DP-H	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 800A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	PNL-H1	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 1200A.	1	Ea.					x	No deficiency observed
	PNL-H2	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 1200A.	1	Ea.					x	No deficiency observed
	EM-HH	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 100A.3P. M.C.B.	1	Ea.					x	No deficiency observed
	ELDP-H	Panelboard	Room HT01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 150A.3P. M.C.B.	1	Ea.					x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
	Subst-H	Substation	Room HT01			X	1961	25 Years	-34 Years	G.E. 500KVA 120/208V	1	Ea.				x		
	ATS-EM-H	ATS	Room HT01	X			2015	25 Years	20 Years	Kohler 120/208V., 800A,	1	Ea.				x		No deficiency observed
	ATS-EL-H	ATS	Room HT01	X			2015	25 Years	20 Years	Kohler 120/208V., 150A,	1	Ea.				x		No deficiency observed
J WING																		
	LP-NA1	Panelboard	Room J129	X			2005	25 Years	10 Years	Square D. 120/208V 3 PH 4W 200A. M.C.B.	1	Ea.				x		No deficiency observed
	LP-NA2	Panelboard	Room J129	X			2005	25 Years	10 Years	Square D. 120/208V 3 PH 4W 225A. M.C.B.	1	Ea.				x		No deficiency observed
	LP-R	Panelboard	Room J102	X			1997	25 Years	10+ Years	Square D 120/208V 3PH 4W M.L.O.	1	Ea.				x		No deficiency observed
	LP-W	Panelboard	Room J101	X			1997	25 Years	2 years	Square D 120/208V 3PH 4W M.L.O.	1	Ea.				x		No deficiency observed
	LP-N	Panelboard	Room J101	X			2005	25 Years	2 years	Square D 120/208V 3PH 4W 225A. M.L.O.	1	Ea.				x		No deficiency observed
	LP-N1	Panelboard	Room J101	X			2005	25 Years	10 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.				x		No deficiency observed
K WING																		
	LP-L	Panelboard	Room K110	X			1989	25 Years	-6 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.				x		No deficiency observed
	LP-LA	Panelboard	Room K110	X			1989	25 Years	-6 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.				x		No deficiency observed
	LP-K	Panelboard	Room K103			X	1961	25 Years	-34 Years	G.E. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.				x		No deficiency observed
	LP-BX	Panelboard	Room K103			X	1961	25 Years	-34 Years	G.E. 120/208V 3 PH 4W 100A.	1	Ea.				x		No deficiency observed
	LP-K1	Panelboard	Room K113			X	1961	25 Years	-34 Years	G.E. 120/208V 3 PH 4W 100A. M.L.O.	1	Ea.				x		No deficiency observed
	PP-5	Panelboard	Room KT01	X			2005	25 Years	10 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.				x		No deficiency observed
	LP-J	Panelboard	Room KT01			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.				x		No deficiency observed
	Subst-K	Substation	Room KT01			X	1961	25 Years	-34 Years	G.E. 500KVA 120/208V	1	Ea.				x		
L WING																		
	PP-IL-IA	Panelboard	Room L126	X			2003	25 Years	8 Years	Square D. 480/277V 30 4W 200A. 3P. M.C.B.	1	Ea.				x		No deficiency observed
	RP-IL-IMTB	Panelboard	Room L126	X			2003	25 Years	8 Years	Square D. 120/208V 30 4W 200A 3P. M.C.B.	1	Ea.				x		No deficiency observed
	RP-IL-IMTA	Panelboard	Room L126	X			2003	25 Years	8 Years	Square D. 120/208V 30 4W 200A 3P. M.C.B.	1	Ea.				x		No deficiency observed
	LP-IL-ILA	Panelboard	Room L195B	X			2003	25 Years	8 Years	Square D. 480/277V 30 4W 100A. 3P. M.C.B.	1	Ea.				x		No deficiency observed
	EL-L	Panelboard	Room L101	X			2006	25 Years	8 Years	Square D. 120/208V 3PH 4W 100A 3P. M.C.B.	1	Ea.				x		No deficiency observed
	EM-L	Panelboard	Room L101A	X			2016	25 Years	21 Years	Square D. 120/208V 3PH 4W 600A.	1	Ea.				x		No deficiency observed
	LP-B	Panelboard	Room L101			X	2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 225A 3P. M.L.O.	1	Ea.				x		No deficiency observed
	RP-IL-IRC	Panelboard	Room L108			X	2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 100A 3P. M.C.B.	1	Ea.				x		No deficiency observed
	PP-PT	Panelboard	Room L130A	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W, 400A MCB	1	Ea.				x		No deficiency observed
	RP-PT	Panelboard	Room L130A	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.				x		No deficiency observed
	RP-ILM-IWA	Panelboard	Room L140	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.				x		No deficiency observed
	PDP-ILM-IW	Panelboard	Room L140	X			2003	25 Years	8 Years	Square D. 480/277V, 3PH 4W	1	Ea.				x		No deficiency observed
	MCC-PT	Motor Control Center	Room L130A	X			2003	25 Years	8 Years	Square D. 480V, 3ph, 3W	1	Ea.				x		No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
	MCC-C	Panelboard	Room LT01	X			2004	25 Years	9 Years	Square D. 208V 3PH 3W, 400A, MLO	1	Ea.					x	No deficiency observed
	LP-A	Panelboard	Room LT01			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	PP-4	Panelboard	Room LT01			X	1961	25 Years	-34 Years	G.E. 240 3PH 3W 400A M.L.O.	1	Ea.					x	No deficiency observed
	LP-H7	Lead Center	Room LT01	X			2004	25 Years	9 Years	Square D. 120/208V M.L.O.	1	Ea.					x	No deficiency observed
	LP-H	Panelboard	Room LT01			X	1961	25 Years	-34 Years	G.E. 120/208V 3PH 4W 800A M.L.O.	1	Ea.					x	No deficiency observed
	Subst-L	Substation	Room LT01			X	1961	25 Years	-34 Years	G.E. 500KVA 120/208V	1	Ea.			x			
	ATS-EL-L	ATS	Room LT01	X			2016	25 Years	21 Years	Kohler	1	Ea.					x	No deficiency observed
	ATS-EL-M	ATS	Room LT01	X			2016	25 Years	21 Years	Kohler	1	Ea.					x	No deficiency observed
	RP-IL-IR	Panelboard	Room L125	X			2017	25 Years	22 Years	Square D. 120/208V 3PH 4W 800A 3P, M.C.B.	1	Ea.					x	No deficiency observed
	PDP-IL-IA	Panelboard	Room L125	X			2017	25 Years	22 Years	Square D. 480/277V 3PH 4W 600A 3P, M.C.B.	1	Ea.					x	No deficiency observed
	PP-IL-IB	Panelboard	Room L125	X			2017	25 Years	22 Years	Square D. 480/277V 3PH 4W 250A M.L.O.	1	Ea.					x	No deficiency observed
	RP-IL-IRE	Panelboard	Room L125	X			2017	25 Years	22 Years	Square D. 120/208V 3PH 4W 225A M.L.O.	1	Ea.					x	No deficiency observed
	T-IIIR	Transformer	L125	X			2017	25 Years	22 Years	Square D. 480-120/208V 225 KVA	1	Ea.					x	No deficiency observed
	T-PT	Transformer	L130		X		2003	25 Years	8 Years	Square D. 480-120/208V 30 KVA	1	Ea.					x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
M WING																		
	SUBST.-M	Substation	Room M202	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W 3000A Main 1500kVA	1	Ea.					x	No deficiency observed
	MCC-A	Motor Control Center	Room M202	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	RDP-1M	Panelboard	Room M202	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 2000A Main MSW	1	Ea.					x	No deficiency observed
	PP-M	Panelboard	Room M162	X			2003	25 Years	8 Years	Square D. 480V, 3ph, 3W, 400A MCB	1	Ea.					x	No deficiency observed
	DP-M	Panelboard	Room M162	X			2003	25 Years	8 Years	Square D. 120/208V, 3ph, 4W 100A MCB	1	Ea.					x	No deficiency observed
	RP-M	Panelboard	Room M162	X			2003	25 Years	8 Years	Square D. 120/208V, 3ph, 4W 200A	1	Ea.					x	No deficiency observed
	PDP-IM-ICT	Panelboard	Room M150B	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W 400A.	1	Ea.					x	No deficiency observed
	PDP-IM-ICLT1	Panelboard	Room M150B	X			2003	25 Years	8 Years	Square D. 480/277V, 3ph, 4W, 100A MLO	1	Ea.					x	No deficiency observed
	RP-IM-ICTB	Panelboard	Room M150B	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 100A MCB	1	Ea.					x	No deficiency observed
	RP-IM-ICB	Panelboard	Room M150B	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 100A. MCB	1	Ea.					x	No deficiency observed
	LP-IM-ILB	Panelboard	Room M150B	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W 100A. MCB	1	Ea.					x	No deficiency observed
	RP-IM-ICTA	Panelboard	Room M150A	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 200A. MCB	1	Ea.					x	No deficiency observed
	RP-IM-ICTA-I	Panelboard	Room M150D	X			2003	25 Years	8 Years	Square D. 120/208V, 3ph, 4W 200A	1	Ea.					x	No deficiency observed
	RP-IM-ISLC	Panelboard	Room M115	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	RP-IM-ISLD	Panelboard	Room M115	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	RP-IM-ISLB	Panelboard	Room M110	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	RP-IM-ISLA	Panelboard	Room M110	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W	1	Ea.					x	No deficiency observed
	RP-IM-2REF	Panelboard	Room M145	X			2003	25 Years	8 Years	Square D. 120/208V	1	Ea.					x	No deficiency observed
	RP-IM-1REF	Panelboard	Room M145	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-IM-2HVA	Panelboard	Room M140	X			2003	25 Years	8 Years	Square D. 120/208V	1	Ea.					x	No deficiency observed
	RP-IM-1HVA	Panelboard	Room M140	X			2003	25 Years	8 Years	Square D. 120/208V 3 PH 4W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	EL-MA	Panelboard	Room M140	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W, 100A	1	Ea.					x	No deficiency observed
	LP-IM-ILA	Panelboard	Room M140	X			2003	25 Years	8 Years	Square D. 480/277V 3PH 4W 100A.	1	Ea.					x	No deficiency observed
	RP-IM-ICA	Panelboard	Room M140	X			2003	25 Years	8 Years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-H81	Load Center	Room M102	X			2003	25 Years	8 Years	Square D. 120/208V 3ph, 4W	1	Ea.					x	No deficiency observed
	LP-H8	Panelboard	Room M102	X			2003	25 Years	8 Years	Square D 120/208V 3ph, 4W, MCB	1	Ea.					x	No deficiency observed
	EL-MA	Panelboard	Room M102	X			2003	25 Years	8 Years	Square D. 120/208V	1	Ea.					x	No deficiency observed
	PP-1	Panelboard	Room M106	X			2003	25 Years	8 Years	Square D. - Panel cover not secure	1	Ea.		x				
	T-IM	Transformer	M202	X			2003	25 Years	8 Years	Square D. 480-120/208V 500 KVA	1	Ea.					x	No deficiency observed
	T-RPM	Transformer	M162	X			2003	25 Years	8 Years	Square D. 480/120/208V 30 KVA	1	Ea.					x	No deficiency observed
	T-DPM	Transformer	M162	X			2003	25 Years	8 Years	Square D. 480-120/208V 75 KVA	1	Ea.					x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category	
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5		
N WING																	
	LP-FA	Load Center	Room N300	X			2004?	25 Years	9 Years	Square D. 120/208V. 3PH 4W		1	Ea.			x	No deficiency observed
	LP-F	Panelboard	Room N300	X			2004?	25 Years	9 Years	Square D. 120/208V. 3PH 4W 200A. 3P. M.C.B. Panel has exposed bus		1	Ea.			x	No deficiency observed
	MCC-B	Panelboard	Room N300	X			2004?	25 Years	9 Years	Square D. 120/208V. 3PH 3W 800A. M.L.O.		1	Ea.			x	No deficiency observed
	LP-NLLI-I	Load Center	Room N200		X		1961	25 Years	-34 Years	G.E. 120/208V.		1	Ea.			x	No deficiency observed
	LP-NLLI	Panelboard	Room N203	X			2004?	25 Years	9? Years	Square D. 120/208V. 3PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-FA3	Load Center	Room N202	X			1980?	25 Years	15? Years	Square D. 120/208V. 3PH 4W 50A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-FA4	Load Center	Room N204	X			1980?	25 Years	15? Years	Square D. 120/208V. 3PH 4W 50A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-FA1	Load Center	Room N206	X			1980?	25 Years	15? Years	Square D. 120/208V. 3PH 4W 50A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-FA2	Load Center	Room N208	X			1980	25 Years	-15 Years	Square D. 120/208V. 3PH 4W MCB		1	Ea.			x	No deficiency observed
	RP-NG1	Panelboard	Room N118	X			1980	25 Years	-15 Years	Square D. 120/208V. 3PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NL1	Panelboard	Room N112	X			2005	25 Years	10 Years	Square D. 120/208V 3 PH 4W 3P. 200A. M.C.B.		1	Ea.			x	No deficiency observed
	LP-H7A	Load Center	Room N107	x			1990	25 Years	-5 Years	Square D. 120/208V 3Ph. 4W		1	Ea.			x	No deficiency observed
	RP-NPTI	Panelboard	Room N040B	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NKI	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NK2	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NK3	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NK4	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NK5	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 400A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-NKI	Panelboard	Room N036	X			2004?	25 Years	9? Years	Square D. 480/277V		1	Ea.			x	No deficiency observed
	RP-NCI	Panelboard	Room N010	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	RP-NC2	Panelboard	Room N010	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-NC2	Panelboard	Room N002	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed
	LP-NC1	Panelboard	Room N002	X			2004?	25 Years	9? Years	Square D. 120/208V 3 PH 4W 200A. 3P. M.C.B.		1	Ea.			x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor					Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
P WING																
	Subst-P	Substation	Room P020		X		1979	25 Years	-16 Years	Square D. 480/277V 750KVA 1200A - Corrosion	1	Ea.		x		Atmospheric corrosion
	EMPP-P	Panelboard	Room P020	X			2013	25 Years	18 Years	Square D. 480/277V 3 PH 4W 150A. 3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	EMRP-P	Panelboard	Room P020	X			2013	25 Years	18 Years	Square D. 120/208V 3PH 4W 60A.3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	LP-PP1	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 480/277V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	EL-P, aka LP-EM	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 480/277V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	RP-PP1	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	RP-PP4	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.		x		Atmospheric corrosion
	MCC-A	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 480V 800A. M.L.O.	1	Ea.		x		Atmospheric corrosion
	RP-PPT1	Panelboard	Room P040		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PPS1	Panelboard	Room P016		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PCS1	Panelboard	Room P015		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PDG1	Panelboard	Room P212		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	LP-PDG1	Panelboard	Room P212		X		2004?	25 Years	97 Years	Square D. 480/277V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PFC1	Panelboard	Room P111		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PFC2	Panelboard	Room P111		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PP2	Panelboard	Room P136		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	LP-PP2	Panelboard	Room P136		X		2004?	25 Years	97 Years	Square D. 480/277V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PP3	Panelboard	Room P136		X		2004?	25 Years	97 Years	Square D. 120/208V 3 PH 4W 100A. 3P. M.C.B.	1	Ea.			x	No deficiency observed
	RP-PTE1	Panelboard	Room 124		X		2004?	25 Years	97 Years	Square D. 120/208V 3PH 4W 100A.3P. M.C.B.	1	Ea.			x	No deficiency observed
	PP-PD1	Panelboard	Room P106		X		2000	25 Years	5 years	Square D. 480V, 3PH, 3W	1	Ea.			x	No deficiency observed
	ATS-EM	ATS	Room P020	X			2013	25 Years	18 Years	Kohler 150A 480/277V.	1	Ea.			x	No deficiency observed
	LP-EM	Panelboard	Room P020		X		2004?	25 Years	97 Years	Square D. 480/277V 3 PH 4W 100A.	1	Ea.			x	No deficiency observed
	ATS-EL	ATS	Room P020	X			2013	25 Years	18 Years	Kohler 70A 480/277V.	1	Ea.			x	No deficiency observed
	RP-PDG1A	Panelboard	RM	X			2018	25 Years	23 Years	Square D. 120/208V 3 PH 4W 225A. M.L.O.	1	Ea.			x	No deficiency observed
	T-PDG1	Transformer	Room P212		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PP2	Transformer	Room P136		X		2004?	25 Years	9 Years	Square D. 480-120/208V 30 KVA	1	Ea.			x	No deficiency observed
	T-PP3	Transformer	Room P136		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PPI	Transformer	Room P020		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PCFI	Transformer	Room P111		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PCSI	Transformer	Room P015		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PPS1	Transformer	Room P027		X		2004?	25 Years	9 Years	Square D. 480-120/208V 30 KVA	1	Ea.			x	No deficiency observed
	T-PTE1	Transformer	Room P124		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PP4	Transformer	Room P020		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-PPT1	Transformer	Room P420		X		2004?	25 Years	9 Years	Square D. 480-120/208V 45 KVA	1	Ea.			x	No deficiency observed
	T-EMRPP	Transformer			X		2013	25 Years	18 Years	Square D. 480-120/208V 15 KVA	1	Ea.			x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
S WING																		
	RP-8	Panelboard	Room ST01		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed
	EM-S	Panelboard	Room ST01	X			2015	25 Years	20 Years	Square D. 120/208V 3PH 4W 40A.3P M.C.B.	1	Ea.					x	No deficiency observed
	EM-DR-S	Panelboard	Room ST01	X			2015	25 Years	20 Years	Square D. 480/277V 3PH 4W 150A.3P M.C.B.	1	Ea.					x	No deficiency observed
	PNL-SCL	Panelboard	Room ST01	X			2008	25 Years	13 Years	Square D. 480/277V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	DP-2	Panelboard	Room ST01			X	1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 600A. M.L.O.	1	Ea.					x	No deficiency observed
	DP-1	Panelboard	Room ST01		X		1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 600A. M.L.O.	1	Ea.					x	No deficiency observed
	FPCP	Fire Pump Control PNL	Room ST01			X	1971	25 Years	-24 Years	Old Worn Condition/Does not have required working clearance	1	Ea.	x					
	Subst-S	Substation	Room ST01		X		1971	25 Years	-24 Years	Square D. 1000KVA 480/277V	1	Ea.					x	No deficiency observed
	ATS-EL-S	ATS	Room ST01	X			2015	25 Years	20 Years	Kohler 150A. 480/277V.	1	Ea.					x	No deficiency observed
	ATS-EM-S	ATS	Room ST01	X			2015	25 Years	20 Years	Kohler 150A. 480/277V.	1	Ea.					x	No deficiency observed
	RP-4	Panelboard	Room S230		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	DP-6	Panelboard	Room S230		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 400A M.L.O.	1	Ea.					x	No deficiency observed
	LP-6	Panelboard	Room S230			X	1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A M.L.O.-Panel does not have required working clearance	1	Ea.	x					
	EL-S	Panelboard	Room S022	X			2015	25 Years	20 Years	Square D. 480/277V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	DP-4	Panelboard	Room S022			X	1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 600A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-1	Panelboard	Room S053		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A.3P M.C.B.	1	Ea.					x	No deficiency observed
	LP-7	Panelboard	Room S259		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A.3P M.C.B.	1	Ea.					x	No deficiency observed
	DP-3	Panelboard	Room S022		X		1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 600A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-3	Panelboard	Room S022		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-3A	Load Center	Room S022		X		1971	25 Years	-24 Years	Square D. 120/208V 3ph, 4W	1	Ea.					x	No deficiency observed
	LP-1	Panelboard	Room S110		X		1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-4	Panelboard	Room S110		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-1S-1FA	Panelboard	Room S110	X			2004?	25 Years	9? Years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	No deficiency observed
	DP-5	Panelboard	Room S136			X	1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 600A M.L.O.	1	Ea.					x	No deficiency observed
	LP-2	Panelboard	Room S136		X		1971	25 Years	-24 Years	Square D. 480/277V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	LP-5	Panelboard	Room S136		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	RP-2	Panelboard	Room S136		X		1971	25 Years	-24 Years	Square D. 120/208V 3PH 4W 100A M.L.O.	1	Ea.					x	No deficiency observed

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Z WING																		
	PP-14-LP-1	Panelboard	Room ZT01		X		1996	25 Years	1 Years	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	No deficiency observed
	MCC-BR	Panelboard	Room ZT01		X		1996	25 Years	1 Years	Square D. 480V 3PH 3W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	MCC-PH	Panelboard	Room ZT01		X		1996	25 Years	1 Years	Square D. 480V 3PH 3W 400A. M.L.O.	1	Ea.					x	No deficiency observed
	PRIM.SWS	Primary	Room Z110		X		1965, 1974 & 2012	25 Years	-30, -19, -8 Years	Combination GE and Square D.	1	Lot				x		
	Chiller Subst (N)	Substation	Room Z102		X		1993	25 Years	-2 Years	Square D. 2500/3000KVA 480V 3PH 3W, 4000A	1	Ea.				x	No deficiency observed	
	Chiller Subst (S)	Substation	Room Z102		X		2012	25 Years	17 Years	Square D. 3000KVA. 480V. 4000A.	1	Ea.				x	No deficiency observed	
	LPA-1	Panelboard	Room Z103		X		1990	25 Years	-5 years	Square D. 120/208V 3PH 4W 150A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	LPA-1-A	Load Center	Room Z101		X		1990	25 Years	-5 years	Square D. 120/280V	1	Ea.				x	No deficiency observed	
	PP-12-LP-2	Panelboard	Room Z106		X		1990	25 Years	-5 years	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.				x	No deficiency observed	
	PP-11	Panelboard	Room Z109		X		2007	25 Years	12 Years	Square D. 480V 3PH 600A. M.L.O.	1	Ea.				x	No deficiency observed	
	PP-12	Panelboard	Room Z109		X		2007	25 Years	12 Years	Square D. 120/208V 3PH 4W 200A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	Parking PNL	Panelboard	Room Z109			X	1986	25 Years	-9 Years	Control panel	1	Ea.				x		
	EL-Z	Panelboard	Room Z109		X		1986	25 Years	-9 Years	Square D. 120/208V 3PH 4W 50A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	ATS	ATS	Room Z109		X		1986	25 Years	-9 Years	Kohler	1	Ea.				x	No deficiency observed	
	ATS	ATS	Room Z109		X		1986	25 Years	-9 Years	Kohler	1	Ea.				x	No deficiency observed	
	Gen-Z	Generator	Outdoor		X		1986	25 Years	-9 Years	Kohler	1	Ea.				x		
	ELDP-Z	Panelboard	Room Z109		X		1986	25 Years	-9 Years	Square D. 480/277V 3PH 4W 100A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	EM-Z	Panelboard	Room Z109		X		1986	25 Years	-9 Years	Square D. 120/208V 3PH 4W 50A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	EMDP-Z	Panelboard	Room Z109		X		1986	25 Years	-9 Years	Square D. 480V 3PH 3W 200A. 3P. M.C.B.	1	Ea.				x	No deficiency observed	
	Sub-CG	Substation	Room Z11			X	1986	25 Years	-9 Years	Square D. 750KVA 8320-480V	1	Ea.				x	No deficiency observed	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Main Campus	
Building Area: 899,682 SF	
No. of Floors: 3	
Year Built: 1961	
Year Renovated: Various -- see A001, A002 and A003	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities									
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety	Priority 2	Potential Critical: Problem Avoidance	Priority 3	Necessary - Not Yet Critical: Predictable deterioration	Priority 4	Recommended: Sensible or program oriented	Priority 5	Grandfathered or no immediate action required

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>LIGHTING FIXTURES</b>																		
A Wing		Fluorescent Fixtures with LED Lamps	Offices		X		2005	25 Years	10 Years	Closets A201 and A215 do not have occupancy control	40,008	SF			x			
A Wing		LED	TV Studio area and tunnels	X			2015	25 Years	20 Years		9,664	SF				x		
A Wing		Fluorescent Fixtures with LED Lamps	Corridors/General			X	1961	25 Years	-24 Years		40,250	SF		x				
A Wing		Fluorescent Fixtures with LED Lamps	Library/Classrooms		X		1999/1997	25 Years	4/2 Years		63,500	SF		x				
B Wing		Fluorescent Fixtures with LED Lamps	East Area		X		2005s	25 years	10± Years		11,730	SF		x				
B Wing		LED	West Area	X			2015s	25 Years	20± Years		13,770	SF		x				
C Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		1997	25 Years	2 Years		39,800	SF		x				
D Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		2005	25 Years	10 Years		40,300	SF		x				
E Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		1997	25 Years	2 Years		28,400	SF	x					
F Wing		Fluorescent Fixtures with LED Lamps	Throughout with Exceptions	X			2015	25 Years	20 Years		82,379	SF		x				
F Wing		LED	Core/Lobby	X			2015	25 Years	20 Years		11,021	SF		x				
G Wing		Fluorescent Fixtures with LED Lamps	Throughout			X	1970/1997	25 Years	-25/12 Years		20,700	SF		x				
H Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		2005	25 Years	10 Years	Outdoor Canopy fixture filled with dead moths	11,630	SF		x				
J Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		2005	25 Years	10 Years	Outdoor Canopy fixture filled with dead moths	27,150	SF	x					
K Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		1997	25 Years	2 Years		16,250	SF		x				
L Wing		Fluorescent Fixtures with LED Lamps	North & East Areas		X		2003	25 Years	8 Years		27,238	SF		x				
L Wing		LED	South Area	X			2016	25 Years	21 Years		7,862	SF		x				
M Wing		Fluorescent Fixtures with LED Lamps	Southeast Area/Misc.			X	2005s	25 Years	-4/10± Years		40,179	SF	x	x				
M Wing		LED	Throughout with Exceptions	X			2015	25 Years	20 Years		30,621	SF		x				
N Wing		Fluorescent Fixtures with LED Lamps	Throughout		X		1997±	25 Years	2± Years	Rooms N130 and N140 do not have occupancy control	111,220	SF	x					
N Wing		LED	Vestibules/Dining	X			2013	25 Years	18 Years		14,880	SF		x				
P Wing		Fluorescent Fixtures with LED Lamps	Majority of Area		X		2004±	25 Years	9± Years	Room P109 Lighting inoperable	150,566	SF		x				
P Wing		LED	Majority of Area	X			2018	25 Years	23 Years		25,534	SF		x				
S Wing		Fluorescent Fixtures with LED Lamps	Majority of Wing			X	1972	25 Years	-22 Years		76900	SF	x					
S Wing		INCAND.	Atrium			X	1972±	25 Years	-22 Years		2700	SF	x					
Z Wing		Fluorescent Fixtures with LED Lamps	Throughout			X	1972±	25 Years	-22 Years		14100	SF	x					
Tunnel		LED	Tunnels	X			2015±	25 Years	20 Years		16,000	SF		x				
Site		LED	Throughout	X			Varies		15 years	LED throughout with some exceptions	1	Lot		x				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Service Buildings			
Building Area: Transmitter 1 1,025 SF, Transmitter 2 860 SF, Water Meter Building 408 SF			
No. of Floors: 1			
Year Built: Transmitter 1 1981, Transmitter 2 1984, Water Meter Building 2004			
Year Renovated:			
Evaluated: First Quarter 2020			

Condition		
State	Condition Description	
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.	
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.	
Poor	Needs major repair or replacement.	

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining Service Life (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>ROOFING</b>																		
Transmitter #1		Grass and concrete		X								Ea.						
<b>EXTERIOR</b>																		
Transmitter #1												Ea.						
		Walls (Concrete)			X						Some staining.	Ea.				x		
		Doors		X								Ea.				x		
<b>INTERIOR</b>																		
Transmitter #1		Overall										Ea.						
		Ceilings (Exposed)		X						No apparent leaking.		Ea.				x		
		Floors (Exposed)		X								Ea.				x		
		Walls		X								Ea.				x		
		Doors		X								Ea.				x		
		Windows		X								Ea.				x		
		Janitor Closets										Ea.						
		Ceilings (Painted)		X						No apparent leaking.		Ea.				x		
		Floors (Exposed)		X								Ea.				x		
		Walls		X								Ea.				x		
		Doors				X				Door requires to be replaced.		Ea.		x				
<b>SITE</b>																		
Transmitter #1		Concrete			X							Ea.				x		
		Asphalt			X							Ea.				x		
		Landscaping		X								Ea.				x		
<b>ROOFING</b>																		
Transmitter #2		Shingles			X					Visual inspection only.		Ea.				x		
<b>EXTERIOR</b>																		
Transmitter #2		Walls (Concrete and wood)			X							Ea.				x		
		Doors (H.M.)s				X				Rusting at the top and bottom of the door.		Ea.			x			
		Rolling Shutter Doors		X								Ea.			x			
		Louvers (metal)		X								Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Service Buildings	
Building Area: Transmitter 1 1,025 SF, Transmitter 2 860 SF, Water Meter Building 408 SF	
No. of Floors: 1	
Year Built: Transmitter 1 1981, Transmitter 2 1984, Water Meter Building 2004	
Year Renovated:	
Evaluated: First Quarter 2020	

Condition		
State	Condition Description	
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.	
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.	
Poor	Major repair or replacement required.	

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>INTERIOR</b>																		
Transmitter #2																		
	Overall												Ea.					
	Ceilings (Exposed Timber)			X						No apparent leaking.			Ea.					x
	Floors (Exposed Concrete)				X					Rust stains and crackings in the floor			Ea.			x		
	Walls (Concrete)			X						Pitted Concrete on walls.			Ea.		x			
	Janitor Closets												Ea.					
	Ceilings (Exposed Timber)			X						No apparent leaking.			Ea.			x		
	Floors (Exposed)			X									Ea.			x		
	Walls				X					Different color paint patches. Paint.			Ea.		x			
	Doors (H.M.)			X									Ea.			x		
<b>SITE</b>																		
Transmitter #2	Concrete			X									Ea.					x
	Asphalt			X									Ea.			x		
	Landscaping			X									Ea.			x		
<b>EXTERIOR</b>																		
Water Tower													Ea.					
	Water Steel Tower			X									Ea.			x		
<b>SITE UTILITIES</b>																		
Site Utilities													Ea.		x			
	Asphalt					X				Crackings in Asphalt.			Ea.			x		
	Gravel/ Landscaping			X									Ea.			x		
<b>EXHAUST EQUIPMENT</b>																		
Transmitter #2	EF-1	Wall Mounted		1st Floor - High Wall		X			20		Inaccessible. Appears older.		1	Ea.		x		
													1	Ea.				
<b>UNIT HEATERS (UH)</b>																		
Transmitter #1	UH-1	Unit Heater	1st Floor	X			Unknown	20		Emerson. Electric. 460V, 3 Ph.		1	Ea.		x			
Transmitter #2	UH-2	Unit Heater	1st Floor					20				1	Ea.		x			
												1	Ea.					

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Service Buildings	
Building Area: Transmitter 1 1,025 SF, Transmitter 2 860 SF, Water Meter Building 408 SF	
No. of Floors: 1	
Year Built: Transmitter 1 1981, Transmitter 2 1984, Water Meter Building 2004	
Year Renovated:	
Evaluated: First Quarter 2020	

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	1

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>SPLIT SYSTEMS:</b>																		
													1	Ea.				
Transmitter #1	ACCU-1	Condesning Unit	1st Floor		X		Unkown	20		Trane. 2 HP, 460V, 3 Ph. Appears older.	1	Ea.				x		
													1	Ea.				
<b>DOMESTIC WATER HEATING EQUIPMENT</b>																		
Transmitter #1	DWH-1	Domestic hot water tank - Serves Toilet Room	1st Floor		X		1981	20	-19	State. Electric. 6 gal. 120V, 1 Ph. Based on serialnumber assumed 1981.	1	Ea.				x		
													1	Ea.				
<b>PLUMBING FIXTURES</b>																		
Transmitter #1	WC	Water Closet	Toilet Room		X					Floor mounted	1	Ea.				x		
Transmitter #2	WC	Water Closet	Toilet Room			X				Floor mounted	1	Ea.			x			
Transmitter #1	LAV.	Lavatory	Toilet Room		X					Wall Mounted. Single faucet/single handle	1	Ea.			x			
Transmitter #2	LAV.	Lavatory	Toilet Room			X				Wall Mounted. Single faucet/dual handle	1	Ea.			x			\$ - \$
<b>POWER AND DISTRIBUTION SYSTEM</b>																		
Transmitter #1	MDP	Panelboard	North Wall		X		1981	25 Years	-14 Years	Square D. 480V 800A. M.S.W.	1	Ea.				x		
Transmitter #1	RP-A	Panelboard	North Wall			X	1981	25 Years	-14 Years	Square D. 120/208V 3PH 4W Panel does not have required working clearance.	1	Ea.	x					
Transmitter #1	LC-A	Load Center	North Wall		X		1981	25 Years	-14 Years	Square D. 120/208V 70A. 2P. M.C.B.	1	Ea.			x			
Transmitter #1	T-A	Transformer	North Wall		X		1981	25 Years	-14 Years	Square D. 480V-120/208V, 30kVA	1	Ea.			x			
Transmitter #1	T-1	Transformer	Outdoor		X		1981	25 Years	-14 Years	480/277V, 500 kva	1	Ea.			x			
Transmitter #2	T-2	Transformer	Outdoor			X	1984	25 Years	-31 Years	120/208, 225 kva	1	Ea.			x			
Transmitter #2	P.S.	Primary Swich	Outdoor			X	1984	25 Years	-31 Years	8320V	1	Ea.			x			
											1	Ea.			#REF!	#REF!		
<b>LIGHTING FIXTURES</b>																		
Transmitter #1	Fluorescent	Interior			X		1981	25 Years	-14 Years		1025	SF			x			
Transmitter #2	H.I.D.	Exterior			X		1981	25 Years	-14 Years		860	SF			x			
<b>FIRE ALARM</b>																		
Transmitter #1	Notification / Initiation	Throughout			X		11981	15 Years	-24 Years		1025	SF			x			
Transmitter #2	Notification / Initiation	Throughout			X		1981	15 Years	-24 Years		860	SF			x			
																	\$ - \$	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Grounds Buildings	
Building Area: Grounds Maintenance - 8,400 SF, Grounds Maintenance Storage Bldgs - 1,792, 4,224, 2,772 SF	
No. of Floors: 1	
Year Built: Grounds Maintenance - 1968, Grounds Maintenance Storage Bldgs - 1984, 2009, 2009	
Year Renovated:	
Evaluated: First Quarter 2020	

Condition		
State	Condition Description	
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.	
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.	
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.	

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining Service Life (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>ROOFING</b>																		
Maintenance Building		Metal Roof		X								Ea.					x	
<b>EXTERIOR</b>																		
Maintenance Building		Walls (Metal siding with CMU base)		X								Ea.					x	
		Doors				X					Door frames are corroding at the bottom. Paint.	7	Ea.		x			
		Garage Doors		X								Ea.					x	
		Windows				X					Non-insulated glass does not meet current energy code.	Ea.			x			
		Metal louvers		X								Ea.					x	
<b>INTERIORS</b>																		
Maintenance Building																		
		Overall										Ea.						
		Ceilings (Exposed Steel Structure)		X							Insulation on the under side of ceiling.	Ea.			x			
		Floors (Exposed Concrete)		X								Ea.			x			
		Walls		X							Insulation on the face of wall.	Ea.			x			
		Doors				X					Door frames are corroding at the bottom. Paint.	4	Ea.	x				
		Windows				X					Non-insulated glass does not meet current energy code.	Ea.			x			
		Kitchenette/ Office										Ea.						
		Ceilings (Act 2 x 2)		X								Ea.			x			
		Floors (Exposed)		X								Ea.			x			
		Walls		X								Ea.			x			
		Doors		X								1	Ea.		x			
		Windows		X								Ea.			x			
		Millwork		X								Ea.			x			
		Toilet Rooms										Ea.						
		Ceilings (Act 2 x 2)		X								Ea.			x			
		Floors (Exposed)		X								Ea.			x			
		Walls		X								Ea.			x			
		Doors		X								2	Ea.		x			
		Janitor Closets										Ea.						
		Ceilings (Exposed)				X					Insulation on the ducts not sealed properly.	Ea.		x				
		Floors (Exposed)		X								Ea.			x			
		Walls		X								Ea.			x			
		Doors		X								1	Ea.		x			
		Windows				X					Non-insulated glass does not meet current energy code.	Ea.			x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Grounds Buildings
Building Area: Grounds Maintenance - 8,400 SF, Grounds Maintenance Storage Bldgs - 1,792, 4,224, 2,772 SF
No. of Floors: 1
Year Built: Grounds Maintenance - 1968, Grounds Maintenance Storage Bldgs - 1984, 2009, 2009
Year Renovated:
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining Service Life (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Maintenance Building		N / A										Ea.						
<b>ACCESSIBILITY/ADA</b>																		
Maintenance Building		Meets ADA										Ea.						
<b>SITE</b>																		
Maintenance Building		Concrete			X					Cracked and/or pitted concrete.		Ea.			x			
Maintenance Building		Asphalt				X				Crackings in asphalt.		Ea.			x			
<b>INTERIORS</b>																		
Maintenance Storage Building																		
		Overall										Ea.						
		Ceilings (Exposed Timber and Metal)		X						Insulation on the under side of ceiling.		Ea.			x			
		Floors (Exposed Concrete)			X					Crackings and pitted concrete		Ea.			x			
		Walls		X						Insulation on the face of wall.		Ea.			x			
		Doors			X					Door frames are corroding at the bottom. Paint.		Ea.			x			
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Maintenance Storage Building		N / A										Ea.						
<b>ACCESSIBILITY/ADA</b>																		
Maintenance Storage Building		Meets ADA										Ea.						
<b>SITE</b>																		
Maintenance Storage Building		Concrete			X					Cracked and/or pitted concrete.		Ea.			x			
Maintenance Storage Building		Asphalt				X				Cracking and surface indentation,		Ea.			x			
Maintenance Storage Building		Gravel		X								Ea.			x			
<b>EXHAUST EQUIPMENT</b>																		
Maintenance Building	EF-3	Exhaust Fan	Roof				20		208V		1	Ea.			x			
Maintenance Building	EF-4	Exhaust Fan	Roof				20		208V		1	Ea.			x			
Maintenance Building	EF-5	Exhaust Fan	Roof				20		208V						x			
									208V									

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Grounds Buildings									
Building Area: Grounds Maintenance - 8,400 SF, Grounds Maintenance Storage Bldgs - 1,792, 4,224, 2,772 SF									
No. of Floors: 1									
Year Built: Grounds Maintenance - 1968, Grounds Maintenance Storage Bldgs - 1984, 2009, 2009									
Year Renovated:									
Evaluated: First Quarter 2020									

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority	Description
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining Service Life (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>UNIT HEATERS (UH)</b>																		
Maintenance Building	UH-1	Unit Heater	1st Floor	X			Assume 2014	20	14	Trane. Electric heat. 101,250 BTU/hr output. 120V, 1 Ph. Based on serial number assumed 2014.	1	Ea.					x	
Maintenance Building	UH-2	Unit Heater	1st Floor	X			Assume 2014	20	14	Trane. Electric heat. 101,250 BTU/hr output. 120V, 1 Ph. Based on serial number assumed 2014. (w/ Disconnect)	1	Ea.					x	
Maintenance Building	UH-3	Unit Heater	1st Floor	X			Assume 2014	20	14	Trane. Electric heat. 101,250 BTU/hr output. 120V, 1 Ph. Based on serial number assumed 2014. (w/ Disconnect)							x	
Maintenance Building	UH-4	Unit Heater	1st Floor	X			Assume 2014	20	14	Trane. Electric heat. 101,250 BTU/hr output. 120V, 1 Ph. Based on serial number assumed 2014. (w/ Disconnect)							x	
													1	Ea.				
<b>SPLIT SYSTEMS:</b>																		
Maintenance Building	HVU-1 (aka ERV-1)	Ventilating unit - Serves Offices	Storage Room	X			Assume 2014	20	14	Inline. 208V. Assume Trane to match ACCU and DDC controls. Up high - unable to confirm info.	1	Ea.					x	
Maintenance Building	ACCU-1	Condensing Unit	Exterior grade	X			2014	20	14	Trane. HFC-410A, 1/8 HP, 208/30V, 1 Ph. (w/ disconnect and service receptacle)							x	
													1	Ea.				
<b>HVAC CONTROLS</b>																		
Maintenance Building	DDC-1	Digital Controls		X			Assume 2014			Trane	1	Ea.					x	
													1	Ea.				
<b>DOMESTIC WATER HEATING EQUIPMENT</b>																		
Maintenance Building	HWH-1	Istantaneous Water Heater	1st Floor	X			Unknown	20		Navien. Appears new	1	Ea.					x	
Maintenance Building	AS-1	Air Separator - Serves EWH-1	1st Floor	X			Unknown	30		Amtral	1	Ea.					x	
													1	Ea.				
<b>PLUMBING FIXTURES</b>																		
Maintenance Building	GM-1	Gas Meter	Exterior	X			Unknown			Honeywell Digital. Regulator looks recently replaced.	1	Ea.					x	
Maintenance Building	WS-1	Water Shutoff	Garage		X					Assembly has bucket below to catch water.				x			x	
Maintenance Building	WC	Water Closet	Toilet Rooms	X						Floor mounted	2					x		
Maintenance Building	LAV.	Lavatory	Toilet Rooms	X						Wall mounted. Single faucet/handle combo	2	Ea.				x		
Maintenance Building	UR.	Urinal	Toilet Rooms	X							1	Ea.				x		
Maintenance Building	D.F.	Drinking Fountain	Garage	X						Dual height with bottle filler		Ea.				x		
Maintenance Building	S.S.	Sink (Service) Sink	Garage	X						Floor mounted	1	Ea.				x		
Maintenance Building	1-CS	One Compartment Sink	Garage	X						Plastic tub with single faucet/dual handles						x		
Maintenance Building	H.S.	Kitchen Hand Sink	Break Room	X						Stainless Steel. Single faucet/dual handles		Ea.				x		
Maintenance Building	AC-1	Air Compressor	Garage		X		1967			Furnas motor. 208V (w/ Disconnect). Tank namplete 1967					x			

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Grounds Buildings
Building Area: Grounds Maintenance - 8,400 SF, Grounds Maintenance Storage Bldgs - 1,792, 4,224, 2,772 SF
No. of Floors: 1
Year Built: Grounds Maintenance - 1968, Grounds Maintenance Storage Bldgs - 1984, 2009, 2009
Year Renovated:
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining Service Life (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category	
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5		
<b>ELECTRICAL DISTRIBUTION SYSTEM</b>																			
Maintenance Building	LP-B	Load Center	1st Floor		x		1998	25 Years	3	Square D. 120/208V 3PH 4W.	1	Ea.							
Maintenance Building	LP-A	Load Center	1st Floor		x		1998	25 Years	3	Square D 120/208V	1	Ea.					x		
Maintenance Building	MDP-1	Panelboard	1st Floor		x		1998	25 Years	3	Square D. 120/208V 3PH 4W 400A. M.L.O.	1	Ea.					x		
Maintenance Building	MDP-2	Load Center	1st Floor		x		1998	25 Years	3	Square D. 120/208V 3 PH 4W	1	Ea.					x		
Maintenance Storage	LC-MS	Load Center	1st Floor		x		1984	25 Years	-11	Square D. 120/208V 1 PH 3W	1	Ea.					x		
Maintenance Storage Large	LP-A1	Load Center	1st Floor	x			2009	25 Years	14	Square D. 120/208V 3PH 4W 60A. 3P. M.C.B.	1	Ea.					x		
Maintenance Storage	LP-X4	Load Center	1st Floor	x			2009	25 Years	14	Square D. 120/208V 3PH 4W 60A 3 P. M.C.B.	1	Ea.					x		
Maintenance Pavilion	T-MB	Transformer	Outdoor		x		1998	25 Years	3		1	Ea.					x		
											1	Ea.					x		
<b>LIGHTING FIXTURES</b>																			
Mainteance Building	Fluorescent	Office Area		x			2015	25 Years	20	Occupancy sensor control	800	SF						x	
Mainteance Building	LED	Garage Area		x			2015	25 Years	20	Occupancy sensor control	7600	SF					x		
Mainteance Storage	Fluorescent	Throughout		x			1984	25 Years	-11	Timer controlled	1792	SF					x		
Mainteance Storage Large	Fluorescent	Throughout		x			2009	25 Years	14	Timer controlled	4224	SF					x		
Mainteance Storage	Fluorescent	Throughout		x			2009	25 Years	14	Timer controlled	2772	SF					x		
																	x		
<b>FIRE ALARM</b>																			
Maintenance Building	Notification/initiation	Throughout		x			2009	15 years	4 years		8400	SF					x		
Maintenance Storage	Notification/initiation	Throughout		x			1984	16 years	-21 years		1792	SF							
Maintenance Storage Large Eq.	Notification/initiation	Throughout		x			2009	17 years	4 years		4224	SF							
Maintenance Storage Salt	Notification/initiation	Throughout		x			2009	18 years	4 years		2772	SF							
										Total Cost									

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority	Description
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>ROOFING</b>																		
Farm House		Shingles		X						Visual inspection only.							x	
<b>EXTERIOR</b>																		
Farm House																		
		Walls (Wood siding)		X						Chipped out paint in the front porch at the bottom.							x	
		Doors		X													x	
		Garage Doors		X													x	
		Windows		X													x	
		Deck (Wood)		X													x	
		Porch (Brick)		X													x	
<b>INTERIORS</b>																		
Farm House			Lower Level															
		Basement											Ea.					
		Ceilings (Exposed Concrete)		X									Ea.				x	
		Floors (Exposed Concrete)			X					Cracking in floor in old basement areas.			Ea.			x		
		Walls			X					Damage to walls were addition and modifications were made to basement rooms. Cracks in wall at window sill in old basement. New basement looks good.			Ea.		x			
		Doors		X									Ea.			x		
		Windows		X									Ea.			x		

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Farm House			First Level															
		Overall																
		Ceilings (Gyp. Bd.)		X									Ea.					x
		Floors (Wood - Family, Sun Room)		X									Ea.					x
		Floors (Carpet - Living, Great, Study Room)		X									Ea.					x
		Walls		X														x
		Doors		X									Ea.					x
		Windows		X									Ea.					x
		Hall Corridor Entry											Ea.					
		Ceilings (Gyp. Bd.)		X									Ea.					x
		Floors (Wood)		X									Ea.					x
		Floors (Tile)		X									Ea.					x
		Walls		X														x
		Doors		X									Ea.					x
		Windows		X									Ea.					x
		Dining Room											Ea.					
		Ceilings (Gyp. Bd.)		X									Ea.					x
		Floors (Wood)		X									Ea.					x
		Walls		X														x
		Doors		X									Ea.					x
		Windows		X									Ea.					x
		Millwork		X									Ea.					x
		Kitchen											Ea.					
		Ceilings (Gyp. Bd.)		X									Ea.					x
		Floors (Wood)		X									Ea.					x
		Walls		X														x
		Doors		X									Ea.					x
		Windows		X									Ea.					x
		Millwork		X									Ea.					x

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
		Toilets										Ea.						
		Ceilings (Gyp. Bd.)		X								Ea.					x	
		Floors (Wood )		X								Ea.					x	
		Walls		X													x	
		Doors		X								Ea.					x	
		Millwork		X								Ea.					x	
		Garage										Ea.						
		Ceilings (Gyp. Bd.)		X								Ea.					x	
		Floors (Exposed Concrete)		X								Ea.					x	
		Walls		X													x	
		Doors		X								Ea.					x	
Farm House																		
		Family Room, Study Room										Ea.						
		Ceilings (Gyp. Bd.)		X								Ea.					x	
		Floors (Carpet)		X								Ea.					x	
		Walls		X													x	
		Doors		X								Ea.					x	
		Windows		X								Ea.					x	
		Bedrooms										Ea.						
		Ceilings (Gyp. Bd.)		X								Ea.					x	
		Floors (Carpet)		X								Ea.					x	
		Walls		X													x	
		Doors		X								Ea.					x	
		Windows		X								Ea.					x	
		Toilets										Ea.						
		Ceilings (VCT)		X								Ea.					x	
		Floors (Carpet)		X								Ea.					x	
		Walls		X													x	
		Doors		X								Ea.					x	
		Millwork		X								Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority	Description
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Farm House		Stairs (Wood)		X						Meet residential code.	1	Ea.					x	
<b>ACCESSIBILITY/ADA</b>																		
Farm House		Wheelchair lift to first floor.		X						Operational		Ea.					x	
<b>SITE</b>																		
Farm House		Asphalt				X				Cracking in asphalt near garage doors.						x		
Farm House		Concrete		X								Ea.					x	
Farm House		Gravel and Landscaping		X													x	
<b>ROOFING</b>																		
Farm House Pavilion		Shingles			X					Flashing around perimeter is loose/ bent. Gutters recommended.						x		
<b>EXTERIOR</b>																		
Farm House Pavilion																		
		Ceilings (Exposed)		X								Ea.					x	
		Floors (Exposed Concrete)		X								Ea.					x	
		Heavy Timber Wood Structure		X								Ea.					x	
		Wood siding			X					Panels are fraying and require paint.		Ea.				x		
<b>ROOFING</b>																		
Farm House Barn		Shingles				X				Visual inspection only.						x		
<b>EXTERIOR</b>																		
Farm House Barn																		
		Walls (Wood planks with CMU base, Conc., Stone)				X				Broken wood planks and holes/ cracking in base. Paint.						x		
		Doors				X				Most doors are operable but recommend doors to be replaced with new tracks, doors, and hinges.						x		
		Windows				X				Broken glass panes						x		
<b>INTERIORS</b>																		
Farm House Barn																		
		Ceilings (Heavy timber)		X								Ea.					x	
		Floors (Exposed Concrete and Wood)		X								Ea.					x	
		Walls (Heavy timber wood structure)		X								Ea.					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Farm House Barn		N / A											Ea.					
<b>ACCESSIBILITY/ADA</b>																		
Farm House Barn		N / A											Ea.					
<b>SITE</b>																		
Farm House Barn		Landscaping		X													X	
Farm House Barn		Asphalt		X													X	
<b>ROOFING</b>																		
Farm House Shed		Shingles			X					Fascia around perimeter is loose and warping.							X	
<b>EXTERIOR</b>																		
Farm House Shed																		
		Walls (cmu/wood siding)		X									Ea.					X
		Doors (Wood)			X					Doors and hardware to be replaced.			Ea.			X		
		Windows		X						Non-insulated but not a conditioned space.			Ea.				X	
<b>INTERIORS</b>																		
Farm House Shed			First Floor															
		Ceilings (Exposed Structure)		X									Ea.					X
		Floors (Exposed Concrete)			X					Crackings in floor and stained.			Ea.				X	
		Walls (CMU and masonry)			X					Damaged and broken walls.			Ea.				X	
		Doors (Wood)			X					Operable doors but recommended to be replaced.			Ea.				X	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm					
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF					
No. of Floors: 1					
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984					
Year Renovated: House 1999, Garage Addition 2015					
Evaluated: First Quarter 2020					

Condition		
State	Condition Description	
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.	
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.	
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.	

Deficiency Priorities					
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety				
Priority 2	Potential Critical: Problem Avoidance				
Priority 3	Necessary - Not Yet Critical: Predictable deterioration				
Priority 4	Recommended: Sensible or program oriented				
Priority 5	Grandfathered: Outside of current code/standards				

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
Farm House Shed			Second Level															
		Ceilings (Exposed timber structure)		X								Ea.					x	
		Floors (Wood)			X					Floor warped with loose planks.		Ea.			x			
		Windows		X						Non-insulated but not a conditioned space.		Ea.				x		
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Farm House Shed		Stairs (Wood)				X				No handrails. Hatch at second level.	1	Ea.		x				
<b>ACCESSIBILITY/ADA</b>																		
Farm House Shed		N / A								Is not required to be accessible.		Ea.						
<b>SITE</b>																		
Farm House Shed		Grass		X											x			
Farm House Shed		Asphalt			X					Cracking.				x				
<b>ROOFING</b>																		
Farm House Tool Shed		Metal				X				Structure appears to be in good condition. Panels are warped and rusted.				x				
<b>EXTERIOR</b>																		
Farm House Tool Shed																		
		Walls (Metal panels and Concrete base)			X					Warped and rusted. Base is broken and cracked.		Ea.		x				
		Doors (metal)				X				Operable but recommended to be replaced with new doors and track.		Ea.		x				
<b>INTERIORS</b>																		
Farm House Tool Shed			First Level															
		Overall										Ea.						
		Ceilings (Exposed timber structure)		X								Ea.		x				
		Walls (Exposed timber structure)		X								Ea.		x				
		Floors (Gravel)		X								Ea.		x				
<b>VERTICAL AND HORIZONTAL TRANSPORTATION</b>																		
Farm House Tool Shed		N / A										Ea.						

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF
No. of Floors: 1
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984
Year Renovated: House 1999, Garage Addition 2015
Evaluated: First Quarter 2020

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority	Description
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>ACCESSIBILITY/ADA</b>																		
Farm House Tool Shed		N/A											Ea.					
<b>SITE</b>																		
Farm House Tool Shed		Grass		X													x	
<b>AIR HANDLING UNITS</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>EXHAUST EQUIPMENT</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>CHILLED WATER EQUIPMENT</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>HOT WATER HEATING EQUIPMENT</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>EXTRANCE CABINET UNIT HEATERS</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>UNIT HEATERS (UH)</b>																		
Farmhouse	UH-1	Unit Heater	Garage	X			2005	20	5	Resznor. Electric. Digital Stat in garage. 115V, 1 Ph.		1	Ea.					
													1	Ea.				
<b>UNIT VENTILATOR (HOT WATER / DX)</b>																		
N/A													1	Ea.				
													1	Ea.				
<b>ENERGY RECOVERY UNIT (ERU)</b>																		
N/A													1	Ea.				
													1	Ea.				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Farm										
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF										
No. of Floors: 1										
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984										
Year Renovated: House 1999, Garage Addition 2015										
Evaluated: First Quarter 2020										

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority	Description
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>SPLIT SYSTEMS:</b>																		
Farmhouse	FN-1	Furnace	Basement	X			Assume 2018	18	16	Byant. 2 Stage ECM. Based on the serial number, assumed 2018.	1	Ea.					x	
Farmhouse	FN-2	Furnace	Basement	X			Assume 2017	18	15	Byant. 2 Stage ECM. Based on the serial number, assumed 2017.	1	Ea.					x	
Farmhouse	ACCU-1	Condensing Unit	Exterior			X	Assume 1999	20	-1	ArcoAire. 1/5 HP, 208/230V, 1 Ph. Based on the serial number, assumed 1999.	1	Ea.		x				
Farmhouse	ACCU-2	Condensing Unit	Exterior	X			Assume 2018	20	16	Bryant. R-410A, 1/3 HP, 220-410V, 3 Ph.	1	Ea.				x		
Farmhouse	ACCU-3	Air Conditioner	Basement	X			2017	20	15	GE. Mobile air conditioning unit. R-410A, 115V, 1 Ph.	1	Ea.				x		
<b>HVAC CONTROLS</b>																		
Farmhouse	DDC-1	Digital Controls	First Floor	X			Assume 2017			Bryant Digital Controls	1	Ea.					x	
													1	Ea.				
<b>DOMESTIC WATER HEATING EQUIPMENT</b>																		
Farmhouse	DWH-1	Domestic Water Heater	Basement		X		Unknown	20		Natural Gas. Tank covered with insulation - tank information inaccessible. Appears to be approx 91 gal.	1	Ea.				x		
													1	Ea.				
<b>PLUMBING FIXTURES</b>																		
Farmhouse	WM-1	Water Meter	Basement		X		Unknown			Sensus. Analog.	1	Ea.				x		
Farmhouse	GM-1	Gas Meter	Exterior		X		Unknown			Metris. Consumers Energy. Analog. Moisture inside cover plate and mold growing on meter.	1	Ea.				x		
Farmhouse	WC	Water Closet	1st/2nd Floor		X						4	Ea.				x		
Farmhouse	LAV.	Lavatory	1st/2nd Floor		X						3	Ea.				x		
Farmhouse	1-CS	One Compartment Sink			X					Ceramic with single faucet/dual levers	1	Ea.				x		
Farmhouse	2-CS	Two Compartment Sink	Kitchen		X					Plastic with bucket pump and single faucet/dual levers	1	Ea.				x		
Farmhouse	2-CS	Two Compartment Sink	Basement		X					Ceramic with single faucet/dual levers	1	Ea.				x		
Farmhouse	SH-T	Shower/Tub Combo Unit			X					W/ glass doors	1	Ea.				x		
Farmhouse	SH	Shower			X					W/ glass doors	1	Ea.				x		\$ - \$
<b>SUMP PUMP</b>																		
Farmhouse	SP-1	Sump Pump	Basement				Unknown	10		Switch Mate Pump 120V	1	Ea.				x		
Farmhouse	SP-2	Sump Pump	Basement				Unknown	10		Goulds with Simplex Controls and rotary disconnect	1	Ea.				x		

Delta College Farm						
Building Area: House 9,064 SF, Barn 7,900 SF, Shed 1,020 SF, Tool Shed 1,320 SF, Pavilion 960 SF						
No. of Floors: 1						
Year Built: House 1870, Barn 1881, Shed 1890, Tool Shed 1930, Pavilion 1984						
Year Renovated: House 1999, Garage Addition 2015						
Evaluated: First Quarter 2020						

Condition	
State	Condition Description
Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.
Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.
Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.

Deficiency Priorities	
Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety
Priority 2	Potential Critical: Problem Avoidance
Priority 3	Necessary - Not Yet Critical: Predictable deterioration
Priority 4	Recommended: Sensible or program oriented
Priority 5	Grandfathered: Outside of current code/standards

Area (Floor/Wing)	Tag	Item/Description	Location	Condition			Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
				Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	
<b>POWER AND DISTRIBUTION</b>																		
Farmhouse	LP-A	Panelboard	Basement				2001	25 Years	6	Square D. 120/2 1 PH. 3W. 200A. 2P. M.C.S	1	Ea.					x	
Farmhouse	LP-B	Panelboard	Basement				2001	25 Years	6	Square D. 120/2 1 PH. 3W. 100A. M.L.O.	1	Ea.					x	
Farmhouse	LP-C	Panelboard	Basement				2001	25 Years	6	Square D. 120/2 1 PH. 3W. 100A. M.L.O.	1	Ea.					x	
Farmhouse	LP-D	Load Center	Garage				2001	25 Years	6	Square D. 120/2 1 PH 3W. 100A. 2P. M.C.B.	1	Ea.					x	
Farmhouse	LC-S	Load Center	Brick Shed			x		25 Years		Square D. 120/2 1 PH. 3W. 60A. M.L.O.	1	Ea.				x		
<b>LIGHTING FIXTURES</b>																		
Farmhouse	Incandescent	Throughout					2001	25 Years	6 Years	Residential Lighting		SF					x	
Farmhouse	Flourescent	Throughout					2001	25 Years	6 Years	Strip Fixtures		SF					x	
Farmhouse	Incandescent	Throughout						25 Years		Porcelain Keyless Lamp Outlets	1020	SF					x	
Farmhouse	Incandescent	Throughout						25 Years		Porcelain Keyless Lamp Outlets	1320	SF					x	
Farmhouse	Incandescent	Throughout					1984	25 Years		Porcelain Keyless Lamp Outlets and Floods	960	SF					x	
Farmhouse	Incandescent	Throughout						25 Years		Porcelain Keyless Lamp Outlets	7900	SF					x	
<b>FIRE ALARM</b>																		
Farmhouse	Notification / Invitation	Throughout					2001	15 Years			9100	SF					x	
Farmhouse	Notification / Invitation	Throughout						15 Years			1020	SF					x	
Farmhouse	Notification / Invitation	Throughout						15 Years			1320	SF					x	
Farmhouse	Notification / Invitation	Throughout					1984	15 Years			960	SF					x	
Farmhouse	Notification / Invitation	Throughout						15 Years			7900	SF					x	

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Planetarium & Science Center				Condition							Deficiency Priorities								
				State	Condition Description							Priority 1		Current Critical: Safety hazard, accelerated deterioration, potential life safety					
				Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.							Priority 2		Potential Critical: Problem Avoidance					
				Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.							Priority 3		Necessary - Not Yet Critical: Predictable deterioration					
				Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.							Priority 4		Recommended: Sensible or program oriented					
				Condition			Approx year installed		Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks		Qty	Unit	Deficiency Priorities				
Area (Floor/Wing)	Tag	Item/Description	Location	Good	Fair	Poor							Priority 1	Priority 2	Priority 3	Priority 4	Priority 5	Deficiency Category	
ROOFING						x							Ea.						
EXTERIOR ELEMENTS						x							Ea.						
INTERIORS						x							Ea.						
VERTICAL AND HORIZONTAL TRANSPORTATION						x							Ea.						
ACCESSIBILITY/ADA						x							Ea.						
SITE						x							Ea.						
AIR HANDLING UNITS															x				
Lower Level	AHU-1	Modular Air handling unit	Lower level mechanical room		x		1995	24	-1	Trane, modular, chilled water, hot water, Designed as 10000 CFM, 369 MBH cooling, 165 MBH heating, 15 hp, 460 V, 3ph. Associated with RF-1	1	Ea.				x			
Lower Level	AHU-2	Modular Air handling unit	Lower level mechanical room		x		1995	24	-1	Trane, modular, chilled water, hot water, Designed as 17500 CFM, 681 MBH cooling, 284 MBH heating, 25 hp, 460 V, 3ph. Associated with RF-2	1	Ea.				x			
Lower Level	AHU-3	Modular Air handling unit	Lower level mechanical room		x		1995	24	-1	Trane, modular, chilled water, hot water, Designed as 21500 CFM, 864 MBH cooling, 465 MBH heating, 40 hp, 460 V, 3ph. Associated with RF-3	1	Ea.				x			
Lower Level	RF-1	Modular Air handling unit	Lower level mechanical room		x		1995	20	-5	Greenheck, Designed as 9500 CFM, 7.5 hp, 460 V, 3ph. Associated with AHU-1						x			
Lower Level	RF-2	Modular Air handling unit	Lower level mechanical room		x		1995	20	-5	Greenheck, Designed as 16500 CFM, 10 hp, 460 V, 3ph. Associated with AHU-2						x			
Lower Level	RF-3	Modular Air handling unit	Lower level mechanical room		x		1995	20	-5	Greenheck, Designed as 20000 CFM, 15 hp, 460 V, 3ph. Associated with AHU-3						x			
Lower Level	HV-1	Heating and ventilation unit	Lower level mechanical room		x		1995	20	-5	Trane, modular, heating only, Designed as 2000 CFM, 120 MBH heating, 5 hp, 460 V, 3ph	1	Ea.			x				
Lower Level	HV-2	Heating and ventilation unit	Lower level mechanical room		x		1995	20	-5	Trane, modular, heating only, Designed as 2000 CFM, 120 MBH heating, 5 hp, 460 V, 3ph	1	Ea.			x				
Lower Level	FCU-1	Fan coil unit	Lower level mechanical room		x		assume 1995	20	-5	Designed as McQuay, Heating, and cooling, 700 cfm, 26.2 MBH cooling, 56 MBH heating, 1/2 hp, 460 V, 3ph	1	Ea.			x				
Lower Level	FCU-2	Fan coil unit	Lower level mechanical room		x		assume 1995	20	-5	Designed as McQuay, Heating only, 600 cfm, 45 MBH heating, 1/2 hp, 460 V, 3ph	1	Ea.			x				

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00

Delta College Planetarium & Science Center				Condition								Deficiency Priorities													
				State	Condition Description											Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety								
				Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.											Priority 2	Potential Critical: Problem avoidance								
				Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.											Priority 3	Necessary - Not Yet Critical: Predictable deterioration								
				Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.											Priority 4	Recommended: Sensible or program oriented								
																				Priority 5	Grandfathered: Outside of current code/standards				
Area (Floor/Wing)	Tag	Item/Description	Location	Condition	Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category						
<b>EXHAUST EQUIPMENT</b>																									
Roof	EF-1	Exhaust fan, Servers toilet room	Roof		X			1995	20	-5	Designed as Greenheck, 950 CFM, 1/2 hp, 460 V, 3ph	1	Ea.				x								
Roof	EF-2	Exhaust fan, Servers toilet room	Roof		X			1995	20	-5	Designed as Greenheck, 1100 CFM, 1/2 hp, 460 V, 3ph	1	Ea.			x									
Lower Level	EF-3	Exhaust fan, inline fan	Lower level mechanical room		X			1995	20	-5	Greenheck, Designed as 4500 CFM, 3 hp, 460 V, 3ph	1	Ea.			x									
Lower Level	EF-4	Exhaust fan, propeller wall fan	Lower level mechanical room		X			1996	20	-4	Greenheck, Designed as 4700 CFM, 3/4 hp, 460 V, 3ph	1	Ea.			x									
<b>CHILLED WATER EQUIPMENT</b>																									
On grade outside	CH-1	Chiller	Outside on grade		X			1995	20	-5	Trane, designed as, 162 tons, 440 gpm, 460 V, 3ph	1	Ea.			x									
Lower level	CHWP-1	Chilled water pump	Lower level mechanical room		X			1995	20	-5	Bell and gossett, 440 gpm, 140ft head, 25 hp, 460 V, 3ph	1	Ea.			x									
Lower level	GP-1	Glycol pump	Lower level mechanical room		X			1995	20	-5	MagneTek motor, 3/4 hp, 460 V, 3ph	1	Ea.			x									
<b>HOT WATER HEATING EQUIPMENT</b>																									
Lower level	B-1	Boiler	Lower level mechanical room		X			1995	20	-5	Universal Energy Corporation, 2680000 btu/hr output. Burner PowerFlame, 1-1/2hp, 460 V, 3ph	1	Ea.			x									
Lower level	PHWP-1	Primary heating hot water pump	Lower level mechanical room		X			1995	20	-5	Bell and gossett, 240 gpm, 50 ft head, 5 hp, 460 V, 3ph	1	Ea.			x									
Lower level	SHWP-1	Secondary heating hot water pump	Lower level mechanical room		X			1995	15	-10	Designed as Bell and gossett, 130 GPM, 85 ft head, 7-1/2 hp, 460 V, 3ph	1	Ea.			x									
Lower level	SHWP-2	Secondary heating hot water pump	Lower level mechanical room		X			1995	15	-10	Designed as Bell and gossett, 100 GPM, 60 ft head, 5 hp, 460 V, 3ph	1	Ea.			x									
Lower level	CCP-1	Coil circulation pump - Serves AHU-1	Lower level mechanical room		X			1995	15	-10	Bell and gossett, 26 gpm, 25 ft head, 3/4 hp, 460 V, 3ph	1	Ea.			x									
Lower level	CCP-2	Coil circulation pump - Serves AHU-2	Lower level mechanical room		X			1995	15	-10	Bell and gossett, Designed as 20 gpm, 25 ft head, 3/4 hp, 460 V, 3ph	1	Ea.			x									
Lower level	CCP-3	Coil circulation pump - Serves AHU-3	Lower level mechanical room		X			1995	15	-10	Bell and gossett, Designed as 36 gpm, 25 ft head, 3/4 hp, 460 V, 3ph	1	Ea.			x									
<b>EXTRANCE CABINET UNIT HEATERS</b>																									
First floor	CUH-1	Cabinet unit heater wall mounted	Stair #3		X			assume 1995	20	-5	Designed as Sterling, 20.4 mbh, 2 gpm, 380 CFM, 1/10 hp, 115 V, 1ph	1	Ea.			x									
First floor	CUH-2	Cabinet unit heater ceiling recessed	Stair #2		X			assume 1995	20	-5	Designed as Sterling, 20.4 mbh, 2 gpm, 380 CFM, 1/10 hp, 115 V, 1ph	1	Ea.			x									
													1	Ea.											
<b>UNIT HEATERS (UH)</b>																									
First floor	UH-1	Unit heater	receiving and storage		X			1995	20	-5		1	Ea.			x									
First floor	UH-2	Unit heater	receiving and storage		X			1995	20	-5		1	Ea.			x									
Lower level	UH-3	Unit heater	Lower level mechanical room		X			1995	20	-5		1	Ea.			x									
Lower level	UH-4	Unit heater	Lower level mechanical room		X			1995	20	-5		1	Ea.			x									
													1	Ea.											

Delta College Planetarium & Science Center				Condition										Deficiency Priorities									
				State	Condition Description													Priority 1	Current Critical: Safety hazard, accelerated deterioration, potential life safety				
				Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.													Priority 2	Potential Critical: Problem Avoidance				
				Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.													Priority 3	Necessary - Not Yet Critical: Predictable deterioration				
				Poor	Beyond normal service life AND extremely worn, damaged and not functional requiring high maintenance and repairs.													Priority 4	Recommended: Sensible or program oriented				
																		Priority 5	Grandfathered: Outside of current code/standards				
Area (Floor/Wing)	Tag	Item/Description	Location	Condition	Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category				
UNIT VENTILATOR (HOT WATER / DX)				N/A								1	Ea.										
ENERGY RECOVERY UNIT (ERU)				N/A								1	Ea.										
SPLIT SYSTEMS: ERV + AC				First floor	CC-1	Condensing unit	Headend room	X		ASSUME 2017	20	17			1	Ea.		x					
				On grade outside	AC-1	Air conditioner	Outside on grade	X		2017	20	17			1	Ea.		x					
SPECIALTY SYSTEMS				Lower level	COMP-1	Air compressor	Lower level mechanical room	X		assum 1995	20	-5			1	Ea.		x					
				Lower level	CP-1	Condensate Pump	Kitchen	X		1995	15	-10			1	Ea.		x					
HVAC CONTROLS				DDC-1								1	Ea.					x					
DOMESTIC WATER HEATING EQUIPMENT				DWH-1	Domestic water heater	Lower level mechanical room		X		2008	20	8	Bradford white. Natural gas, 76 mbh input, 75 gal.		1	Ea.		x					
				DHWC-1	Domestic hot water circulation pump	Lower level mechanical room		X		assume 2008	20	8			1	Ea.		x					
PLUMBING FIXTURES													Ea.										

# Delta College Facilities Condition Assessment

DSD Project No. 20-0501.00


Delta College Planetarium & Science Center				Condition							Deficiency Priorities								
				State	Condition Description							Priority 1		Current Critical: Safety hazard, accelerated deterioration, potential life safety					
				Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.							Priority 2		Potential Critical: Problem Avoidance					
				Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.							Priority 3		Necessary - Not Yet Critical: Predictable deterioration					
				Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.							Priority 4		Recommended: Sensible or program oriented					
												Priority 5		Grandfathered: Outside of current code/standards					
Area (Floor/Wing)	Tag	Item/Description	Location	Condition	Good	Fair	Poor	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category
<b>ELECTRICAL DISTRIBUTION SYSTEM</b>																			
Planetarium	MCC-2	Panelboard	Room B101		X			1995	25 Years	0	Square D. 480V 3PH 3W 600A. M.L.O.	1	Ea.					x	
Planetarium	MCC-1	Panelboard	Room B103		X			1995	25 Years	0	Square D. 480V 3PH 3W 600A. M.L.O.	1	Ea.					x	
Planetarium	RP-4	Panelboard	Room B102		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	
Planetarium	DP-1	Panelboard	Room B102		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 800A. 3P. M.C.B.	1	Ea.					x	
Planetarium	T-2	Transformer	Room B102		X			1995	25 Years	0	Square D. 112.5KVA 480V-120/208V	1	Ea.					x	
Planetarium	T-1	Transformer	Room B102		X			1995	25 Years	0	Square D. 225KVA 480V-120/208V	1	Ea.					x	
Planetarium	DP-2	Panelboard	Room B102		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 400A. 3P. M.C.B.	1	Ea.					x	
Planetarium	SUB-1	Substation	Room B102		X			1995	25 Years	0	Square D. 750KVA 480/277V	1	Ea.					x	
Planetarium	ATS-EL	ATS	Room B102		X			1998	25 Years	2	Cummins	1	Ea.					x	
Planetarium	AT-EM	ATS	Room B103		X			1998	25 Years	2	Cummins	1	Ea.					x	
Planetarium	PNL-EL	Panelboard	Room B104		X			1998	25 Years	2	Square D. 480/277V 3PH 4W 40A. 3P. M.C.B.	1	Ea.					x	
Planetarium	EMDP	Panelboard	Room B105		X			1998	25 Years	2	Square D. 480/277V 3PH 4W 40A. 3P. M.C.B.	1	Ea.					x	
Planetarium	PNL-EM	Panelboard	Room B106		X			1998	25 Years	2	Square D. 120/208V 3PH 4W 60A. 3P. M.C.B.	1	Ea.					x	
Planetarium	IT-1	Panelboard	Room 106		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 200A. M.L.O.	1	Ea.					x	
Planetarium	RP-1	Panelboard	Room 106		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	
Planetarium	LP-1	Panelboard	Room 106		X			1995	25 Years	0	Square D. 480/277V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	IT-2	Panelboard	Room 117		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	RP-2	Panelboard	Room 117		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 225A. M.L.O.	1	Ea.					x	
Planetarium	EL-4	ELROOF	Panelboard		X			1995	25 Years	0	Square D. 120/208V 3PH M.C.B.	1	Ea.					x	
Planetarium	RP-6	Panelboard	Room 130		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	DDP	Panelboard	Room 131		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 300A. 3P. M.C.B.	1	Ea.					x	
Planetarium	DP-3	Panelboard	Room 131		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 400A. M.C.B.	1	Ea.					x	
Planetarium	IT-4	Panelboard	Room 200		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	LP-3	Panelboard	Room 200		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	IT-3	Panelboard	Room 208A		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 200A. M.L.O.	1	Ea.					x	
Planetarium	RP-3	Panelboard	Room 208A		X			1995	25 Years	0	Square D. 120/208V 3PH 4W .	11	Ea.					x	
Planetarium	LP-2	Panelboard	Room 208A		X			1995	25 Years	0	Square D. 480/277V 3PH 4W 100A. M.L.O.	1	Ea.					x	
Planetarium	RP-5	Panelboard	Room 131		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 200A. M.L.O.	1	Ea.					x	
Planetarium	RP-7	Panelboard	Room 130		X			1995	25 Years	0	Square D. 120/208V 3PH 4W 60A. 3P. M.C.B.	1	Ea.					x	

Delta College Planetarium & Science Center				Condition			Deficiency Priorities											
				State	Condition Description		Priority 1		Priority 2		Priority 3		Priority 4		Priority 5			
				Good	Within the first half of its life and in good condition - no reported issues or concerns and no repairs needed.		Current Critical: Safety hazard, accelerated deterioration, potential life safety		Priority 2		Potential Critical: Problem Avoidance		Necessary - Not Yet Critical: Predictable deterioration		Recommended: Sensible or program oriented			
				Fair	In the second half of its life. Minor repairs needed or higher than routine maintenance required.		Priority 3		Priority 4		Priority 5		Priority 5		Grandfathered: Outside of current code/standards			
				Poor	Beyond normal service life AND extremely worn, damaged or not functional requiring high maintenance and repairs.													
Area (Floor/Wing)	Tag	Item/Description	Location	Condition	Approx year installed	Industry Standard Life	Est. Remaining ServiceLife (as of 2020)	Remarks	Qty	Unit	Deficiency Priorities					Deficiency Category		
LIGHTING FIXTURES																		
		Corridor Lighting																
		Classroom Lighting																
		Office Lighting																
		Mechanical/Electrical Rooms																
		Media Center Lighting																
		Gymnasium Lighting																
		Cafetorium/Auditorium Lighting																
Planetarium	Fluorescent	Throughout		X	1995	25	0		1	lot								
FIRE ALARM																		
		Corridor Lighting																
		Classroom Lighting																
		Office Lighting																
		Mechanical/Electrical Rooms																
		Media Center Lighting																
		Gymnasium Lighting																
		Cafetorium/Auditorium Lighting																
Planetarium	Notification/annunciation	Throughout		X	1995	15	-10		1	lot								

# DELTA COLLEGE FACILITIES CONDITION ASSESSMENT

1961 DELTA ROAD



UNIVERSITY CENTER MICHIGAN 48710



DiCLEMENTE SIEGEL DESIGN INC.

28105 GREENFIELD ROAD  
SOUTHFIELD, MICHIGAN 48076-3046

DSD PROJECT No. 20-0501



NORTH  
MAIN CAMPUS SITE PLAN  
NOT TO SCALE

ENGINEERING AND ARCHITECTURE

G-001 COVER SHEET

## ARCHITECTURAL INDEX

SHEET	DESCRIPTION
MAIN CAMPUS	
A-001	LOWER LEVEL PHASING PLAN
A-002	FIRST FLOOR PHASING PLAN
A-003	SECOND FLOOR PHASING PLAN
A-004	THIRD FLOOR PHASING PLAN
A-005	ROOF PHASING PLAN
A-011	LOWER LEVEL COMPOSITE EGRESS PLAN
A-012	FIRST FLOOR COMPOSITE EGRESS PLAN
A-013	SECOND FLOOR COMPOSITE EGRESS PLAN
A-100	MAIN CAMPUS ARCHITECTURAL SITE PLAN
A-101	MAIN CAMPUS COMPOSITE LOWER LEVEL PLAN
A-102	MAIN CAMPUS FIRST FLOOR COMPOSITE PLAN
A-103	MAIN CAMPUS SECOND FLOOR COMPOSITE PLAN
A-104	MAIN CAMPUS THIRD FLOOR COMPOSITE PLAN
A-121	MAIN CAMPUS COMPOSITE ROOF PLAN
SERVICE/UTILITY BUILDING	
A-101	COMPOSITE FIRST FLOOR ARCHITECTURAL PLAN
GROUNDS/MAINTENANCE BUILDING	
A-101	COMPOSITE FIRST FLOOR ARCHITECTURAL PLAN
FARM BUILDINGS	
A-101	COMPOSITE SITE ARCHITECTURAL PLAN
A-102	COMPOSITE BASEMENT ARCHITECTURAL PLAN
A-103	COMPOSITE FIRST FLOOR ARCHITECTURAL PLAN
A-104	COMPOSITE SECOND FLOOR ARCHITECTURAL PLAN
PLANETARIUM	
A-001	BASEMENT AND FIRST FLOOR ARCHITECTURAL PLANS
A-002	SECOND FLOOR AND ROOF ARCHITECTURAL PLANS


## MECHANICAL SHEET INDEX

SHEET	DESCRIPTION
M-001	GENERAL MECHANICAL INFORMATION
MAIN CAMPUS	
M-101	PARTIAL LOWER LEVEL MECHANICAL PLAN
M-102	PARTIAL LOWER LEVEL MECHANICAL PLAN
M-103	PARTIAL FIRST FLOOR MECHANICAL PLAN
M-104	PARTIAL FIRST FLOOR MECHANICAL PLAN
M-105	SECOND AND THIRD FLOOR MECHANICAL PLANS
M-106	ROOF MECHANICAL PLAN
M-000	LOWER LEVEL AIR HANDLING UNIT ZONE PLAN
M-001	FIRST FLOOR AIR HANDLING UNIT ZONE PLAN
M-002	SECOND FLOOR AIR HANDLING UNIT ZONE PLAN
M-003	BOILER ROOM SECTION DIAGRAM
M-004	STEAM AND CONDENSATE BUILDING DIAGRAM
M-005	STEAM AND CONDENSATE BOILER DIAGRAM
M-006	CHILLED WATER SYSTEM BUILDING DIAGRAM
M-007	CHILLED WATER/ICE STORAGE PIPING SCHEMATIC
M-008	CHILLED WATER PIPING DIAGRAM
SERVICE/UTILITY BUILDING	
M-101	FIRST FLOOR MECHANICAL PLAN
GROUNDS/MAINTENANCE	
M-101	FIRST FLOOR MECHANICAL PLAN
FARM BUILDINGS	
M-101	FIRST FLOOR MECHANICAL PLAN
M-102	BASEMENT MECHANICAL PLAN
M-103	FIRST FLOOR MECHANICAL PLAN
PLANETARIUM	
M-001	BASEMENT AND FIRST FLOOR MECHANICAL PLANS
M-002	SECOND FLOOR AND ROOF MECHANICAL PLANS

## ELECTRICAL SHEET INDEX

SHEET	DESCRIPTION
E-001	ELECTRICAL GENERAL INFORMATION
MAIN CAMPUS	
E-011	COMPOSITE LOWER LEVEL ELECTRICAL PLAN
E-012	COMPOSITE FIRST FLOOR ELECTRICAL PLAN
E-013	COMPOSITE SECOND & THIRD FLOORS ELECTRICAL PLANS
E-101	PARTIAL LOWER LEVEL ELECTRICAL PLAN
E-102	PARTIAL LOWER LEVEL ELECTRICAL PLAN
E-103	PARTIAL FIRST FLOOR ELECTRICAL PLAN
E-104	PARTIAL FIRST FLOOR ELECTRICAL PLAN
E-105	SECOND AND THIRD FLOORS ELECTRICAL PLANS
SERVICE/UTILITY BUILDING	
E-101	FIRST FLOOR ELECTRICAL PLAN
GROUNDS/MAINTENANCE	
E-101	FIRST FLOOR MECHANICAL PLAN
FARM BUILDINGS	
E-101	ELECTRICAL SITE PLAN
E-102	BASEMENT ELECTRICAL PLAN
E-103	FIRST FLOOR ELECTRICAL PLAN
E-104	SECOND FLOOR ELECTRICAL PLAN
PLANETARIUM	
E-001	PLANETARIUM BASEMENT & FIRST FLOOR ELECTRICAL PLANS
E-002	PLANETARIUM SECOND FLOOR ELECTRICAL PLAN

NOT FOR  
CONSTRUCTION  
DO NOT USE FOR BIDDING,  
CONSTRUCTION, OR ORDERING  
OF MATERIALS.



DiClemente Siegel  
Design Inc.  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd. Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com



These documents are instruments of service for use solely  
with respect to this project. DSD and its contractors shall  
be deemed the authors and owners of their respective  
instruments of service and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a non-exclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification  
documents that are not intended to be used by the contractor  
as shop drawings. Final construction, site access,  
grading, miscellaneous fittings, final installations and  
coordination is the contractor's responsibility.

A/E SEAL


**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

**DELTA COLLEGE**  
**FACILITIES CONDITION ASSESSMENT**  
UNIVERSITY CENTER, MICHIGAN


©2020 DiClemente Siegel Design Inc.

DATE	ISSUED FOR:
03/20/20	OWNER PROGRESS REVIEW
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
-	-
9/30/20	FINAL

DESIGNER:	DA
MODELER:	DA
PM:	ATW
PIC:	BUR
ACADFILE:	202001-A001.DWG
PROJECT No:	20-0501.00
SHEET TITLE	MAIN CAMPUS LOWER LEVEL PHASING PLAN
SHEET NUMBER	A-001



LOWER LEVEL  
PHASING PLAN  
SCALE: 1" = 50'  
0 25 50 100 Feet



# celebrating 50 Years

# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

 Delta College

documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall remain the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of inspecting, using and maintaining this project.

documents are traditional plan and specification documents that are not intended to be used by the contractor to drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**AL**

---

**PRELIMINARY  
NOT FOR CONSTRUCTION  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.

NER:	DA
LLER:	DA
	ATW
	BJR
FILE:	20-0501-A-002.DWG
ECT No.	20-0501.00
TITLE	
CADD-CAM SYSTEMS	

**MAIN CAMPUS**  
**FIRST FLOOR**

## FIRST FLOOR PHASING PLAN

NUMBER

A-002

A-002

---

This architectural map illustrates the layout and renovation history of the University of Michigan's Kresge Auditorium building. The building is divided into several wings, each distinguished by a unique color:

- M - WING**: Located at the top left, colored pink.
- L - WING**: Located at the top right, colored purple.
- K - WING**: Located in the upper center, colored orange.
- J - WING**: Located in the upper center, colored green.
- H - WING**: Located in the upper right, colored red.
- G - WING**: Located in the upper right, colored blue.
- A - WING**: Located on the far right, colored dark green.
- B - WING**: Located in the lower right, colored purple.
- C - WING**: Located at the bottom center, colored orange.
- E - WING**: Located in the lower center, colored yellow.
- D - WING**: Located in the lower center, colored orange.
- F - WING**: Located at the bottom left, colored blue.
- P - WING**: Located in the middle left, colored yellow.
- Z - WING**: Located on the far left, colored orange.

The map also highlights several renovation projects:

- 2003 RENOVATION**: Indicated by a red bracket on the left side.
- 2003 RENOVATION**: Indicated by a red bracket on the bottom left side.
- ORIGINAL CONSTRUCTION**: Indicated by a red bracket on the far left side.

A legend on the left provides a key for the colors used to represent different types of additions:

- ADDITION (Grey)
- ADDITION (Dark Blue)
- ADDITION (Teal)
- ADDITION (Purple)
- ADDITION (Light Blue)
- UNKNOWN (Red)

Timeline markers indicate specific years of construction or renovation:


- 1961
- 1962
- 1968
- 1968
- 1972
- 1978
- 1979
- 1999
- 1961
- 1998
- 2004
- 2004
- 2000
- 2004
- 2013

**NORTH**

**FIRST FLOOR  
PHASING PLAN**

SCALE: 1" = 50'

0      25      50      100      Feet



# Celebrating 50 Years

# **DICLEMENTE SIEGEL DESIGN INC.**

## **ARCHITECTURE & ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

 Delta College

documents are instruments of service for use solely  
pect to this project. DSD and DSD's consultants shall  
med the authors and owners of their respective  
ents of service and shall retain all common law,  
ry and other reserved rights, including copyrights.  
ants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ucting, using and maintaining this project.

documents are traditional plan and specification  
ments that are not intended to be used by the contractor  
o drawings. Final dimensions, equipment access,  
g, miscellaneous fittings, final installation and  
ination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE

## ACILITIES CONDITION ASSESSMENT


### IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

NER:	DA
LLER:	DA
	ATW
	BJR
FILE:	20-0501-A-003.DWG
ECT No.	20-0501.00
TITLE	

## MAIN CAMPUS SECOND FLOOR PHASING PLAN


NUMBER  
**A-003**



COND FLOOR  
EASING PLAN

E: 1" = 50'

25      50      100      Feet



# Celebrating 50 Years

# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely in respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights, grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of inspecting, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DETA COLLEGE



# ACILITIES ONDITION SSESSMENT


## IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

OWNER:	DA
SELLER:	DA
	ATW
	BJR
FILE:	20-0501-A-004.DWG
ECT No.	20-0501.00
TITLE	
MAIN CAMPUS	
THIRD FLOOR	
PHASING PLAN	

NUMBER  
A-004





# Celebrating 50 Years

**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

documents are instruments of service for use solely  
pect to this project. DSD and DSD's consultants shall  
rm the authors and owners of their respective  
ents of service and shall retain all common law,  
ry and other reserved rights, including copyrights.  
ants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ucting, using and maintaining this project.

documents are traditional plan and specification documents that are not intended to be used by the contractor to drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and orientation is the contractor's responsibility.

**AL**

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DETAILED ACILITIES CONDITION ASSESSMENT VERSITY CENTER, MICHIGAN

NER:	R. WILSON
LLER:	D. ARORA
	ATW
	BJR
FILE:	20-0501-A-005.DWG
ECT No.	20-0501.00
TITLE	

## ROOF FLOOR PHASING PLAN

NUMBER  
**A-005**



## Celebrating 50 Years

**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights, grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of constructing, using and maintaining this project.

documents are traditional plan and specification documents that are not intended to be used by the contractor to drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**AL**

**PRELIMINARY**  
**NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# **DETA COLLEGE**

# **FACILITIES CONDITION ASSESSMENT**


## **UNIVERSITY CENTER, MICHIGAN**

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

NER:	.
LLER:	.
	ATW
	BJR
FILE:	20-0501A-011.DWG
ECT No.	20-0501.00
TITLE	

## LOWER LEVEL IMPOSITE EGRESS PLAN



## **LOWER LEVEL COMPOSITE EXPRESS PLAN**

# COMPOS

SCALE: 1" = 50'

0      25      50      100   Feet

A-011



# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



se documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights, which grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**SEAL**

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DELTA COLLEGE


# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	.
ELLER:	.
	ATW
	BJR
DFILE:	20-0501A-012.DWG
JECT No.	20-0501.00
ET TITLE	

## FIRST FLOOR COMPOSITE EGRESS PLAN




A circular icon containing a black arrow pointing left, positioned above the title text.

# FIRST FLOOR COMPOSITE EGRESS PLAN

SCALE: 1" = 50'

A horizontal scale bar representing 50 feet. It features a series of four rectangular segments of increasing width from left to right, followed by a long straight segment. Below the bar, numerical values 0, 25, 50, and 100 are aligned with their respective segments, and the word "Feet" is written at the end of the bar.



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
ermed the authors and owners of their respective  
ments of service and shall retain all common law,  
try and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

DELTA COLLEGE


# FACILITIES CONDITION ASSESSMENT

UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

OWNER:	.
SELLER:	.
	ATW
	BJR
FILE:	20-0501A-013.DWG
ECT No.	20-0501.00
ATTITLE	

## SECOND FLOOR IMPOSITE EGRESS PLAN



## **SECOND FLOOR COMPOSITE EXPRESS PLAN**

**SCALE: 1/2" = 11'0"**

SCALE: 1/8" = 1'-0"

0      4      8      16      Feet

A-013





# celebrating 50 Years

# **DiClemente Siegel Design Inc.**

## **ARCHITECTURE & ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
pect to this project. DSD and DSD's consultants shall  
med the authors and owners of their respective  
ents of service and shall retain all common law,  
ry and other reserved rights, including copyrights.  
ants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ucting, using and maintaining this project.

documents are traditional plan and specification  
ments that are not intended to be used by the contractor  
o drawings. Final dimensions, equipment access,  
g, miscellaneous fittings, final installation and  
ination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# **FACILITIES CONDITION ASSESSMENT**

UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

NER:	REW
LLER:	DA
	ATW
	BJR
FILE:	20-0501-A-101.DWG
ECT No.	20-0501.00
TITLE	

# MAIN CAMPUS COMPOSITE LOWER LEVEL PLAN


NUMBER



# COMPOSITE LOWER LEVEL PLAN

SCALE: 1" = 50'

A step function graph showing a piecewise constant function. The x-axis is labeled "Feet" and ranges from 0 to 100. The function starts at height 0, jumps to height 1 at x=0, stays at height 1 until x=5, then drops to height 0.5 at x=5, stays at height 0.5 until x=15, then drops to height 0 at x=15. It remains at height 0 until x=25, then jumps to height 1 at x=25, stays at height 1 until x=50, then drops to height 0 at x=50. It remains at height 0 until x=100.



# celebrating 50 Years

# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

The logo for Delta College features a stylized green dome composed of concentric arcs above the words "Delta College" in a serif font.

documents are instruments of service for use solely  
pect to this project. DSD and DSD's consultants shall  
med the authors and owners of their respective  
ents of service and shall retain all common law,  
ry and other reserved rights, including copyrights.  
ants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ucting, using and maintaining this project.

documents are traditional plan and specification sets that are not intended to be used by the contractor to drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and orientation is the contractor's responsibility.

**AL**

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**


# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.

NER:	REW
LLER:	DA
	ATW
	BJR
FILE:	A-102.DWG
ECT No.	20-0501.00
TITLE	
SOMA CANTING	

**MAIN CAMPUS  
FIRST FLOOR  
COMPOSITE PLAN**

NUMBER



## FIRST FLOOR COMPOSITE PLAN

SCALE: 1" = 50'

A step function graph representing a ramped signal. The x-axis is labeled "Feet" and ranges from 0 to 100. The signal starts at 0, remains flat until x=5, then jumps to 1. It stays at 1 until x=10, then drops back to 0. It stays at 0 until x=25, then jumps to 1. It stays at 1 until x=50, then drops back to 0. It stays at 0 until x=75, then jumps to 1. It stays at 1 until x=100.

A-102



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)




The documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of constructing, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**




NORTH

BARN FIRST FLOOR  
COMPOSITE PLAN

---

SCALE: 1/8" = 1'-0"

0 4 8 16




**NORTH**

**FARM HOUSE FIRST FLOOR  
COMPOSITE PLAN**

SCALE: 1/8" = 1'-0"

0 4 8 16 Feet



NORTH

OLD GARAGE FIRST FLOOR  
COMPOSITE PLAN

SCALE: 1/8" = 1'-0"


0      4      8      16 Feet

NORTH

SCALE: 1/8" = 1'-0"

STORAGE FIRST FLOOR  
COMPOSITE PLAN

0 4 8 16 Feet



**OLD GARAGE FIRST FLOOR  
COMPOSITE PLAN**

NORTH

SCALE: 1/8" = 1'-0"

0      4      8      16 Feet

The logo features a circular compass rose with a diagonal line from the top-left to the bottom-right, indicating the North direction. Below the compass is the title "OLD GARAGE FIRST FLOOR COMPOSITE PLAN". To the left of the title is the word "NORTH". Below the title is the scale information "SCALE: 1/8\" data-bbox="108 167 900 360" data-label="Text"> $^{\prime\prime}$  = 1'-0" data-bbox="108 167 900 360" data-label="Text">

Below the scale is a horizontal scale bar divided into four segments, labeled 0, 4, 8, and 16, with "Feet" written at the end.

DESIGNER:	REW
MODELLER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-A-103.DWG
PROJECT No.	20-0501.00

**SHEET TITLE**  
**FARM HOUSE & BUILDINGS**  
**COMPOSITE FIRST FLOOR**  
**ARCHITECTURAL PLAN**

A-103



# Celebrating 50 Years

# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



se documents are instruments of service for use solely respect to this project. DSD and DSD's consultants shall deemed the authors and owners of their respective uments of service and shall retain all common law, uthority and other reserved rights, including copyrights, grants to the owner a nonexclusive license to reproduce s instruments of service solely for the purposes of tructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE



# ACILITIES CONDITION ASSESSMENT

## IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	DA
SELLER:	DA
	ATW
	BJR
DFILE:	20-0501-A-104.DWG
JECT No.	20-0501.00
ET TITLE	MAIN CAMPUS THIRD FLOOR COMPOSITE PLAN
ET NUMBER	

ITEM NUMBER





SYMBOL LEGEND		
TWO LINE SYMBOLS	SCHEMATIC SYMBOLS	DESCRIPTION
		PIPING ELBOW
		PIPING ELBOW UP
		PIPING ELBOW DOWN
		PIPING TEE
		PIPING TEE UP
		PIPING TEE DOWN
		DIELECTRIC UNION OR FLANGE CONNECTION
		ISOLATION VALVE
		GATE VALVE
		CHECK VALVE
		BUTTERFLY VALVE
		SOLENOID VALVE
		BALL VALVE
		GLOBE VALVE
		LUBRICATED PLUG VALVE
		BALANCE VALVE
		CONTROL VALVE - 2 WAY
		CONTROL VALVE - 3 WAY
		BACKWATER VALVE
		STRAINER
		THERMOMETER
		PRESSURE GAUGE WITH BALL VALVE
		CIRCUIT SETTER
		FLOW METER
		PIPE EXPANSION LOOP
		PIPE ANCHOR
		PIPE GUIDE
		CONCRETE THRUST BLOCK
		FLOW ARROW
		FIRE DAMPER HORIZONTAL POSITION
		COMBINATION FIRE/SMOKE DAMPER HORIZONTAL POSITION
		FIRE DAMPER VERTICAL POSITION
		COMBINATION FIRE/SMOKE DAMPER VERTICAL POSITION
		FIRE PROTECTION FLOW SWITCH
		FIRE PROTECTION TAMPER SWITCH
		MOTORIZED DEVICE
		SUPPLY AIR CEILING DIFFUSER
		RETURN AIR REGISTER OR GRILLE
		EXHAUST AIR REGISTER OR GRILLE
		FLEXIBLE DUCT
		SPIN-IN FITTING WITH VOLUME DAMPER (TO BOTTOM OF DUCT)
		SPIN-IN FITTING WITH VOLUME DAMPER (TO SIDE OF DUCT)
		CONCENTRIC REDUCER (PIPE OR DUCT)
		ECCENTRIC REDUCER (PIPE OR DUCT)
		THERMOSTAT
		HUMIDISTAT
		TEMPERATURE CONTROL SENSOR

ABBREVIATIONS	
SYMBOL	DESCRIPTION
A.A.V.	AUTOMATIC AIR VENT
ABV	ABOVE
A.F.F.	ABOVE FINISHED FLOOR
A.H.U.	AIR HANDLING UNIT
A.S.R.	AUTOMATIC SPRINKLER RISER
B.D.O.	BOTTOM OF DUCT
B.O.P.	BOTTOM OF PIPE
B.W.V.	BACK WATER VALVE
C.A.	COMPRESSED AIR
CHWP	CHILLED WATER PUMP
C.I.	CAST IRON
C.O.	CLEAN OUT
CONN.	CONNECTION
C.W.	COLD WATER
C.W.P.	CONDENSER WATER PUMP
C.V.	CONTROL VALVE
D.C.W.	DOMESTIC COLD WATER
DN	DOWN
D&T	DRIP AND TRAP
E.W.C.	ELECTRIC WATER COOLER
E.W.H.	ELECTRIC WATER HEATER
EXH.	EXHAUST
E.R.	EXHAUST REGISTER
F.D.	FLOOR DRAIN
FLR.	FLOOR
F.H.	FIRE HYDRANT
F.J.U.	Fixture Units (Drainage)
G.D.	GARBAGE DISPOSAL
G.V.	GATE VALVE
GL.V.	GLOBE VALVE
H.B.	HOSE BIBB
H.C.	HOSE CABINET
H.W.	HOT WATER
HYD.	HYDRANT
H.O.	HUB OUTLET
I.E.	INVERT ELEVATION
LAV.	LAVATORY
M.B.H.	THOUSAND BTUHR (BRITISH THERMAL UNITS PER HOUR)
M.H.	MANHOLE
N.I.C.	NOT IN CONTRACT
NK.	NECK
O.A.	OUTSIDE AIR
PCHWS	PRIMARY CHILLED WATER SUPPLY
PCHWR	PRIMARY CHILLED WATER RETURN
P.H.	PHYSICALLY HANDICAPPED
P.R.V.	PRESSURE REDUCING VALVE
P.T.	PLUGGED TEE
R.A.	RETURN AIR
R.A.F.	RETURN AIR FAN
R.C.	RAINWATER CONDUCTOR
R.C.(S)	RAINWATER CONDUCTOR SECONDARY

ABBREVIATIONS	
SYMBOL	DESCRIPTION
R.S.	ROOF SUMP
S.A.	SUPPLY AIR
SAN	SANITARY PIPE
SCHWS	SECONDARY CHILLED WATER SUPPLY
SCHWR	SECONDARY CHILLED WATER RETURN
S.S.	SERVICE SINK
T.A.D.	TRANSFER AIR DUCT
T.D.C.	TILE DRAIN CONNECTION
TYP.	TYPICAL
UR.	URINAL
V	VENT
VAV	VARIABLE AIR VOLUME BOX
VAVR	VARIABLE AIR VOLUME BOX WITH HOT WATER REHEAT
VAVRE	VARIABLE AIR VOLUME BOX WITH ELECTRIC REHEAT
V.T.R.	VENT THROUGH ROOF
V.D.	VOLUME DAMPER
V.O.	VALVED OUTLET
W	WASTE
W.C.	WATER CLOSET
W.C.O.	WALL CLEAN OUT
W.H.	WALL HYDRANT

MECHANICAL SHEET INDEX	
sheet	description
M-001	GENERAL MECHANICAL INFORMATION
MAIN CAMPUS	
M-101	PARTIAL LOWER LEVEL MECHANICAL PLAN
M-102	PARTIAL LOWER LEVEL MECHANICAL PLAN
M-103	PARTIAL FIRST FLOOR MECHANICAL PLAN
M-104	PARTIAL FIRST FLOOR MECHANICAL PLAN
M-105	SECOND AND THIRD FLOOR MECHANICAL PLANS
M-106	ROOF MECHANICAL PLAN
M-600	LOWER LEVEL AIR HANDLING UNIT ZONE PLAN
M-601	FIRST FLOOR AIR HANDLING UNIT ZONE PLAN
M-602	SECOND FLOOR AIR HANDLING UNIT ZONE PLAN
M-603	BOILER ROOM SECTION DIAGRAM
M-604	STEAM AND CONDENSATE BUILDING DIAGRAM
M-605	STEAM AND CONDENSATE BOILER DIAGRAM
M-606	CHILLED WATER SYSTEM BUILDING DIAGRAM
M-607	CHILLED WATER/ICE STORAGE PIPING SCHEMATIC
M-608	CHILLED WATER PIPING DIAGRAM
SERVICE/UTILITY BUILDING	
M-101	FIRST FLOOR MECHANICAL PLAN
GROUNDS/MAINTENANCE	
M-101	FIRST FLOOR MECHANICAL PLAN
FARM BUILDINGS	
M-101	BASEMENT MECHANICAL PLAN
M-102	FIRST FLOOR MECHANICAL PLAN
M-103	SECOND FLOOR MECHANICAL PLAN
PLANETARIUM	
M-001	BASEMENT AND FIRST FLOOR MECHANICAL PLANS
M-002	SECOND FLOOR AND ROOF MECHANICAL PLANS



Since 1969

DiClemente Siegel  
Design Inc.  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com

These documents are instruments of service for use solely  
with respect to this project. DSD reserves the right to make changes  
as deemed by its authors and owners of their respective  
instruments of service and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purpose of  
constructing, using and maintaining this project.

These documents are traditional plan and specification  
documents that are not intended to be used by the contractor  
as shop drawings. Final dimensions, locations, access,  
clearances, miscellaneous fittings, final installations and  
coordination is the contractor's responsibility.

A/E SEAL

PRELIMINARY  
NOT FOR CONSTRUCTION

NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
FACILITIES  
CONDITION  
ASSESSMENT  
UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

DATE ISSUED FOR:

9/30/20 FINAL

03/20/20 OWNER PROGRESS REVIEW


DESIGNER: KLE  
MODELLER: JDL  
PM: ATW  
PIC: BJR  
ACADFILE: 20-0501.MDWG  
PROJECT NO: 20-0501.00  
SHEET TITLE: MECHANICAL GENERAL INFORMATION

SHEET NUMBER

M-001

XREF: 20-0501-1B  
XREF: 20-0501-APL  
XREF: 20-0501-MPL

LEVEL KEY PLAN





# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

1105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



se documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyright. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to shop drawings. Final dimensions, equipment sizing, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design

DESIGNER:	KLE
MODELLER:	JDL
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501M-102.DWG
PROJECT N:	20-0501-02

PROJECT NO. 20-0501.00  
SHEET TITLE  
**MAIN CAMPUS**  
**PARTIAL LOWER LEVEL**  
**MECHANICAL PLAN**

## MECHANICAL PLAN


SET NUMBER  
**M 102**

A circular north arrow icon with a black diagonal line from the top-left to the bottom-right. The word "NORTH" is printed in black capital letters to the left of the circle.

**PARTIAL LOWER LEVEL  
MECHANICAL PLAN**

SCALE : 1/32" = 1'-0"

0      16      32      64      Feet





# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

1105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedonline.com](http://www.dedonline.com)



se documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of inspecting, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Signal Design Inc.

<b>DESIGNER:</b>	KLE
<b>MODELLER:</b>	JDL
<b>PM:</b>	ATW
<b>PIC:</b>	BJR
<b>ACADFILE:</b>	20-0501-W-103.DWG
<b>PROJECT No:</b>	20-0501 00

PROJECT NO. 20-333455  
SHEET TITLE  
**MAIN CAMPUS  
PARTIAL FIRST FLOOR  
MECHANICAL PLAN**

**SHEET NUMBER**

# PARTIAL FIRST FLOOR PLAN

## MECHANICAL PLAN

SCALE : 1/32" = 1'-0"





# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

1105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



se documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of inspecting, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

## SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design

DESIGNER:	KLE
MODELLER:	JDL
PM:	ATW
PIC:	BJR
ACADFILE:	200501-M-104.DWG
PROJECT No.	20_0501_00


PROJECT NO. 20-0501.00

SHEET TITLE

MAIN CAMPUS  
PARTIAL FIRST FLOOR  
MECHANICAL PLAN


## SHEET NUMBER

**STREET NUMBER**



# PARTIAL FIRST FLOOR PLAN MECHANICAL PLAN

A scale bar and north arrow are located at the top left of the map. The scale bar shows distances of 0, 16, 32, and 64 feet. A north arrow indicates the cardinal direction.








**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



ROOF MECHANICAL PLAN

NORTH  MECHANICAL FLOOR  
SCALE: 1" = 50'

A scale bar with a circular end on the left. The text "SCALE: 1 : 60" is above the bar. Below the bar, numerical markings are present at 0, 25, 50, and 100, followed by the word "Feet".

NER:	KLE
LLER:	JDL
	ATW
	BJR
FILE:	20-0501-M-106.DWG
ECT No.	20-0501.00

## MAIN CAMPUS

## MAIN CAMP 03 ROOF

## MECHANICAL PLAN

NUMBER

M 106

M-100

---



# Celebrating 50 Years

The logo consists of two blue interlocking circular arrows forming a stylized 'P' shape.

# **DiClemente Siegel Design Inc.**

## **ARCHITECTURE & ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

REAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**



# DELTA COLLEGE

# ACILITIES ONDITION SSESSMENT

©2020 DiClemente Siegel Design Inc.

#### Legend

	AH-01		AH-19		AH-37
	AH-02		AH-20		AH-38
	AH-03		AH-21		AH-39
	AH-04		AH-22		AH-40
	AH-05		AH-23		AH-41
	AH-06		AH-24		AH-42
	AH-07		AH-25		AH-43
	AH-08		AH-26		AH-44
	AH-09		AH-27		AH-45
	AH-10		AH-28		Levered 24Hr Continuous
	AH-11		AH-29		Unit Ventilation
	AH-12		AH-30		Unit Heater
	AH-13		AH-31		Cabinet Heater
	AH-14		AH-32		Fin Tube
	AH-15		AH-33		Radiant Panel
	AH-16		AH-34		No Air Handling
	AH-17		AH-35		Air Intakes
	AH-18		AH-36		



 Lower Level – Heating & Cooling


The image shows a detailed architectural floor plan of a building. The plan includes numerous rooms, each labeled with a name such as 'BED ROOM', 'BATH', 'KITCHEN', 'LIVING ROOM', 'STUDY', 'DINING', 'BALCONY', 'STOREROOM', and 'W.C.'. A central corridor runs through the middle of the building. On the left side, there is a vertical corridor with several doors. A large room on the left is labeled 'AH-22'. A blue triangle is located in the bottom-left corner of the image, pointing towards the building's entrance area.

GNER:	KLE
ELLER:	JDL
	ATW
	BJR
FILE:	20-0501-W-600.DWG
ECT No.	20-0501.00
T TITLE	

# LOWER LEVEL AIR HANDLING UNIT ZONE PLAN

# ITEM NUMBER

# M-600



 First Floor — Heating & Cooling



# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.

IGNER:	KLE
SELLER:	JDL
	ATW
	BJR
DFILE:	20-0501-M-601.DWG
JECT No.	20-0501.00

# FIRST FLOOR AIR HANDLING UNIT

**NET NUMBER**

M-601



**DiClemente Siegel  
Design Inc.**  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd. Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com

These documents are traditional plan and specification documents that are not intended to be used by the contractor as shop drawings. Final decisions, equipment access, piping, miscellaneous fittings, installation and coordination is the contractor's responsibility.


A/E SEAL  
**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
FACILITIES  
CONDITION  
ASSESSMENT  
UNIVERSITY CENTER, MICHIGAN


©2020 DiClemente Siegel Design Inc.

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL
03/2020	OWNER PROGRESS REVIEW

DESIGNER:	KLE
MODELER:	JDL
PM:	ATW
PIC:	BUR
ACADFILE:	202001A402.DWG
PROJECT No:	20-0501.00
SHEET TITLE	SECOND FLOOR AIR HANDLING UNIT ZONE PLAN
SHEET NUMBER	M-602



Second Floor – Heating & Cooling





se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
uments of service and shall retain all common law,  
actory and other reserved rights, including copyrights.  
e grants to the owner a nonexclusive license to reproduce  
s instruments of service solely for the purposes of  
constructing, using and maintaining this project.

se documents are traditional plan and specification

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**SEAL**

---

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE

# ACILITIES CONDITION ASSESSMENT


## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	KLE
ELLER:	JDL
	ATW
	BJR
DFILE:	20-0501-M-603.DWG
JECT No.	20-0501.00
ET TITLE	

# BOILER ROOM ZT01

## SECTION DIAGRAM



## BOILER ROOM SECTION (LOOKING SOUTH)

**BOL**  
NO ESCA

M-603



Since 1969

# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

28105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedonline.com](http://www.dedonline.com)




These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.



**STEAM AND CONDENSATE SYSTEM BUILDING/TUNNEL PIPING SCHEMATIC**

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
1/30/20	FINAL
1/30/2020	OWNER PROGRESS REVIEW
DESIGNER:	KLE
MODELLER:	JDL
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-M-604.DWG
PROJECT No.	20-0501.00
SHEET TITLE	
<b>STEAM AND CONDENSATE BUILDING SYSTEM SCHEMATIC DIAGRAM</b>	
SHEET NUMBER	
<b>M-604</b>	




Since 1969

# DiClemente Siegel Design Inc.

## ARCHITECTURE

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedonline.com](http://www.dedonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
em the authors and owners of their respective  
ments of service and shall retain all common law,  
try and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
 instruments of service solely for the purposes of  
ructing, using and maintaining this project.

Documents are traditional plan and specification  
ments that are not intended to be used by the contractor  
op drawings. Final dimensions, equipment access,  
g, miscellaneous fittings, final installation and  
lination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE

# ACILITIES CONDITION ASSESSMENT

## VERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

	ISSUED FOR:
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
0	FINAL
20	OWNER PROGRESS REVIEW

OWNER:	KLE
SELLER:	JDL
	ATW
	BJR
FILE:	20-0501-M-605.DWG
ECT No.	20-0501.00

M-605



Since 1969

# **DiClemente Siegel Design Inc.**

## ARCHITECTURE & ENGINEERING

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedonline.com](http://www.dedonline.com)

 Delta College

e documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
documents of service and shall retain all common law,  
copyright and other reserved rights, including copyrights,  
grants to the owner a nonexclusive license to reproduce  
such instruments of service solely for the purposes of  
constructing, using and maintaining this project.


The documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

# PRELIMINARY NOT FOR CONSTRUCTION

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# ACILITIES ONDITION SSESSMENT

## VERSITY CENTER, MICHIGA



CHILLED WATER SYSTEM BUILDING/TUNNEL PIPING SCHEMATIC

E	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
20	FINAL
.	.
GNER:	.
ELLER:	.
	ATW
	BJR
FILE:	20-0501-M-606.DWG
JECT No.	20-0501.00
ET TITLE	HILLED WATER SYSTEM BUILDING/TUNNEL PIPING DIAGRAM
ET NUMBER	M-606



The documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce the documents as instruments of service solely for the purposes of constructing, using and maintaining this project.

The documents are traditional plan and specification

The documents are traditional plan and specification  
ments that are not intended to be used by the contractor  
to prepare drawings. Final dimensions, equipment access,  
clearing, miscellaneous fittings, final installation and  
coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# ACILITIES ONDITION SSESSMENT

©2020 DiClemente Siegel Design Inc.

CHILLED WATER/ICE STORAGE&CONDENSER WATER PIPING SCHEMATIC

---

NO SCA

REF ID: A1000000000000000000000000000000

ITEM NUMBER

M-607

[View Details](#)



**DiClemente Siegel  
Design Inc.**  
ARCHITECTURE & ENGINEERING

28105 Greenfield Rd. Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com



These documents are instruments of service for use solely by their respective clients. DSD does not claim title to any of the drawings or designs contained herein. It is the intent of the author and owner of the respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a non-exclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor as shop drawings. Final dimensions, elevations, access, piping, miscellaneous fittings, final installations and coordination is the contractor's responsibility.

A/E SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

## DELTA COLLEGE FACILITIES CONDITION ASSESSMENT UNIVERSITY CENTER, MICHIGAN


©2020 DiClemente Siegel Design Inc.

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL

DESIGNER:	.
MODELER:	.
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-1B.DWG
PROJECT NO:	20-0501.00
SHEET TITLE	CHILLED WATER PIPING DIAGRAM

SHEET NUMBER

M-608



VALVE SCHEDULE														
#	Tag	Line Service	Size	Valve	2W GPM	OK GPM	VLV	VALVE	ADJ. PD	CNTL	FAIL ACTIVATOR	TYPE	VALVE	
V1	MBV-1	Main Sys Bending	15	15	3W	8F	4500	5829	0.5	2AV	100	0-10 VDC	N	RE0302-15-WNA
V2	MV-1	Ice Make Up Control	15	15	3W	8F	4500	5829	0.5	2AV	100	0-10 VDC	N	RE0302-15-WNA
V3	CHV-1A	CHV-1A	10	10	3W	8F	4500	5829	0.5	2AV	100	0-10 VDC	N	RE0302-15-WNA
V4	CHV-1B	CHV-1B	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V5	CHV-2A	CHV-2A	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V6	CHV-2B	CHV-2B	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V7	CHV-3A	CHV-3A	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V8	CHV-3B	CHV-3B	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V9	CHV-3B	CHV-3B	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V10	CHV-4A	CHV-4A	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V11	CHV-4B	CHV-4B	10	10	3W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V12	IMFV-1	Ice Min/Max Flow Byp	16	16	2W	8F	4500	5829	0.5	2AV	100	0-10 VDC	N	RE0302-15-WNA
V13	MIV-1	Chiller Min Flow Byp	12	6	2W	2000	941	733	0.4	2AV	100	0-10 VDC	N	RE0302-15-WNA
V14	CTV-1A	CTV-1A	12	12	2W	8F	2400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WNA
V15	CTV-1A	Tow er 1 Inlet	10	10	2W	8F	3400	5880	0.2	2AV	100	2 Position	N	RE15P2-15-WHA
V16	CTV-2A	Tow er 2 Inlet	8	8	2W	8F	2400	3540	0.5	2AV	50	2 Position	N	RE15P2-15-WHA
V17	CTV-3A	Tow er 3 Inlet	8	8	2W	8F	2400	3540	0.5	2AV	50	2 Position	N	RE15P2-15-WHA
V18	CTV-3B	Tow er 3 Inlet	8	8	2W	8F	2400	3540	0.5	2AV	50	2 Position	N	RE15P2-15-WHA
V19	CTV-4A	Tow er 4 Inlet	8	8	2W	8F	2400	3540	0.5	2AV	50	2 Position	N	RE15P2-15-WHA
V20	CTV-4B	Tow er 4 Inlet	8	8	2W	8F	2400	3540	0.5	2AV	50	2 Position	N	RE15P2-15-WHA
V21	CHV-1C	CHV-1C	10	10	2W	8F	2400	5880	0.2	2AV	50	2 Position	N	RE15P2-15-WNA
V22	CHV-1D	CHV-1D	10	10	2W	8F	2400	5880	0.2	2AV	50	2 Position	N	RE15P2-15-WNA
V23	CHV-1E	CHV-1E	12	12	2W	8F	2400	6080	0.1	2AV	50	2 Position	N	RE15P2-15-WNA
V24	CHV-2C	CHV-2C	12	12	2W	8F	2400	6080	0.1	2AV	50	2 Position	N	RE15P2-15-WNA
V25	CHV-2D	CHV-2D	12	12	2W	8F	2400	6080	0.1	2AV	50	2 Position	N	RE15P2-15-WNA
V26	CHV-2E	CHV-2E	12	12	2W	8F	2400	6080	0.1	2AV	50	2 Position	N	RE15P2-15-WNA
V27	MUV-1	MUV-1	3	3	2W	8F	680	457	0.5	2AV	150	2 Position	N	RE58-3

FLOW METER SCHEDULE													
TAG	SERVICE	SIZE	GPM	ABB Model #	FLOW RATE MEASUREMENT OUTPUTS ARE SCALABLE								
FM-1	System Load Total Flow	18	6000	FEF121-4500K15A18TD1CA2B3A1M50WA									
FM-2	Chiller Measuring Total Flow	15	6000	FEF121-400K15A18TD1CA2B3A1M50WA									
FM-3	East Loop Flow	12	4000	FEF121-300K15A18TD1CA2B3A1M50WA									
FM-4	West Loop Flow	12	4000	FEF121-300K15A18TD1CA2B3A1M50WA									

CHILLED WATER PIPING DIAGRAM  
NTS

APPROVAL APPROVED BY: \_\_\_\_\_  
APPROVAL DATE: \_\_\_\_\_

VALVE SCHEDULE
See page 14

VALVE SCHEDULE	PROJ. ID	NUM.	REV.	DATE	BT
CHILLER PLANT	20-0501	1	3	06/2020	00000
LEARN CENTER	20-0501	1	3	06/2020	00000
COLLEGE HALL	20-0501	1	3	06/2020	00000

REVISION

BT

NAME

DESIGNED BY

CHANGED BY

DATE

REMOVED BY

REPLACED BY

RELOCATED BY

</div



Since 1969

**DiClemente Siegel  
Design Inc.**  
**ARCHITECTURE  
& ENGINEERING**

28105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com



These documents are instruments of service for use solely  
in connection with this project. DSD grants no general license and  
it is understood that the authors and owners of their respective  
instruments of service and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

A/E SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
**FACILITIES  
CONDITION  
ASSESSMENT**  
UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

<b>ELECTRICAL SHEET INDEX</b>	
SHEET	DESCRIPTION
E-001	ELECTRICAL GENERAL INFORMATION
MAIN CAMPUS	
E-011	COMPOSITE LOWER LEVEL ELECTRICAL PLAN
E-012	COMPOSITE FIRST FLOOR ELECTRICAL PLAN
E-013	COMPOSITE SECOND & THIRD FLOORS ELECTRICAL PLANS
E-101	PARTIAL LOWER LEVEL ELECTRICAL PLAN
E-102	PARTIAL LOWER LEVEL ELECTRICAL PLAN
E-103	PARTIAL FIRST FLOOR ELECTRICAL PLAN
E-104	PARTIAL FIRST FLOOR ELECTRICAL PLAN
E-105	SECOND AND THIRD FLOORS ELECTRICAL PLANS
SERVICE/UTILITY BUILDING	
E-101	FIRST FLOOR ELECTRICAL PLAN
GROUNDS/MAINTENANCE	
E-101	FIRST FLOOR MECHANICAL PLAN
FARM BUILDINGS	
E-101	ELECTRICAL SITE PLAN
E-102	BASEMENT ELECTRICAL PLAN
E-103	FIRST FLOOR ELECTRICAL PLAN
E-104	SECOND FLOOR ELECTRICAL PLAN
PLANETARIUM	
E-001	PLANETARIUM BASEMENT & FIRST FLOOR ELECTRICAL PLANS
E-002	PLANETARIUM SECOND FLOOR ELECTRICAL PLAN

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL

DESIGNER:	TBR
MODELER:	DDA
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-E001.DWG
PROJECT No:	20-0501.00
SHEET TITLE	ELECTRICAL GENERAL INFORMATION

SHEET NUMBER  
**E-001**



se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
uments of service and shall retain all common law,  
lutory and other reserved rights, including copyrights.  
e grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

\_\_\_\_\_

IGNER: **TBR**

SELLER: DDA

ATW

BJR

DFILE: 20-0501-E-011.DWG

JECT No. 20-0501.00

## SET TITLE

LOWER LEVEL

# COMPOSITE

# ELECTRICAL PLAN


**REF ID:** 100-00000000

ITEM NUMBER

E-011

---

Digitized by srujanika@gmail.com




NORTH

# LOWER LEVEL COMPOSITE ELECTRICAL PLAN

SCALE: 1" = 50'

0      25      50      100      Feet



Since 1969

**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedonline.com](http://www.dedonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
ermed the authors and owners of their respective  
ments of service and shall retain all common law,  
ory and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor to draw up drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DETA COLLEGE

# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Signal Design Inc.

	ISSUED FOR:
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
0	FINAL
00	OWNER PROGRESS REVIEW


SNER:	TBR
ELLER:	DDA
	ATW
	BJR
FILE:	20-0501-E-012.DWG
ECT No.	20-0501.00

# FIRST FLOOR

# COMPOSITE ELECTRICAL PLAN

Ε 013

L-012



NC

# **FIRST FLOOR COMPOSITE ELECTRICAL PLAN**

SCAL



**Delta College**

The documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. This grants to the owner a nonexclusive license to reproduce these instruments of service solely for the purposes of inspecting, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to draw up drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and

EAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

# DELTA COLLEGE

# ACILITIES ONDITION SSESSMENT


©2020 DiClemente Signal Design Inc.

GNER:	TBR
ELLER:	DDA
	ATW
	BJR
FILE:	200501-E-013.DWG
JECT No.	20_0501_00

**COND & THIRD FLOORS  
COMPOSITE  
ELECTRICAL PLANS**

NET NUMBER

E-013





**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
named the authors and owners of their respective  
ments of service and shall retain all common law,  
try and other reserved rights, including copyrights.  
ants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ucting, using and maintaining this project.

documents are traditional plan and specification documents that are not intended to be used by the contractor to drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**AL**

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DETA COLLEGE



# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.

NER:	TBR
LLER:	DDA
	ATW
	BJR
FILE:	20-0501-E-101.DWG
ECT No.	20-0501.00
TITLE	


**MAIN CAMPUS  
1ST FLOOR  
ELECTRICAL**

NUMBER



# PARTIAL LOWER LEVEL ELECTRICAL PLAN

SCALE : 1/32" = 1'-0"





DiClemente Siegel  
Design Inc.  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd. Southfield, MI 48076-3046  
 248.569.1430 Fax: 248.569.0096  
 Website: www.dsdesign.com



These documents are instruments of service for use solely  
with respect to this project. DSD and its contractors shall  
be deemed the authors and owners of their respective  
instruments and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a non-exclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification  
documents that are not intended to be used by the contractor  
as shown here. Final decisions, access, coordination,  
miscellaneous fittings, piping, installation and  
coordination is the contractor's responsibility.


A/E SEAL


**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
FACILITIES  
CONDITION  
ASSESSMENT  
UNIVERSITY CENTER, MICHIGAN

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL

DESIGNER:	TBR
MODELLER:	DOA
PM:	ATW
PIC:	BUR
ACADFILE:	20-0501-00
PROJECT No:	20-0501.00
SHEET TITLE:	MAIN CAMPUS LOWER LEVEL ELECTRICAL PLAN
SHEET NUMBER:	E-102






These documents are instruments of service for use solely  
as shown hereon. Final decisions, all rights reserved,  
shall be deemed to the authors and owners of their respective  
instruments and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a non-exclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are not intended to be used by the contractor  
as shop drawings. Final decisions, all rights reserved,  
including, miscellaneous fittings, piping, installation and  
coordination is the contractor's responsibility.

A/E SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.



NORTH  
KEY PLAN  
NO SCALE

DELTA COLLEGE  
FACILITIES  
CONDITION  
ASSESSMENT  
UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.


DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL

DESIGNER:	TBR
MODELER:	DOA
PM:	ATW
PIC:	BUR
ACADFILE:	20-0501-E13DNG
PROJECT No:	20-0501.00

SHEET TITLE:  
MAIN CAMPUS  
1ST FLOOR  
ELECTRICAL

SHEET NUMBER:

E-103



# **DiClemente Siegel Design Inc.**

## **ARCHITECTURE & ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dedenline.com](http://www.dedenline.com)




se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
uments of service and shall retain all common law,  
actory and other reserved rights, including copyrights.  
 grants to the owner a nonexclusive license to reproduce  
's instruments of service solely for the purposes of  
structing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor as shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and

SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**






# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design I



IGNER:	TBR
SELLER:	DDA
	ATW
	BJR
DFILE:	20-0501-E-104.DWG
JECT No.	20-0501.00
ET TITLE	<p style="text-align: center;"><b>MAIN CAMPUS FIRST FLOOR ELECTRICAL PLAN</b></p>
ET NUMBER	<p style="text-align: center;"><b>E-104</b></p>





**DiClemente Siegel  
Design Inc.**


**ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. This grants to the owner a nonexclusive license to reproduce these instruments of service solely for the purposes of inspecting, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.




# DELTA COLLEGE

# ACILITIES ONDITION SSESSMENT

## VERSITY CENTER, MICHIGAN

	ISSUED FOR:
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
20	FINAL
/20	OWNER PROGRESS REVIEW

GNER:	REW
ELLER:	EKS
	ATW
	BJR
FILE:	20-0501A-101.DWG
JECT No.	20-0501.00
ET TITLE	SERVICE BUILDINGS OMPOSITE FIRST FLOOR RCHITECTURAL PLAN
ET NUMBER	




**FIRST FLOOR  
TRANSMITTER #2 COMPOSITE PLAN**

---

SCALE: 1/2" = 1'-0"





NORTH



# FIRST FLOOR TRANSMITTER #1 COMPOSITE PLAN

---

SCALE: 1/4" = 1'-0"



GNER:	REW
ELLER:	EKS
	ATW
	BJR
FILE:	20-0501-A-101.DWG
JECT No.	20-0501.00
ET TITLE	
SERVICE BUILDINGS	
COMPOSITE FIRST FLOOR	
ARCHITECTURAL PLAN	
ET NUMBER	
A-101	

A-101



These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**


# DETA COLLEGE

# ACILITIES CONDITION ASSESSMENT

## IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	KLE
SELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-M-101.DWG
JECT No.	20-0501.00
ET TITLE	
SERVICE BUILDINGS	
FIRST FLOOR	
MECHANICAL PLAN	
ET NUMBER	
M-101	




**FIRST FLOOR  
TRANSMITTER #2 MECHANICAL PLAN**


SCALE: 1/2" = 1'-0"

NORTH

0 1 2 4 Feet







NORTH




# FIRST FLOOR SALT/MATERIAL STOARGE COMPOSITE PLAN

SCALE: 1/8" = 1'-0"



0      4      8      16 Feet




NORTH



# FIRST FLOOR GENERAL STORAGE COMPOSITE PLAN

SCALE: 1/8" = 1'-0"





NORTH




# FIRST FLOOR POLE BUILDING COMPOSITE PLAN

---

SCALE: 1/8" = 1'-0"



0      4      8      16 Feet



NORTH



# FIRST FLOOR MAINTENANCE BUILDING COMPOSITE PLAN

SCALE: 1/8" = 1'-0"



IGNER:	REW
SELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-A-101.DWG
JECT No.	20-0501.00
ET TITLE	

MINTON BUILDINGS  
COMPOSITE FIRST FLOOR  
ARCHITECTURAL PLAN

A-101



se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
uments of service and shall retain all common law,  
utory and other reserved rights, including copyrights.  
grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
structing, using and maintaining this project.

se documents are traditional plan and specification

**PRELIMINARY**

**NOT FOR CONSTRUCTION**


---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# ACILITIES CONDITION ASSESSMENT IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	REW
ELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-A-101.DWG
JECT No.	20-0501.00
ET TITLE	MINTAINANCE BUILDINGS OMPOSITE FIRST FLOOR ARCHITECTURAL PLAN
ET NUMBER	




NORTH



# FIRST FLOOR SALT/MATERIAL STOARGE MECHANICAL PLAN

SCALE: 1/8" = 1'-0"






NORTH



# FIRST FLOOR GENERAL STORAGE MECHANICAL PLAN

SCALE: 1/8" = 1'-0"





ELECT./  
STORAGE  
X100

A schematic diagram of a vehicle exhaust system component, showing a cross-section of a pipe with internal baffles or valves. The word "EXHAUST" is printed above the drawing.

5

EF

EF

The diagram illustrates a system layout with several labeled components:

- ELECT. / STORAGE**
- HVU CONTROL 2 PANEL**
- MAIN GAS MONITOR PANEL**
- ELECT. / JC**
- VIN1**
- HVU-1 (ERV-1)**
- UH**
- AC-1**
- WS-1**


NORTH



# FIRST FLOOR MAINTENANCE BUILDING MECHANICAL PLAN

SCALE: 1/8" = 1'-0"





These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor as shop drawings. Final dimensions, equipment access, routing, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

A/E SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

©2020 DiClemente Siegel Design Inc.

DESIGNER:	KLE
MODELLER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-M-101.DWG
PROJECT No.	20-0501.00
SHEET TITLE	<p><b>MAINTENANCE BUILDINGS</b></p> <p><b>FIRST FLOOR</b></p> <p><b>MECHANICAL PLAN</b></p>
SHEET NUMBER	<p><b>M-101</b></p>



# HOTCHKISS

# ROAD

NORTH

**FARM HOUSE & BUILDINGS  
COMPOSITE SITE PLAN**

SCALE: 1" = 30'

0 15 30 60 Feet


DESIGNER:	REW
MODELLER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-A-101.DWG
PROJECT No.	20-0501.00

A-101



**DICLEMENTE SIEGEL  
DESIGN INC.  
ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



**NORTH**

**BASEMENT BARN COMPOSITE PLAN**

---

SCALE: 1/8" = 1'-0"

0 4 8 16 Feet

**NORTH**

**BASEMENT FARM HOUSE COMPOSITE PLAN**

SCALE: 1/8" = 1'-0"

0      4      8      16      Feet

DESIGNER:	REW
MODELLER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-A-102.DWG
PROJECT No.	20-0501.00
SHEET TITLE	FARM HOUSE & BUILDINGS COMPOSITE BASEMENT ARCHITECTURAL PLAN
SHEET NUMBER	A-102

A-102



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



The documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of constructing, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE


# ACILITIES ONDITION SSESSMENT

## IVERSITY CENTER, MICHIGAN


©2020 DiClemente Siegel Design Inc.

GNER:	REW
ELLER:	EKS
	ATW
	BJR
FILE:	20-0501-A-103.DWG
JECT No.	20-0501.00
ET TITLE	ARM HOUSE & BUILDINGS OMPOSITE FIRST FLOOR RCHITECTURAL PLAN
ET NUMBER	

A-103



The logo consists of a circular compass rose with a north arrow pointing upwards. The word "NORTH" is written vertically to the left of the circle. To the right of the circle, the text "BARN FIRST FLOOR" is stacked above "COMPOSITE PLAN" in large, bold, sans-serif capital letters. Below this, the scale "SCALE: 1/8\" data-bbox="380 210 490 230"/> = 1'-0" is centered. At the bottom is a horizontal scale bar with tick marks at 0, 4, 8, and 16.








**NORTH**

**OLD GARAGE FIRST FLOOR  
COMPOSITE PLAN**

SCALE: 1/8" = 1'-0"

0      4      8      16      Feet





**DiClemente Siegel  
Design Inc.**


**ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



e documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce these instruments of service solely for the purposes of inspecting, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.




# DELTA COLLEGE

# ACILITIES ONDITION SSESSMENT

## VERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

GNER:	REW
ELLER:	EKS
	ATW
	BJR
FILE:	20-0501-A-104.DWG
JECT No.	20-0501.00
ET TITLE	ARM HOUSE & BUILDINGS MPOSITE SECOND FLOOR ARCHITECTURAL PLAN
ET NUMBER	




**OLD GARAGE SECOND FLOOR  
COMPOSITE PLAN**

NORTH

SCALE: 1/4" = 1'-0"

0 2 4 8 Feet



NORTH

FARM HOUSE SECOND FLOOR  
COMPOSITE PLAN

SCALE: 1/8" = 1'-0"

0 4 8 16 Feet



# DiClemente Siegel Design Inc.

## ARCHITECTURE & ENGINEERING

1105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



These documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights. DSD grants to the owner a nonexclusive license to reproduce DSD's instruments of service solely for the purposes of constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DETA COLLEGE

# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.




# **NORTH**

# BASEMENT FARM HOUSE MECHANICAL PLAN

SCALE: 1/8" = 1'-0"





DESIGNER:	KLE
MODELLER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-M101.DWG
PROJECT No.	20-0501.00
SHEET TITLE	FARM HOUSE BASEMENT MECHANICAL PLAN
SHEET NUMBER	M-101



DiClemente Siegel  
Design Inc.  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd. Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesign.com



These documents are instruments of service for use solely  
in connection with this project. DSD grants no rights and shall  
not be deemed to be the authors and owners of their respective  
instruments of service and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a non-exclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification  
documents that are not intended to be used by the contractor  
as shop drawings. Final dimensions, elevations, access  
ways, openings, miscellaneous fittings, piping, installations and  
coordination is the contractor's responsibility.

AE SEAL


**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
FACILITIES CONDITION ASSESSMENT  
UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL
03/2020	OWNER PROGRESS REVIEW

DESIGNER:	KLE
MODELER:	EKS
PM:	ATW
PIC:	BUR
ACADFILE:	2020-0501.00
PROJECT No:	20-0501.00
SHEET TITLE	FARM HOUSE FIRST FLOOR MECHANICAL PLAN
SHEET NUMBER	M-102




NORTH  
FARM HOUSE FIRST FLOOR  
MECHANICAL PLAN  
SCALE: 1/8" = 1'-0"  
0 4 8 16 Feet



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



**NORTH**

**FARM HOUSE SECOND FLOOR  
MECHANICAL PLAN**

SCALE: 1/8" = 1'-0"

0      4      8      16      Feet

IGNER:	KLE
ELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-M-103.DWG
JECT No.	20-0501.00
ET TITLE	FARM HOUSE SECOND FLOOR MECHANICAL PLAN
ET NUMBER	M-103

# HOTCHKISS ROAD



# FARM HOUSE & BUILDINGS ELECTRICAL SITE PLAN

SCALE: 1" = 30'



se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
uments of service and shall retain all common law,  
actory and other reserved rights, including copyrights.  
It grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

A rectangular stamp with a black border. The word "SEAL" is at the top left. The main text "PRELIMINARY" is on top in large bold letters, followed by "NOT FOR CONSTRUCTION" in a slightly smaller bold font. Below this is a horizontal line. At the bottom, the text "NOT FOR USE FOR BIDDING, CONSTRUCTION, OR ORDERING OF MATERIALS." is centered in a smaller font.


# ACILITIES CONDITION ASSESSMENT

## IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	TBR
ELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-E-101.DWG
JECT No.	20-0501.00
ET TITLE	RM HOUSE & BUILDINGS ELECTRICAL SITE PLAN
ET NUMBER	


E-101



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)





# BASEMENT FARM HOUSE ELECTRICAL PLAN

NORTH


SCALE: 1/8" = 1'-0"



0      4      8      16      Feet

IGNER:	TBR
SELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-E-102.DWG
JECT No.	20-0501.00
ET TITLE	
RM HOUSE & BUILDINGS BASEMENT FLOOR ELECTRICAL PLAN	
ET NUMBER	
<b>E-102</b>	

E-102



**FARMHOUSE BARN FIRST FLOOR ELECTRICAL PLAN**

NORTH

SCALE: 1/8" = 1'-0"

Page	Section	Description
1	1	MAIN PANEL
2	2	WATER PUMP
3	3	WATER TOWER
4	4	WATER TOWER
5	5	WATER TOWER
6	6	WATER TOWER
7	7	WATER TOWER
8	8	WATER TOWER
9	9	WATER TOWER
10	10	WATER TOWER
11	11	WATER TOWER
12	12	WATER TOWER
13	13	WATER TOWER
14	14	WATER TOWER
15	15	WATER TOWER
16	16	WATER TOWER

**NORTH**

**FARMHOUSE PAVILION  
ELECTRICAL PLAN**

SCALE: 1/8" = 1'-0"

0 4 8 16 Feet


**NORTH**






**FARMHOUSE  
TOOL SHED FIRST FLOOR  
ELECTRICAL PLAN**

---

SCALE: 1/8" = 1'-0"



0      4      8      16      Feet



The image shows a circular north arrow pointing towards the top-left. To its left, the word "NORTH" is written vertically. To the right of the north arrow, the words "SHED ELECTRICAL PLAN" are written in large, bold, pink letters. Below this, the scale "SCALE: 1/8\" data-bbox="470 350 720 380"/> = 1'-0" is displayed. At the bottom, a scale bar shows increments of 0, 4, and 8, with a vertical line extending from the 10 mark.

se documents are instruments of service for use solely  
respect to this project. DSD and DSD's consultants shall  
be deemed the authors and owners of their respective  
documents of service and shall retain all common law,  
copyright and other reserved rights, including copyrights,  
which grants to the owner a nonexclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification documents that are not intended to be used by the contractor for shop drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS**

DELTA COLLEGE  
ACILITIES  
CONDITION  
ASSESSMENT  
IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

IGNER:	TBR
SELLER:	EKS
	ATW
	BJR
DFILE:	20-0501-E103.DWG
JECT No.	20-0501.00
ET TITLE	RM HOUSE & BUILDINGS FIRST FLOOR ELECTRICAL PLAN
ET NUMBER	

E-103



DiClemente Siegel  
Design Inc.  
ARCHITECTURE  
& ENGINEERING

28105 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: www.dsdesignonline.com



These documents are instruments of service for use solely  
in connection with this project. DSD and its contractors shall not  
be deemed the authors and owners of their respective  
instruments of service and shall retain all common law,  
statutory and other reserved rights, including copyrights.  
DSD grants to the owner a non-exclusive license to reproduce  
DSD's instruments of service solely for the purposes of  
constructing, using and maintaining this project.

These documents are traditional plan and specification  
documents that are not intended to be used by the contractor  
as shop drawings. Final dimensions, locations, access,  
grading, miscellaneous fittings, final installations and  
coordination is the contractor's responsibility.

A/E SEAL

**PRELIMINARY  
NOT FOR CONSTRUCTION**  
NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.

DELTA COLLEGE  
**FACILITIES CONDITION ASSESSMENT**  
UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.



DATE	ISSUED FOR:
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
.	.
9/30/20	FINAL

DESIGNER:	TBR
MODELER:	EKS
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-E104.DWG
PROJECT NO:	20-0501.00

SHEET TITLE  
**FARM HOUSE & BUILDINGS  
SECOND FLOOR  
ELECTRICAL PLAN**

SHEET NUMBER

E-104



NORTH **FARMHOUSE SHED SECOND FLOOR  
ELECTRICAL PLAN**  
SCALE: 1/4" = 1'-0"  
0 2 4 8 Feet

NORTH **FARM HOUSE SECOND FLOOR  
ELECTRICAL PLAN**  
SCALE: 1/8" = 1'-0"  
0 4 8 16 Feet

E-104





**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

5 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)

This architectural floor plan illustrates a building's layout across three levels. The top level features Classroom 6 (223) and Classroom 5 (221). A central vertical corridor, labeled CORR. 275E, contains Stair #3 (275F) leading up. To the left of this corridor is an open area. Below the central corridor, there is a women's restroom (WOMEN T. 219) and an alcove (ALCOVE 200B). A balcony (BALCONY 200) is located on the left side of the central corridor. A circular area at the top right contains Stair #1 (275B), an elevator (ELEV.), and a vestibule (VESTIBULE 275A). The middle level includes Classroom 4 (212), Classroom 1 (213), Classroom 2 (215), and Classroom 3 (217). It also contains an electrical room (ELEC. 216), an A/V equipment room (A/V EQUIP. 214), a janitor's closet (JAN. 209), a vending area (VENDING 211), and a corridor (CORRIDOR 275C). The bottom level shows a staircase (STAIR #4 275G) leading down to a catwalk (CATWALK 218). Other labels include 375A, OPEN, and ROOF.

**SECOND FLOOR  
COMPOSITE PLAN**


---

NORTH

SCALE: 1/16" = 1'-0"



0      8      16      32



**ROOF COMPOSITE PLAN**

NORTH

SCALE: 1/16" = 1'-0"

0 8 16 32 Feet

documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall inform the authors and owners of their respective instruments of service and shall retain all common law, statutory and other reserved rights, including copyrights. It grants to the owner a nonexclusive license to reproduce the instruments of service solely for the purposes of inspecting, using and maintaining this project.

g, miscellaneous fittings, final installation and  
ination is the contractor's responsibility.

**PRELIMINARY**  
**NOT FOR CONSTRUCTION**  
**NOT FOR USE FOR BIDDING,**  
**CONSTRUCTION, OR**  
**ORDERING OF MATERIALS.**

# DELTA COLLEGE

# ACILITIES CONDITION ASSESSMENT

## IVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

NER:	REW
LLER:	EKS
	ATW
	BJR
FILE:	20-0501-A-002.DWG
ECT No.	20-0501.00
TITLE	PLANETARIUM COND FLOOR & ROOF ARCHITECTURAL PLAN

NUMBER  
A-002



# Celebrating 50 Years

**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
ermed the authors and owners of their respective  
ments of service and shall retain all common law,  
ory and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
 instruments of service solely for the purposes of  
ructing, using and maintaining this project.

Documents are traditional plan and specification documents that are not intended to be used by the contractor to draw up drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

---

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**


# DETAILED ACILITIES ONDITION SSESSMENT VERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

	ISSUED FOR:
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
0	FINAL
20	OWNER PROGRESS REVIEW

OWNER:	TBR
SELLER:	DDA
	ATW
	BJR
FILE:	200501-E-001.DWG
ECT No.	20-0501.00
PT TITLE	

# PLANETARIUM SEGMENT & FIRST FLOOR ELECTRICAL PLAN




**NORTH**

**BASEMENT FLOOR  
ELECTRICAL PLAN**

SCALE: 1/16" = 1'-0"

0 8 16




NORTH

**FIRST FLOOR  
ELECTRICAL PLAN**

SCALE: 1/16" = 1'-0"

0 8 16 32



T NUMBER



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
emed the authors and owners of their respective  
ments of service and shall retain all common law,  
ory and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ructing, using and maintaining this project.

Documents are traditional plan and specification documents that are not intended to be used by the contractor to draw. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

DETA COLLEGE

# FACILITIES CONDITION ASSESSMENT

UNIVERSITY CENTER, MICHIGAN

©2020 DiClemente Siegel Design Inc.

	ISSUED FOR:
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
	.
0	FINAL
00	OWNER PROGRESS REVIEW




GNER:	KLE
ELLER:	EKS, JDL
	ATW
	BJR
FILE:	200501-M-001.DWG
ECT No:	20_0501_00

**LECTURE HALL  
T TITLE**

**PLANETARIUM  
SEGMENT & FIRST FLOOR  
MECHANICAL PLAN**

# ITEM NUMBER

# M-001



T NUMBER  
**M-001**



**DiClemente Siegel  
Design Inc.**

**ARCHITECTURE  
& ENGINEERING**

05 Greenfield Rd Southfield, MI 48076-3046  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



documents are instruments of service for use solely  
spect to this project. DSD and DSD's consultants shall  
emed the authors and owners of their respective  
ments of service and shall retain all common law,  
ory and other reserved rights, including copyrights.  
rants to the owner a nonexclusive license to reproduce  
instruments of service solely for the purposes of  
ructing, using and maintaining this project.

Documents are traditional plan and specification documents that are not intended to be used by the contractor to draw. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.



**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# ACILITIES ONDITION SESSMENT VERSITY CENTER MICHIGAN

©2020 DiClemente Siegel Design Inc.

OWNER:	KLE
SELLER:	EKS, JDL
	ATW
	BJR
FILE:	20-0501-M-002.DWG
ECT No.	20-0501.00
TTITLE	PLANETARIUM SECOND FLOOR & ROOF MECHANICAL PLAN
T NUMBER	M-002



A cyan line drawing of a stylized, abstract shape. The shape features several vertical and horizontal segments, with a prominent central vertical line that tapers at the top and bottom. To the left of this central line, there's a horizontal segment that slopes down to the right. To the right of the central line, there's another horizontal segment that slopes down to the left. A small circular loop is attached to the right side of the central line. The overall form is somewhat organic and abstract, resembling a stylized figure-eight or a letter 'M'.

 KEY PLAN  
NO SCALE

M-002



# **DiClemente Siegel Design Inc.**

## **ARCHITECTURE & ENGINEERING**

105 Greenfield Rd Southfield, MI 48076-3048  
248.569.1430 Fax: 248.569.0096  
Website: [www.dsdonline.com](http://www.dsdonline.com)



The documents are instruments of service for use solely with respect to this project. DSD and DSD's consultants shall be deemed the authors and owners of their respective documents of service and shall retain all common law, statutory and other reserved rights, including copyrights, which grants to the owner a nonexclusive license to reproduce such instruments of service for the purposes of constructing, using and maintaining this project.

The documents are traditional plan and specification documents that are not intended to be used by the contractor to prepare drawings. Final dimensions, equipment access, piping, miscellaneous fittings, final installation and coordination is the contractor's responsibility.

**EAL**

---

**PRELIMINARY  
NOT FOR CONSTRUCTION**

**NOT FOR USE FOR BIDDING,  
CONSTRUCTION, OR  
ORDERING OF MATERIALS.**

# DELTA COLLEGE

# FACILITIES CONDITION ASSESSMENT

## UNIVERSITY CENTER MICHIGAN



©2020 DiClemente Siegel Design Inc.

DESIGNER:	TBR
MODELLER:	DDA
PM:	ATW
PIC:	BJR
ACADFILE:	20-0501-E-002.DWG

SHEET TITLE

PLANETARIUM  
SECOND FLOOR  
ELECTRICAL PLAN

SHEET NUMBER



KEY PLAN  
NO SCALE

E-002